

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month June, 2024		Day : Sunday				Date : 30.06.24							
Probable Maximum Demand :		15200 MW		Probable Maximum Generation :		14029 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 82.24 ft		Today = 82.06 ft		Rule Curve = 83.46 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.06.24 (Yesterday)		30.06.24 (Today)		29.06.24 (Yesterday) Gen. shortfall for :	(Yesterday) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
<b>(A) Plants in operation:</b>													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under Repowering project	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	240		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	110	110	110	110	80		Gas Shortage	
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0				
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	380	450	450	450				
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
9	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	400	0	0	0	0				
10	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
11	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	316	322	324	324				
12	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	284	300	280	300	35		Gas Shortage	
13	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	25	10	10	10				
14	Gaganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	81	24	81				
15	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	0	0				
16	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	31	30	31	31				
17	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	15	16	16	16				
18	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	12	14	16				
19	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	8				
20	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	50	52	70				
21	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	144	48	149				
22	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
23	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	260	268	263	270				
24	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	119	131	115	130				
25	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	55	55				
26	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
27	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	17	52				
28	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	162	162	162	162				
29	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	35	0				
30	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	35	35	35				
31	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	13	0	13				
32	Unique Meghnaghat 584MW CAPP	Gas (IPP)	1x400+1x184	584	584	0	0	0	0	584		Gas Shortage	
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	33	46	40	50				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	94	82	80	82				
35	Meghnaghat 100 MW(IEL)	HFO (NENP)	12x8.9	100	100	23	16	16	16				
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0	589		Gas Shortage	
<b>Dhaka Zone Total</b>				<b>5828</b>	<b>5634</b>	<b>2078</b>	<b>2503</b>	<b>2294</b>	<b>2539</b>	<b>1738</b>	<b>740</b>		
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	138	137	114	135	93		Inadequate Water Level	
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0				
39	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17				
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0				
41	Patenga 50MW PP (Baraka)	HFO (IPP)	6x6.89	50	50	6	6	6	6				
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	87	51	51	51				
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	222	220	222				
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	52	52	52				
46	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	49	62	49	62				
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	42	85	85	85				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	55	54	55				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	17	10	20				
49	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	19	19	19	19				
50	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.64	54	54	0	54	54	54				
51	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	68	105	51	110				
52	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	50	50	50	50				
53	Juldah 100 MW Unit-1 (Acorn)	HFO (NENP)	8x13.45	100	100	0	35	35	35				
54	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	58	17	60				
55	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	163	54	163				
56	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	600	590	612	612				
57	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	1x575	575	575	520	520	550	550				
58	Cox's Bazar Wind PP	(Wind) (PP)		60	60	54	62	44	62				
59	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)		75	75	1	0	70	0				
<b>Chattogram Zone Total</b>				<b>4517</b>	<b>4457</b>	<b>1990</b>	<b>2360</b>	<b>2230</b>	<b>2420</b>	<b>273</b>	<b>330</b>		
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	34	10	10	10	35		Gas Shortage	
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1'75	221	221	217	206	210	210				
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	240	240	240	240			Gas Shortage	
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	280	310	280	310	50		Gas Shortage	
64	Ashuganj 420 MW CAPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	230	230	170		Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'116	195	195	0	0	0	0	195		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	60	65	90	110				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	35	35	35	35				
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	50	70	70	70				
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	0	0	0				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	43	25	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	114	50	114				
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	37	100	90	100				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	50	115	90	115				
78	Ashuganj 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	0	5	5	5	50		Gas Shortage	
**	Impoport (Tripura)	India		160	160	66	78	146	142				
<b>Cumilla Zone Total</b>				<b>2883</b>	<b>2875</b>	<b>1448</b>	<b>1693</b>	<b>1643</b>	<b>1806</b>	<b>620</b>	<b>0</b>		
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	20	20	20	20	182		Gas Shortage	
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	68	87	68	68				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	95	143	116	145				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	12	0	50	0				
84	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
85	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	12						

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.06.24 (Yesterday)		30.06.24 (Today)		29.06.24 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	10	40	28	40		30	Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	68	68	68	68		22	Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	50	51				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	120	163	163	163				
90	Hobiganj 11 MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	0	2	2				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	60	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	208	210	205	210				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	11	12	11	12				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	320	300	320				
97	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	340	398	365	400				
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	340	355	350	355				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under Construction Project	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	36	36	36	36				
<b>Sylhet Zone Total</b>					<b>2376</b>	<b>2331</b>	<b>1495</b>	<b>1715</b>	<b>1638</b>	<b>1717</b>	<b>0</b>	<b>382</b>	
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	325	340	285	340		70	Gas Shortage	
103	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	14	41	30	41				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	21	40	50	60				
105	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
106	Russha 105 MW PP (Orion russha)	HFO (IPP)	6x18.445	105	105	0	69	25	53				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	2x617	100	100	6	0	100	0				
109	Maitree Super Thermal 1320 MW PP	Coal (BIF/PCL)	1234	1234	723	812	790	820	820				
110	Khulna 330 MW CCPP	Gas/HSD (RPP)	1x220+1x116	336	336	0	0	0	0				
111	Nasipara 40 MW PP (Khanjahan Ali)	HFO NENP	5x8.5	40	40	0	8	8	8				
112	Khulna 115 PP MW (KPCL-2)	HFO NENP	7x17	115	115	0	32	16	32				
**	Bheramara (H/VD)	India		1000	1000	913	922	927	927				
<b>Barisal Zone Total</b>					<b>3858</b>	<b>3854</b>	<b>2002</b>	<b>2264</b>	<b>2231</b>	<b>2281</b>	<b>70</b>	<b>0</b>	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	110	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	4	9	10	10				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130		64	ST under maint.	
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	540	610	622	622		622	Unit-1 under maint.	
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	35	35	35				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	220	307	220	307				
119	Barisal 1 MW Solar PP	Solar (PDB)	1 x 1	1	1	0	0	0	0				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220				
<b>Barishal Zone Total</b>					<b>2266</b>	<b>2236</b>	<b>1125</b>	<b>1421</b>	<b>1347</b>	<b>1434</b>	<b>0</b>	<b>686</b>	
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
121	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	32	40	32	40				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	10				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	88	50	88				
125	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	48	36	48				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	25	35				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	178	200	200	200				
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	292	414	400	414				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	5	5	5				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
133	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	95	60	95				
134	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	113	113	113				
135	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	35	35	35				
136	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	0	0	0	0		1496	Unit 1 & 2 UM	
<b>Raidhahi Zone Total</b>					<b>3403</b>	<b>3381</b>	<b>575</b>	<b>1075</b>	<b>962</b>	<b>1083</b>	<b>501</b>	<b>1596</b>	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	62	60	60	60				
137	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	220	200	220				
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16.2*3	113	113	70	113	113	113				
141	Sardpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Majpara Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0				
143	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	93	90	94				
144	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	9	0	30	0				
145	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	98	0	130	0				
<b>Rangpur Zone Total</b>					<b>1030</b>	<b>950</b>	<b>495</b>	<b>486</b>	<b>631</b>	<b>487</b>	<b>0</b>	<b>85</b>	
<b>Sub-total: Plants in operation</b>					<b>26815</b>	<b>26364</b>	<b>11427.0</b>	<b>13796</b>	<b>13261</b>	<b>14029</b>	<b>3384</b>	<b>3819</b>	
<b>(B) Plants under long term maintenance/ contract expired</b>													
146	Katbott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			Contract Expired	
147	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	0	0	0	0	0			Contract Expired	
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			Contract Expired	
149	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	0	0	0	0	0			Contract Expired	
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Contract Expired	
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>700</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>					<b>27515</b>	<b>26364</b>	<b>11427</b>	<b>13796</b>	<b>13261</b>	<b>14029</b>	<b>3384</b>	<b>3819</b>	
<b>(C) Actual data of 29.06.24 (Yesterday) Saturday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 14000 MW, at = 20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 13305 MW, at = 20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	: 13796 MW, at = 20:00 hrs		MW	MW	MW		MW	MW	MW			
04.	Minimum Generation (Generation end)	: 11427 MW, at = 9:00 hrs	Dhaka	5050	4949	101	Mymensingh	1020	1020	0			
05.	Day-peak Generation (Generation end)	: 11427 MW, at = 9:00 hrs	Chattogram	1168	1168	0	Sylhet	525	525	0			
06.	Evening-peak Generation (Generation end)	: 13796 MW, at = 20:00 hrs	Khulna	1612	1546	66	Barishal	422	422	0			
07.	Evening Peak Load-shed (Sub-station end)	: 195 MW, at = 20:00 hrs	Rajshahi	1464	1464	0	Rangpur	901	873	28			
08.	Minimum Generation Forecast up to 8.00 hrs.	: 11601 MW, at = 5:00 hrs	Cumilla	1143	1143	0							
09.	Generation shortfall at evening peak due to :	:	13.	Fuel cost :	Total		Total		13110	195			
	a) Gas/LF limitation	: 3291 MW		a) Gas =	405945754 Taka		c) Coal =		490297931 Taka				
	d) Coal supply Limitation	: 0 MW		b) Oil =	121218084 Taka		Total =		2108361769 Taka				
	b) Low water level in Kaptai lake	: 93 MW											
	c) Plants under shut down/ maintenance	: 3819 MW	14.	Maximum Temperature in Dhaka was : 31.9°C									
10.	Total Energy (Generation + India Import)	: 297.59 MCKWh	15.	Export through East-West interconnections :									
	By Gas = 131.871 MCKWh	By Oil = 65.770 MCKWh		At evening peak-hour	: 11427 MW, at 20:00 hrs								
	By Coal = 70.000 MCKWh	By Hydro = 3.396 MCKWh		Maximum	: 86 MW, at 21:00 hrs								
	By Solar = 1.582 MCKWh			Energy	: 3182.85 MCKWh								
11.	Total Gas Supplied	: 964.18 MCMCFD											
<b>(D) Forecast of 30.06.24 (Today) Sunday :</b>													
01.	Maximum Demand	: 15200 MW (Generation end)	04.	Maximum Load-shed : 1108 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 14029 MW (Generation end)	05.	Total Generation : 327.88 MCKWh									
03.	Reserve / Shortage	: -1171 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 31.9°C									

#Remarks: Highest Generation 16477 MW on 30-04-2024 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation