

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 12-Aug-20

Page -2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present | Peak | Generov | Remarks |
|------------------------------|---------------------------------------|-----------------------|---------------------|-------------|-------------|-----------------|--------------------------|
| | | | | Capacity | Hour | Generated | |
| | | | Unit No. X Capacity | MW | MW | MW | |
| 1 | Ghorasal TPP (Unit-1&2) | PDB | 2*55 | 85 | 33 | 690000 | Unit-2 Under maint. |
| | Ghorasal Repowered CAPP Unit-3 | PDB | 1*210 | 170 | 0 | 0 | Under maint. |
| | Ghorasal Repowered CAPP Unit-4 | PDB | 1*210 | 180 | 0 | 0 | Gas shortage |
| | Ghorasal TPP Unit-5 | PDB | 1*210 | 190 | 70 | 2016000 | Gas shortage |
| 2 | Ghorasal 365 MW CAPP Unit-7 | PDB | 1*243+1*122 | 365 | 290 | 6686900 | Under shut down |
| 3 | Ghorasal 78.5 MW PP(MAX) | QRPP | 2*40 | 78 | 0 | 0 | Gas shortage |
| 4 | Ghorasal 108MW PP (Regent) | IPP | 34*3.35 | 108 | 95 | 1292181 | Gas shortage |
| 5 | Haripur GTPP | SBU, PDB | 2*32 | 20 | 0 | 0 | Under maint. |
| 6 | Haripur 412 MW CAPP | EGCB | 1*273+1*139 | 412 | 0 | 0 | Under maint. |
| 7 | Haripur 360MW CAPP(HPL) | IPP | 1*235+1*125 | 360 | 352 | 7947000 | |
| 8 | Meghnaghat 450 MW CAPP(MPL) | IPP | 2*150+1*150 | 450 | 360 | 7934500 | |
| 9 | Meghnaghat 100 MW (IEL) | QRPP | 12*8.9 | 100 | 93 | 2265600 | Engine problem |
| 10 | Meghnaghat CAPP(Summit) | IPP | 2*110+1*110 | 305 | 285 | 7054895 | FGMO |
| 11 | Madanganj 102 PP(Summit) | QRPP | 6*17 | 100 | 79 | 2022192 | Engine problem |
| 12 | Madanganj-55 MW PP(Summit) | (IPP) | 3*17.08+1*11.3 | 55 | 55 | 869855 | |
| 13 | Keraniganj 100 MW PP (Powerpac) | QRPP | 8*13.45 | 100 | 88 | 508562 | High voltage |
| 14 | Narshingdi 22 MW PP (Doreen) | SIPP, REB | 8*2.90 | 22 | 22 | 379548 | |
| 15 | 210 MW Siddhirgonj TPP | PDB | 1*210 | 115 | 0 | 0 | Under maint. |
| 16 | Siddhirgonj 2*120 MW GTPP | EGCB | 2*105 | 210 | 0 | 403000 | Gas shortage |
| 17 | Siddhirgonj 100 PP(Dutch Bangla) | QRPP | 12*8.9 | 100 | 83 | 2016000 | |
| 18 | Siddhirgonj 335 MW CAPP | EGCB | 1*217+1*18 | 335 | 280 | 7288840 | FGMO |
| 19 | Gopnagar 102 MW PP (Digital Power) | IPP | 12*8.924 | 102 | 84 | 1859616 | Engine problem |
| 20 | Katpotti 52 MW PP (Sinha) | IPP | 7*7.9 | 51 | 35 | 445776 | Engine problem |
| 21 | Kamalaghat 54 MW PP(Banco Energy) | IPP | 3*18 | 54 | 53 | 1175040 | |
| 22 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 149 | 2030400 | |
| 23 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 55 | 1045927 | |
| 24 | Nababganj 55 MW PP (Southern power) | IPP | 3*19.3 | 55 | 55 | 708080 | |
| 25 | Bosila 108MW PP(CLO) | IPP | 12*8.775+1*3.5 | 108 | 0 | 0 | Fuel Shortage |
| 26 | Summit Power (Madhabadi+Ashulla) | SIPP, REB | 3*3.67+4*8.73 | 80 | 55 | 1243680 | Engine problem |
| 27 | Masana 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 33 | 813900 | |
| 28 | Rupganj 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 33 | 821300 | |
| 29 | Gazipur 52 MW PP | IPP | 6*8.9 | 52 | 52 | 486816 | |
| 30 | Tongi 80 MW GTPP | PDB | 1*105 | 105 | 0 | 0 | Under maint. |
| 31 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 18*17.076 | 300 | 300 | 6854834 | |
| 32 | Keraniganj 300 MW PP (APR) | IPP | 256*1.4 | 300 | 51 | 59610 | Low demand |
| 33 | Bramhanngan 100 MW PP (Aggreko) | IPP | 100 | 100 | 0 | 0 | Reserve |
| 34 | Auraha 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 100 | 0 | 0 | Reserve |
| 35 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 149 | 149 | 131 | 3056580 | Engine problem |
| 36 | Gazipur 100 MW PP | RPCL | 100 MW | 105 | 52 | 1522476 | Low demand |
| | Meghnaghat 104 MW PP (OPCL) | IPP | 18.5*6 | 104 | 104 | 2544960 | |
| | | | | 5895 | 3387 | 74035168 | |
| Dhaka area Total | | | | | | | |
| 37 | Chattogram TPP-1 | PDB | 1*210 | 180 | 0 | 0 | Gas shortage. |
| | Chattogram TPP-2 | PDB | 1*210 | 180 | 0 | 0 | Gas shortage. |
| 38 | Raozan 25 MW PP | IPP | 3*8.9 | 25 | 8 | 102724 | Low demand |
| 39 | Teknaf 20MW PP (Sclartech) | Teknaf SolarTech Ener | 20 | 20 | 0 | 123660 | |
| 40 | Patenga 50MW PP (Baraka) | IPP | 6*8.98 | 50 | 50 | 494880 | |
| 41 | Kapali Hydro: Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 154 | 3292575 | Low water level |
| 42 | Sikalbaha 225MW | PDB | 1*150+1*175 | 225 | 229 | 5383256 | |
| 43 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 109 | 3022410 | |
| 44 | Sikalbaha 105 MW PP (Baraka Sikalbah) | IPP | 105 MW | 105 | 0 | 0 | Reserve |
| 45 | Hathazari 100 MW peaking PP | PDB | 11*8.9 | 98 | 0 | 0 | Under maint. |
| 46 | Dohazari -Kalaish 100 MW Peaking | PDB | 6*17 | 102 | 68 | 385382 | Low demand |
| 47 | Juddah 100 MW Unit-1 (Acom) | QRPP | 8*13.45 | 100 | 0 | 0 | Reserve |
| 48 | Juddah 100 MW PP Unit-3 (Acom) | IPP | 0 | 100 | 100 | 2408640 | |
| 49 | Barabkunda 22 MW PP (Regent) | SIPP, PDB | 8*2.90 | 22 | 18 | 433872 | |
| ** | Malancha, Ctg. EPZ (Unites) | Imported power | 5*8.73+3*9.34 | 29 | 0 | 551520 | |
| 50 | Chattogram 108 MW PP (ECPPV) | IPP | 16*7 | 108 | 97 | 1589760 | Engine problem |
| 51 | Kapali 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 28080 | |
| 52 | Anwara 300 MW PP (United) | IPP | 300 MW | 300 | 197 | 4481236 | Low demand |
| 53 | Jodiak Power | IPP | 3*18.55+1*3.6 | 54 | 0 | 0 | Reserve |
| 54 | Karnaphuli Power Ltd. | IPP | 110 | 110 | 0 | 0 | Reserve |
| | Juddah Unit-2 (Acom) | IPP | 8*13.6 | 100 | 100 | 2361600 | |
| | | | | 2266 | 1159 | 24595295 | |
| Chattogram area Total | | | | | | | |
| 55 | Ashuganj TPP Unit-3 | APSCL | 1*150 | 135 | 0 | 0 | Gas shortage. |
| | Ashuganj TPP Unit-4 | APSCL | 1*150 | 129 | 80 | 1968895 | Gas shortage. |
| | Ashuganj TPP Unit-5 | APSCL | 1*150 | 134 | 80 | 1943492 | Gas shortage. |
| 56 | Ashuganj 225 MW CAPP | APSCL | 1*142+1*175 | 221 | 212 | 4831000 | FGMO |
| 57 | Ashuganj 450 MW CAPP(North) | APSCL | 1*360 | 360 | 0 | 0 | Under maint. |
| 58 | Ashuganj 450 MW CAPP(South) | APSCL | 1*360 | 360 | 255 | 6839000 | FGMO |
| 59 | Ashuganj 50 MW PP | APSCL | 14*3.968 | 45 | 36 | 768528 | Engine problem |
| 60 | Ashuganj 55 MW PP (Precision) | RPP | 15*4 | 55 | 15 | 231360 | Gas shortage. |
| 62 | Ashuganj 195MW PP (APSCL-United) | IPP | 20*9.73+1*16 | 195 | 73 | 1304727 | Gas shortage. |
| 63 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 51 | 1180458 | |
| 64 | Ashuganj 150MW PP (Midland) | IPP | 23*10.5 | 150 | 135 | 2453884 | |
| 66 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 52 | 42 | 225624 | |
| 67 | Chandpur 150 MW CAPP | PDB | 1*106+1*57 | 163 | 85 | 2160937 | ST under maint. |
| 68 | Chandpur 200MW (Desh energy) | IPP | 0 | 200 | 170 | 877920 | |
| 69 | Feni 22MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 21 | 470556 | |
| 70 | Feni 11 MW PP (Doreen) | SIPP, REB | 4*2.90 | 11 | 8 | 201600 | |
| ** | Impoort (Tripura) | Imported power | 0 | 160 | 166 | 3471360 | |
| 71 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4*8.73 | 33 | 33 | 674800 | |
| 72 | Jangalia 52 MW PP (Lakshadweep) | IPP | 6*8.92 | 52 | 22 | 624168 | |
| 73 | Cumilla 25 MW PP (Summit) | SIPP, PDB | 3*3.67+2*6.97 | 25 | 19 | 422670 | Engine problem |
| 74 | Daudkandi 200 MW PP (B.Trac) | IPP | 154*1.4 | 200 | 0 | 0 | Reserve |
| | Feni Lanka Power | IPP | 7*18.415+1*9.78 | 114 | 114 | 1418160 | |
| | Chowmuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 56 | 1348200 | Fuel shortage |
| | | | | 2980 | 1673 | 33437596 | |
| Cumilla Area Total | | | | | | | |
| 75 | RPCL 210MW CAPP | IPP | 4*35+1*70 | 202 | 140 | 3443400 | Engine problem |
| 76 | Tangail 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 20 | 414900 | |
| 77 | Jamalpur 95 MW PP (Powerpac) | IPP | 12*8.924 | 95 | 72 | 1650240 | Engine problem |
| 78 | Sarishabadi 3 MW Solar Plant | IPP | 3 | 3 | 0 | 8400 | |
| 79 | Mymensingh 200 MW PP (United) | IPP | 200 | 200 | 200 | 4877600 | |
| 80 | Jamalpur 115 MW PP (United) | IPP | 115 MW | 115 | 115 | 1394400 | #REF! |
| | | | | 637 | 547 | 11588940 | |
| Mymensingh Area Total | | | | | | | |
| 81 | Fenchuganj CAPP Phase-1 | PDB | 2*32+1*33 | 70 | 86 | 2049000 | |
| 82 | Fenchuganj CAPP Phase-2 | PDB | 2*35+1*35 | 90 | 30 | 720120 | # 4 under maint. |
| 83 | Kushia 163 MW CAPP (KP) | IPP | 1*109+1*54 | 163 | 163 | 3671427 | |
| 84 | Shahjibazar 330 MW CAPP | PDB | 3*110 | 330 | 211 | 4830000 | |
| 85 | Fenchuganj 51 MW PP (Barakatullah) | RPP | 19*2.90 | 51 | 53 | 1205400 | |
| 86 | Fenchuganj 44MW (Energyprima) | RPP | 12*3.5+5*2 | 44 | 49 | 1158408 | |
| 87 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 4*2.90 | 11 | 11 | 193536 | |
| 88 | Shahjibazar GTPP Unit. 8 & 9 | PDB | 2*35 | 66 | 59 | 1294944 | FGMO & GT-8 under maint. |
| 89 | Shahjibazar 86MW PP (Shahjibazar) | RPP | 32*2.90 | 86 | 85 | 1963200 | |
| 91 | Sylhet 225 MW CAPP | PDB | 1*142+1*89 | 231 | 40 | 302410 | GT synchronized |
| 92 | Sylhet 20 MW GTPP | PDB | 1*20 | 20 | 18 | 419000 | |
| 93 | Sylhet 50MW PP (EPL) | RPP | 27*2 | 50 | 0 | 0 | Contract Expired |
| 94 | Shahjahanulla 25 MW PP | SIPP, REB | 3*9.34 | 25 | 24 | 582455 | |
| 95 | Biliana-II 341 MW CAPP (Summit) | IPP | 1*222+1*119 | 341 | 280 | 7272000 | FGMO |
| 96 | Biliana-II 400 MW CAPP | PDB | 400 MW | 400 | 0 | 0 | Under maint. |
| 97 | Sylhet 10MW PP (Desh) | RPP | 6*1.95 | 10 | 10 | 237600 | |
| | Biliana South 400 MW | PDB | 400 MW | 0 | 0 | 0 | On test |
| | | | | 1988 | 1119 | 25895500 | |
| Sylhet Area Total | | | | | | | |
| 98 | Bheramara GTPP Unit-3 | PDB | 1*20 | 16 | 0 | 0 | Reserve |
| ** | Bheramara (HVDC) | Imported power | 2*500 | 1000 | 916 | 21993455 | |
| 99 | Khulna 115 MW PP (KPCL-2) | QRPP | 7*17 | 115 | 115 | 2578560 | |
| 100 | Faridpur 50 MW Peaking PP | PDB | 6*8.89 | 54 | 0 | 0 | Reserve |
| 101 | Khulna 225 MW CAPP | NWPGCL | 1*150+1*175 | 230 | 220 | 3900612 | |
| 102 | Copalganj 100 MW Peaking PP | PDB | 16*8.9 | 109 | 0 | 0 | Reserve |
| 103 | Bheramara 410 MW CAPP | NWPGCL | 1*278+1*132 | 410 | 345 | 8504064 | FGMO |
| 104 | Noapara 40 MW PP (Khanjahan Ali) | QRPP | 5*8.5 | 40 | 40 | 765000 | |
| 105 | Noapara 100 MW PP (Bangla Trac) | IPP | 70*1.4 | 100 | 100 | 628800 | |
| 106 | Rupsha 105 MW PP (Orion rupsha) | IPP | 6*18.445 | 105 | 105 | 978720 | |
| 107 | Madhumati 100 MW PP | IPP | 100 MW | 105 | 0 | 0 | Reserve |
| | | | | 2284 | 1841 | 39349211 | |
| Khulna Area Total | | | | | | | |
| 108 | Barisal 110 MW PP (Summit) | IPP | 7*17.076 | 110 | 110 | 829440 | Engine problem |
| 110 | Bhola 33 MW PP (Venture) | RPP | 1*34.50 | 33 | 36 | 654995 | |
| 111 | Bhola 225 MW CAPP | PDB | 2*63+1*68 | 194 | 90 | 2160669 | GT-2 Under maint. |
| 112 | Bhola 95 MW PP (Aggreko) | QRPP | 86*1.10 | 95 | 77 | 18514178 | Engine problem |
| | Payra 1320 MW | BCPCL | 1*622 | 622 | 619 | 13370200 | |
| | | | | 1054 | 832 | 18876782 | |
| Barisal Area Total | | | | | | | |
| 113 | Baghabari 71 MW GTPP | PDB | 1*71 | 71 | 0 | 0 | Gas shortage. |
| | Baghabari 100 MW GTPP | PDB | 1*100 | 100 | 0 | 0 | Gas shortage. |
| 114 | Baghabari 50 MW Peaking PP | PDB | 6*8.9 | 52 | 50 | 338912 | |
| 115 | Bera 70 MW Peaking PP | PDB | 9*8.29 | 71 | 36 | 166836 | |
| 116 | Amnura 50 MW PP(Sinha) | QRPP | 7*7.79 | 50 | 0 | 0 | Fuel shortage |
| 117 | Katakhat 50 MW PP (Northern) | QRPP | 6*8.9 | 50 | 25 | 142427 | |
| 118 | Katakhat 50 MW Peaking PP | PDB | 6*7.9 | 50 | 47 | 296350 | |
| 119 | Sirajgonj Unit-1 225MW | NWPGCL | 1*150+1*175 | 210 | 0 | 0 | Gas shortage. |
| 120 | Sirajgonj Unit-2 225MW | NWPGCL | 1*150+1*175 | 220 | 158 | 4673945 | FGMO |
| 121 | Sirajgonj Unit-3 225MW | NWPGCL | 1*141 | 220 | 203</ | | |