

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 21-Oct-20

Page -2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | Peak Hour Generation | Energy Generated | Remarks |
|------------------------------|----------------------------------|-------------------------|--------------------|------------------|----------------------|------------------|--------------------------|
| | | | | | | | |
| 1 | Ghorasal TPP (Unit-1&2) | PDB | 2*95 | 85 | 0 | 0 | Unit-1,2 Under maint. |
| | Ghorasal Reservoir CAPP Unit-1 | PDB | 1*210 | 170 | 0 | 0 | Under maint. |
| | Ghorasal Reservoir CAPP Unit-2 | PDB | 1*210 | 180 | 100 | 2405000 | Gas shortage |
| | Ghorasal TPP Unit-5 | PDB | 1*210 | 190 | 115 | 2709000 | Gas shortage |
| 2 | Ghorasal 365 MW CAPP Unit-7 | PDB | 1*243+1*122 | 365 | 200 | 4795464 | Machin problem. |
| 3 | Ghorasal 78.5 MW PP(MAX) | QRPP | 2*40 | 78 | 0 | 0 | Gas shortage |
| 4 | Ghorasal 108MW PP (Regent) | IPP | 34*3.35 | 108 | 72 | 1708272 | Gas shortage |
| 5 | Haripur GTPP | SBU, PDB | 2*32 | 20 | 0 | 0 | Under maint. |
| 6 | Haripur 412 MW CAPP | EGCB | 1*273+1*139 | 412 | 0 | 0 | Under maint. |
| 7 | Haripur 360MW CAPP(HPL) | IPP | 1*235+1*125 | 360 | 354 | 7822000 | |
| 8 | Meghnaghat 450 MW CAPP(MPL) | IPP | 2*150+1*150 | 450 | 420 | 8738500 | Frequency control |
| 9 | Meghnaghat 100 MW(EL) | QRPP | 12*8.9 | 100 | 16 | 383600 | Fuel Shortage |
| 10 | Meghnaghat CAPP(Summit) | IPP | 2*110+1*110 | 305 | 305 | 6584560 | |
| 11 | Madanganj 102 PP(Summit) | QRPP | | 100 | 95 | 2185560 | |
| 12 | Madanganj-55.102 PP(Summit) | IPP | 3*17.08+1*11.3 | 55 | 55 | 1274703 | |
| 13 | Karaniganj 100 MW PP (Powerpac) | QRPP | 8*13.45 | 100 | 37 | 638724 | Engine problem |
| 14 | Narsingdi 22 MW PP (Doreen) | SIPP, REB | 8*2.90 | 22 | 19 | 363420 | |
| 15 | 210 MW Siddhirgonj TPP | PDB | 1*210 | 115 | 0 | 0 | Under maint. |
| 16 | Siddhirgonj 2*120 MW GTPP | EGCB | 2*105 | 210 | 140 | 3144000 | |
| 17 | Siddhirgonj 100 PP(Dutch Bangla) | QRPP | 12*8.9 | 100 | 7 | 418560 | Fuel Shortage |
| 18 | Siddhirgonj 335 MW CAPP | EGCB | 1*21+1*18 | 335 | 0 | 0 | Under Maintenance |
| 19 | Gagnagar 102 MW PP (Digital Po) | IPP | 12*8.924 | 102 | 16 | 395136 | Engine problem |
| 20 | Kapoti 52 MW PP (Sinha) | IPP | 7*7.9 | 51 | 0 | 0 | Fuel Shortage |
| 21 | Kamalaghat 54 MW PP(Banco En) | IPP | 3*18 | 54 | 54 | 951840 | |
| 22 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 150 | 1896000 | |
| 23 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 55 | 1246152 | |
| 24 | Nabaganj 55 MW PP (Southern) | IPP | 3*19.3 | 55 | 55 | 1270152 | |
| 25 | Bosila 108MW PP(CLC) | IPP | 12*8.775+1*3.5 | 108 | 0 | 0 | Fuel Shortage |
| 26 | Summit Power (Madhabadi-Ashuli) | SIPP, REB | 3*3.67+4*8.73 | 80 | 56 | 1299660 | Engine problem |
| 27 | Maona 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 33 | 753600 | |
| 28 | Rugganj 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 33 | 804600 | |
| 29 | Gazipur 52 MW PP | IPP | 6*8.9 | 52 | 52 | 381012 | |
| 30 | Tongi 80 MW GTPP | PDB | 1*105 | 105 | 0 | 0 | Under maint. |
| 31 | Kodda 300 MW PP Unit-2 (Summ) | IPP | 18*17.076 | 300 | 300 | 6009270 | |
| 32 | Karaniganj 300 MW PP (APR) | IPP | 256*1.4 | 300 | 0 | 152236 | Reserve. |
| 33 | Bramhangonj 100 MW PP (Aggr) | IPP | 100 | 100 | 50 | 148257 | Low demand |
| 34 | Aurahati 100MW PP (Aggreko) | IPP | 0.85*23+0.85*91 | 100 | 51 | 154811 | Low demand |
| 35 | Kodda 149 MW PP Unit-1 (Summ) | IPP | 149 | 149 | 149 | 3493010 | |
| 36 | Gazipur 100 MW PP | RPCL | 100 MW | 105 | 53 | 1600080 | Engine problem |
| | Meghnaghat 104 MW PP (QPCL) | IPP | 18*8*6 | 104 | 47 | 913920 | Fuel Shortage |
| Dhaka area Total | | | | 5896 | 3059 | 64683739 | |
| 37 | Chattogram TPP-1 | PDB | 1*210 | 180 | 115 | 2800000 | Gas shortage. |
| | Chattogram TPP-2 | PDB | 1*210 | 180 | 0 | 0 | Gas shortage |
| 38 | Raozan 25 MW PP | IPP | 3*8.9 | 25 | 25 | 303482 | |
| 39 | Teknaf 20MW PP (Solartech) | Teknaf Solartech Energa | 20 | 20 | 0 | 27405 | |
| 40 | Patenga 50MW PP (Baraka) | IPP | 8*6.98 | 50 | 50 | 859200 | |
| 41 | Kaptai Hydro Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 118 | 2807716 | |
| 42 | Sikalbaha 225MW | PDB | 1*150+1*75 | 225 | 217 | 4850356 | Low water level |
| 43 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 145 | 3035704 | |
| 44 | Sikalbaha 105 MW PP (Baraka Si) | IPP | 105 MW | 105 | 0 | 0 | Transformer overload |
| 45 | Hathazari 100 MW peaking PP | PDB | 11*8.9 | 98 | 8 | 52841 | Under maint. |
| 46 | Dohazari-Kalash 100 MW Peakin | PDB | 8*17 | 102 | 102 | 1046445 | |
| 47 | Jaldah 100 MW PP (Acorn) | QRPP | 8*13.45 | 100 | 100 | 788600 | FGMO |
| 48 | Jaldah 100 MW PP Unit-3 (Acorn) | IPP | 0 | 100 | 22 | 486720 | Engine problem |
| 49 | Barabkunda 22 MW PP (Regent) | SIPP, PDB | 8*2.90 | 22 | 20 | 365184 | |
| | * Malancha, Cig, EP2 (United) | | 5*8.73+3*9.34 | 0 | 17 | 463680 | |
| 50 | Chattogram 108 MW PP (ECPV) | IPP | 16*7 | 108 | 6 | 115200 | Engine problem |
| 51 | Kaptai 7 MW Solar PP | PDB | 7*4 MW | 7 | 0 | 19560 | |
| 52 | Anwara 300 MW PP (Unitec) | IPP | 300 MW | 300 | 160 | 3696400 | Transformer O/L. |
| 53 | Asiac Power | IPP | 3*18.55+1*3.6 | 54 | 54 | 7865116 | |
| 54 | Karnaphuli Power Ltd. | IPP | 110 | 110 | 0 | 0 | Transformer O/L. |
| | Jaldah unit-2 (Acorn) | IPP | 8*13.6 | 100 | 100 | 2392320 | |
| Chattogram area Total | | | | 2266 | 1259 | 24908329 | |
| 55 | Ashuganj TPP Unit-3 | APSCL | 1*150 | 135 | 0 | 0 | Gas shortage. |
| | Ashuganj TPP Unit-4 | APSCL | 1*150 | 129 | 70 | 1731625 | Gas shortage. |
| | Ashuganj TPP Unit-5 | APSCL | 1*150 | 134 | 0 | 0 | Gas shortage. |
| 56 | Ashuganj 225 MW CAPP | APSCL | 1*142+1*75 | 221 | 188 | 4628000 | FGMO |
| 57 | Ashuganj 450 MW CAPP(North) | APSCL | 1*360 | 360 | 250 | 6885700 | FGMO |
| 58 | Ashuganj 450 MW CAPP(South) | APSCL | 1*360 | 360 | 250 | 6488000 | FGMO |
| 59 | Ashuganj 50 MW PP | APSCL | 14*3.968 | 45 | 5 | 190296 | Gas shortage |
| 60 | Ashuganj 55 MW PP (Precision) | RPP | 15*4 | 55 | 5 | 138720 | Gas shortage |
| 62 | Ashuganj 195MW PP (APSCL-UR) | IPP | 20*9.73+1*16 | 195 | 8 | 217454 | Gas shortage. |
| 63 | Ashuganj 51 MW PP (Midland) | IPP | 8*6.34 | 51 | 51 | 1212130 | |
| 64 | Ashuganj 150MW PP (Midland) | IPP | 23*7.015 | 150 | 150 | 2959544 | |
| 66 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 52 | 0 | 44432 | |
| 67 | Chandpur 150 MW CAPP | PDB | 1*106+1*57 | 163 | 86 | 1971280 | ST Under maint |
| 68 | Chandpur 200MW (Desh energy) | IPP | 0 | 200 | 135 | 765120 | Engine problem |
| 69 | Feni 22MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 20 | 370980 | |
| 70 | Feni 11 MW PP (Doreen) | SIPP, REB | 4*2.90 | 11 | 10 | 201960 | |
| | * Import (Tritura) | | 0 | 160 | 132 | 3033440 | |
| 71 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4*8.73 | 33 | 20 | 484700 | |
| 72 | Jangalia 52 MW PP (Lakdanav) | IPP | 6*8.92 | 52 | 8 | 290741 | Low demand |
| 73 | Cumilla 25 MW PP (Summit) | SIPP, PDB | 3*3.67+2*6.97 | 25 | 22 | 485960 | Engine problem |
| 74 | Daudkandi 200 MW PP (B.Trac) | IPP | 154*1.4 | 200 | 0 | 0 | Reserve. |
| | Feni Lanka Power | IPP | 7*18.415+1*9.78 | 114 | 35 | 420660 | Engine problem |
| | Chowmuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 113 | 2610720 | |
| Cumilla Area Total | | | | 2980 | 1568 | 35134972 | |
| 75 | RPCL 210MW CAPP | IPP | 4*35+1*70 | 202 | 121 | 2943540 | Gas shortage |
| 76 | Tangal 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 20 | 374904 | |
| 77 | Jamalpur 95 MW PP(Powerpac) | IPP | 12*8.924 | 95 | 25 | 822720 | Engine problem |
| 78 | Sarishabari 3 MW Solar Plant | IPP | 1*3 | 3 | 0 | 8000 | |
| 79 | Mymensingh 200 MW PP (Unitec) | IPP | 200 | 200 | 200 | 4564800 | |
| 80 | Jamalpur 115 MW PP (Unitec) | IPP | 115 MW | 115 | 115 | 1822800 | #REF! |
| Mymensingh Area Total | | | | 637 | 461 | 10536664 | |
| 81 | Fenchugonj CAPP Phase-1 | PDB | 2*32+1*33 | 70 | 73 | 1730000 | |
| 82 | Fenchugonj CAPP Phase-2 | PDB | 2*35+1*35 | 90 | 43 | 1029720 | # 4 under maint. |
| 83 | Kushara 163 MW CAPP (KP) | IPP | 1*109+1*54 | 163 | 110 | 2677827 | Engine problem |
| 84 | Shajibazar 330 MW CAPP | IPP | 3*110 | 330 | 159 | 3534000 | FGMO & GT-2 under maint. |
| 85 | Fenchugonj 51 MW PP (Barakata) | RPP | 19*2.90 | 51 | 22 | 553200 | Engine problem |
| 86 | Fenchugonj 44MW (Energyprima) | RPP | 12*3.35+2 | 44 | 50 | 1119324 | |
| 87 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 4*2.90 | 11 | 11 | 243000 | |
| 88 | Shajibazar GTPP Unit-8 & 9 | PDB | 2*35 | 66 | 62 | 1406976 | FGMO |
| 89 | Shajibazar 86MW PP (Shajibaz) | RPP | 32*2.90 | 86 | 87 | 1896960 | |
| 91 | Sylhet 225 MW CAPP | PDB | 1*142+1*89 | 231 | 219 | 4671950 | Machin problem. |
| 92 | Sylhet 20 MW GTPP | PDB | 1*20 | 20 | 18 | 414000 | |
| 93 | Sylhet 50MW PP (EPL) | RPP | 2*20 | 50 | 0 | 0 | Contract Expired |
| 94 | Shahabnula 25 MW PP | SIPP, REB | 3*9.34 | 25 | 19 | 498960 | |
| 95 | Bibiana-II 341 MW CAPP (Summ) | IPP | 1*222+1*119 | 341 | 325 | 7113500 | FGMO |
| 96 | Bibiana-III 400 MW CAPP | PDB | 400 MW | 400 | 418 | 10132000 | |
| 97 | Sylhet 10MW PP (Desh) | RPP | 6*1.95 | 10 | 10 | 242640 | |
| | Bibiana South 400 MW | PDB | 400 MW | 0 | 0 | 0 | On test |
| Sylhet Area Total | | | | 1988 | 1626 | 37263757 | |
| 98 | Bheramara GTPP Unit-3 | PDB | 1*20 | 20 | 0 | 0 | Reserve. |
| | Bheramara HVDC | Imported power | 2*500 | 1000 | 919 | 22024727 | |
| 99 | Khulna 115 PP MW (KPCL-2) | QRPP | 7*17 | 115 | 115 | 1410240 | |
| 100 | Faridpur 50 MW Peaking PP | PDB | 8*6.89 | 54 | 16 | 119520 | |
| 101 | Khulna 225 MW CAPP | NWPGCL | 1*150+1*75 | 230 | 220 | 3679680 | |
| 102 | Gopalganj 100 MW Peaking PP | PDB | 16*6.98 | 109 | 0 | 0 | Reserve. |
| 103 | Bheramara 410 MW CAPP | NWPGCL | 1*278+1*132 | 410 | 220 | 6050880 | Gas shortage |
| 104 | Nopara 40 MW PP (Khanjahan 4) | IPP | 5*8.5 | 40 | 40 | 298500 | |
| 105 | Nopara 100 MW PP (Bangla Tr) | IPP | 70*1.4 | 100 | 100 | 448320 | |
| 106 | Rupsha 105 MW PP (Orion.rupsh) | IPP | 6*18.445 | 105 | 105 | 1847040 | |
| 107 | Madhumati 100 MW PP | SWPGCL | 100 MW | 105 | 0 | 16848 | Line O/L. |
| Khulna Area Total | | | | 2284 | 1735 | 35895755 | |
| 108 | Barisal 110 MW PP (Summit) | IPP | 7*17.076 | 110 | 97 | 1216512 | |
| 110 | Bhola 33 MW PP (Venture) | RPP | 1*34.50 | 33 | 28 | 612654 | |
| 111 | Bhola 225 MW CAPP | PDB | 2*183+1*68 | 194 | 0 | 0 | Under maint. |
| 112 | Bhola 95 MW PP (Aggreko) | QRPP | 96*1.19 | 95 | 95 | 1737178 | |
| | Payra 1320 MW | BCPCL | 1*622 | 622 | 550 | 12509400 | Line O/L. |
| Barisal Area Total | | | | 1054 | 770 | 16075744 | |
| 113 | Baghabari 71 MW GTPP | PDB | 1*71 | 71 | 0 | 0 | Gas shortage |
| | Baghabari 100 MW GTPP | PDB | 1*100 | 100 | 0 | 0 | Gas shortage. |
| 114 | Baghabari 50 MW Peaking PP | PDB | 6*8.9 | 52 | 43 | 197865 | |
| 115 | Bara 70 MW Peaking PP | PDB | 9*8.29 | 71 | 42 | 182572 | |
| 116 | Amnura 50 MW PP(Sinha) | QRPP | 7*7.79 | 50 | 20 | 379830 | Engine problem |
| 117 | Katakhal 50 MW PP (Northern) | QRPP | 6*8.9 | 50 | 0 | 0 | Fuel Shortage |
| 118 | Katakhal 50 MW Peaking PP | PDB | 6*8.7 | 50 | 38 | 219659 | |
| 119 | Sirajgonj Unit-1 225MW | NWPGCL | 1*150+1*75 | 210 | 0 | 0 | Gas Shortage |
| 120 | Sirajgonj Unit-2 225MW | NWPGCL | 1*150+1*75 | 220 | 143 | 3892300 | FGMO |
| 121 | Sirajgonj Unit-3 225MW | NWPGCL | 1*141 | 220 | 150 | 3849809 | FGMO |
| 122 | Sirajgonj 400 MW CAPP Unit-4 | SNWPGCL | 1*282+1*132 | 414 | 408 | 838 | |