

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	0	0	Unit-1,2 Under maint.
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	150	3224000	Gas shortage
	Ghorasal TPP Unit-5	PDB	1*210	190	115	2740500	Gas shortage
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	200	4735927	Machin problem.
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	12	291681	Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	0	0	Under maint.
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	267	7089000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	300	7476000	Gas shortage
9	Meghnaghat 100 MW(DEL)	QRPP	12*8.9	100	94	500160	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	150	3495331	GT-2 under shut down
11	Madanganj 102 PP(Summit)	QRPP	6*17	100	80	860712	Low demand
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	670310	
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	0	0	Reserve.
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	267732	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	32	1596000	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	100	894720	
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	0	0	Under Maintenance
19	Gagnagar 102 MW PP (Digital Po	IPP	12*8.924	102	94	1270800	
20	Katpott 52 MW PP (Srina)	IPP	7*7.9	51	0	0	
21	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1004760	
22	Kodda 150MW PP (Doreen)	BPDB-RPCL	9*17.06	149	100	349440	Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	342415	
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	35	135256	Low demand
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel Shortage
26	Summit Power,(Madhabdi+Ashulit	SIPP,REB	3*3.67+4*8.73	80	56	1282020	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	17	561700	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	25	559800	Engine problem
29	Gazipur 52 MW PP	IPP	6*8.9	52	51	500136	
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	296	1149163	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve.
33	Bramhanaganj 100 MW PP (Aggr	IPP	100	100	0	0	Reserve.
34	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	138	465264	Low demand
36	Gazipur 100 MW PP	RPCL	100 MW	105	101	1444872	
	Meghnaghat 104 MW PP (OPCL)	IPP	18*56	104	90	1480320	Unit Transformer problem
	Manikganj 162MW PP	IPP	9*18	0	0	391680	
Dhaka area Total				5895	2686	44781699	
37	Chattoagram TPP-1	PDB	1*210	180	115	2700000	Gas shortage.
	Chattoagram TPP-2	PDB	1*210	180	0	0	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	0	0	Reserve.
39	Teknaf 20MW PP (Solartech)Teknaf	SolarTech Energy	20	20	0	137160	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	738240	
41	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	161	3810945	Unit-2 under maint
42	Sikalaha 225MW	PDB	1*150+1*175	225	204	4888916	
43	Sikalaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
44	Sikalaha 105 MW PP (Baraka St	IPP	105 MW	105	0	0	Reserve.
45	Hattazari 100 MW Peaking PP	PDB	11*8.9	98	0	0	Under maint.
46	Dohazari -Kalaish 100 MW Peakin	PDB	6*17	102	51	170878	Low demand
47	Juldah 100 MW Unit-1 (Accom)	QRPP	8*13.45	100	0	0	Reserve.
48	Juldah 100 MW PP Unit-3 (Accom)	IPP	0	100	100	1731840	
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	477456	
*	Malancha, Ctg, EPZ (United)		5*8.73+3*9.34	0	9	515040	
50	Chattoagram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Reserve.
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	29160	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	160	1911927	Transformer OIL
53	Jodiach Power	IPP	3*18.55+1*3.6	54	54	1139481	
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
	Juldah unit-2 (Accom)	IPP	8*13.6	100	100	2451840	
Chattoagram area Total				2266	1024	20702883	
55	Ashuganj TPP Unit-3	APSCL	1*150	135	135	2807624	Gas shortage.
	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas Shortage
	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Gas Shortage.
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	170	4484000	Gas shortage.
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	370	7678700	
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	0	0	Under maint
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	29	655776	Gas shortage
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	10	387360	Gas shortage
62	Ashuganj 195MW PP (APSCL-Ur	IPP	20*9.73+1*16	195	8	250909	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	960146	
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	108	1246181	Low demand
66	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	50	1270690	ST Under maint
68	Chandpur 200MW (Desh energy)	IPP	0	200	0	0	Reserve.
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	445140	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	246240	
**	Impoport (Tripura)	Imported power	0	160	118	2330880	Low demand
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	25	551800	
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	132296	
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	489480	
74	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Reserve.
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	17	26220	Low demand
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	113	1406160	
Cumilla Area Total				2980	1306	25369602	
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	88	2122000	Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	275364	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	33	770880	Engine problem
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	15100	
79	Mymensingh 200 MW PP (United)	IPP	200	200	70	422400	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1580400	#REF!
	Mymensingh PV 50 MW Solar PP	IPP	50	0	0	364000	
Mymensingh Area Total				637	326	6550144	
81	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	41	1012000	GT-2 under maint.
82	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	0	0	Under maint.
83	Kushiaha 163 MW CCPP (KP)	IPP	1*109+1*54	163	107	2532927	ST Under maint
84	Shahjibazar 330 MW CCPP	PDB	3*110	330	159	3612000	FGMO & GT-2 under maint.
85	Fenchuganj 51 MW PP (Barakati)	RPP	19*2.90	51	50	1026600	
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	49	1058688	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	128500	
88	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	40	1377312	FGMO
89	Shahjibazar 86MW PP (Shahjibaz	RPP	32*2.90	86	84	1585920	
91	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	217	5263220	
92	Sylhet 20 MW GTPP	PDB	1*20	20	18	419000	
93	Sylhet 50MW PP (EPL)	RPP	2*72	50	0	0	Contract Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	420120	
95	Bibiana-II 341 MW CCPP (Summi	IPP	1*222+1*119	341	280	7167200	FGMO
96	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	402	9618000	
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	183060	
	Bibiyana South 400 MW	PDB	400 MW	0	40	604900	On test
Sylhet Area Total				1988	1532	36009447	
98	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	897	16682181	
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	66	221760	Low demand
100	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve.
101	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
103	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	300	8422848	FGMO
104	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	40	24	55125	Low demand
105	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	0	0	Reserve.
106	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	90	981120	Engine problem
107	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1377	26363034	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	32	132480	Low demand
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	28	504700	Engine problem
111	Bhola 225 MW CCPP	PDB	2*63+1*68	194	0	0	Under maint.
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	88	1300947	Engine problem
	Payra 1320 MW	BCPCL	1*622	622	660	11034500	
	Bhola Nutan Biddut BD LTD	IPP	220	0	35	903270	
Barisal Area Total				1054	843	13875897	
113	Baghabari 71 MW GTPP	PDB	1*71	71	40	340000	Gas shortage
	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	Reserve.
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
116	Ammura 50 MW PP(Srina)	QRPP	7*7.79	50	0	0	Fuel Shortage
117	Kakshali 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Fuel Shortage
118	Kakshali 50 MW Peaking PP	PDB	6*8.7	60	0	0	Reserve.
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	under maint.
120	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	154	3930373	FGMO
121</							