

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MM	MW	
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	0	0	Unit-1,2 Under maint.
	Ghorasal Repowered CAPP Unit-1	PDB	1*210	170	94	2593800	Gas shortage
	Ghorasal Repowered CAPP Unit-2	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	115	2803500	Gas shortage
2	Ghorasal 365 MW CAPP Unit-7	PDB	1*243+1*122	365	200	4878073	Machine problem.
	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage
	Ghorasal 108MW PP (Regent)	IPP	3*4*35	108	52	1226318	Gas shortage
	Hariapur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
	Hariapur 412 MW CAPP	EGCB	1*273+1*139	412	342	8566488	FGMO
	Hariapur 360MW CAPP(HPL)	IPP	1*235+1*125	360	325	7288000	Gas shortage
8	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	340	7264500	Gas shortage
9	Meghnaghat 100 MW(LEL)	QRPP	12*8.9	100	100	2152320	
10	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	126	3351476	FGMO and GT-2 under maint.
11	Madanganj 102 PPI(Summit)	QRPP	6*17	100	48	325848	High Voltage.
12	Madanganj-55 MW PPI(Summit)	(IPP)	3*117.08+1*11.3	55	15	327588	High Voltage.
13	Keraniganj 100 MW PP (Powerpa)	QRPP	8*13.45	100	86	1491101	Machine problem.
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	394272	
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 MW(Desh Bangla)	QRPP	12*8.9	100	100	554890	
18	Siddhirgonj 335 MW CAPP	EGCB	1*217+1*118	335	0	0	Under maint.
19	Gagnagar 102 MW PP (Digital Po)	IPP	12*8.924	102	0	0	Reserve.
20	Kalpotti 52 MW PP (Sinha)	IPP	7*7.9	51	10	26544	Low demand
21	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	54	1099800	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	98	504960	Low demand
23	Maniganj 55 MW PP (Northern)	IPP	3*19.3	55	55	895519	
24	Nabaganj 55 MW PP (Southern)	IPP	3*19.3	55	55	78059	Reserve.
25	Bosila 108MW PPI(CLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
26	Summit Power,(Madhabdi-Ashuli)	SIPP,REB	3*3.67+4*8.73	80	58	1139820	Engine problem
27	Maona 33 MW PPI(Summit)	SIPP,REB	4*8.73	33	25	569700	Engine problem
28	Rugganj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	25	627900	Engine problem
29	Gazipur 52 MW PP	IPP	6*8.9	52	0	62608	Reserve.
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	2576835	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve.
33	Bramhanganj 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	756860	
36	Gazipur 100 MW PP	RPCL	100 MW	105	0	67232	Reserve.
	Meghnaghat 104 MW PP (OPCL)	IPP	18*8.6	104	90	2169600	Engine problem
	Maniganj 162MW PP	IPP	9*18	0	0	0	On test
Dhaka area Total				5895	2826	53773841	
37	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
38	Raozan 25 MW PP	IPP	3*8.9	25	0	0	Reserve.
39	Taknaf 20MW PP (Solar)Tknaf Solar	Energy	20	20	0	119610	
40	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	0	107520	33 kV line fault
41	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	86	2080080	Unit-2 under maint
42	Sikalbaha 225MW	PDB	1*150+1*175	225	204	490434	
43	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage
44	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	0	0	Reserve.
45	Hathazari 100 MW Peaking PP	PDB	11*9.9	98	0	0	Under maint.
46	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	85	450810	Engine problem
47	Julidah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	0	0	Reserve.
48	Julidah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1902720	
49	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	483984	
*	Malancha, Ctg. EP2 (United)	IPP	5*8.73+3*9.34	0	9	419040	
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	73920	Reserve.
51	Kaptai 7 MW Solar PP	PDB	7.4	7	0	26411	
52	Anwara 300 MW PP (United)	IPP	300 MW	300	179	4074764	Transformer O/L
53	Jodac Power.	IPP	3*18.55+1*3.6	54	45	991053	Engine problem
54	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
	Julidah unit-2 (Acorn)	IPP	8*13.6	100	50	783360	Engine problem
	Anilma Energy Ltd.	IPP	6*21.2	0	0	25091	
Chattogram area Total				2266	778	16448027	
55	Ashuganj TPP Unit-3	APSCL	1*150	135	0	0	Gas shortage.
	Ashuganj TPP Unit-4	APSCL	1*150	120	80	2434170	Gas shortage.
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	270486	Gas shortage.
56	Ashuganj 225 MW CAPP	APSCL	1*142+1*75	221	160	4517000	FGMO
57	Ashuganj 450 MW CAPP(North)	APSCL	1*360	360	0	87500	Under maint
58	Ashuganj 450 MW CAPP(South)	APSCL	1*360	360	0	0	Under maint
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	621072	Gas shortage
60	Ashuganj 55 MW PP (Phission)	RPP	15*4	55	5	506880	Gas shortage
62	Ashuganj 195MW PP (APSCL-UR)	IPP	20*9.73+1*16	195	68	1605816	Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1240097	
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	150	2350181	
66	Tilas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.
67	Chanpur 150 MW CAPP	PDB	1*106+1*57	163	0	0	Under maint.
68	Chanpur 200MW (Desh energy)	IPP	200	100	100	2370720	High Voltage.
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	462276	
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	0	0	Engine problem
**	Impport (Tripura)	Imported power	0	160	120	1961280	
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	819600	
72	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	16	218693	High Voltage.
73	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*8.67+2*8.97	25	21	45960	Reserve.
74	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0	Reserve.
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	28500	Reserve.
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	26	347760	High Voltage.
Cumilla Area Total				2980	877	19891393	
75	RPCL 210MW CAPP	IPP	4*35+1*70	202	110	2517760	Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	415152	
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	60	529920	Engine problem
78	Sarabari 3 MW Solar Plant	IPP	3	3	0	100980	
79	Mymensingh 200 MW PP (United)	IPP	200	200	60	261600	
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2464800	#REF!
	Mymensingh PV 50 MW Solar PP	IPP	50	0	0	214380	
Mymensingh Area Total				637	365	6413612	
81	Fenchuganj CAPP Phase-1	PDB	2*32+1*33	70	40	976000	
82	Fenchuganj CAPP Phase-2	PDB	2*35+1*35	90	22	523900	GT-4 under maint.
83	Kushaura 163 MW CAPP (KP)	IPP	1*109+1*54	163	110	2929990	Gas shortage
84	Shajibazar 330 MW CAPP	PDB	3*110	330	157	3620000	Gas shortage
85	Fenchuganj 51 MW PP (Barakati)	RPP	19*2.90	51	53	1266000	
86	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	47	1083960	
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	157090	Engine problem
88	Shajibazar GTPP Unit- 8 & 9	PDB	2*35	66	36	763872	
89	Shajibazar 85MW PP (Shajibazar)	RPP	32*2.60	86	78	1876720	Engine problem
91	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	0	6790	Gas shortage
92	Sylhet 20 MW GTPP	PDB	1*20	20	19	433000	
93	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired
94	Shahjanulla 25 MW PP	SIPP, REB	3*9.34	25	16	352032	Engine problem
95	Bibiana-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	285	7224500	FGMO
96	Bibiana-III 400 MW CAPP	PDB	400 MW	400	238	5701000	Gas shortage
97	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	0	0	Engine problem
	Bibiana South 400 MW	PDB	400 MW	0	0	0	On test
Sylhet Area Total				1988	1112	26916754	
98	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	760	10676364	
99	Khulna 115 MW PP (KPCL-2)	QRPP	7*17	115	66	148800	Low demand
100	Fandpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve.
101	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
102	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
103	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	0	0	Gas shortage
104	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	40	153375	
105	Noapara 100 MW PP (Bangla Tr)	IPP	70*1.4	100	0	53760	Reserve.
106	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	80	1518240	Engine problem
107	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	956	12550539	
108	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	29184	Reserve.
110	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	26	473900	Engine problem
111	Bhola 225 MW CAPP	PDB	2*63+1*68	194	0	0	Under maint.
112	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	86	850598	Gas shortage
	Payra 1320 MW	BCPCL	1*622	622	660	10641900	
	Bhola Nutan Bidat BD LTD	IPP	220	0	8	257870	
	United Payra Power Ltd.	IPP	8*18.5+1*9.5	0	0	0	On test.
Barisal Area Total				1054	780	12257892	
113	Baghabari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage.
	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage.
114	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	Reserve.
115	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
116	Amnura 50 MW PPI(Sinha)	QRPP	7*7.9	50	0	0	Fuel Shortage
117	Katakhal 50 MW CAPP (Northern)	QRPP	6*8.9	50	0	0	Fuel Shortage
118	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	0	0	Reserve.
119	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0</		