

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | Peak Hour | | Energy Generated | Remarks |
|------------------------------|----------------------------------|------------------|--------------------|----------------------------|-------------|-----------------|------------------|---------------------------|
| | | | | | Generation | MW | | |
| | | | | Unit No. X Capacity | MW | MW | MW | |
| 1 | Ghorasal TPP (Unit-1&2) | PDB | 2*55 | 85 | 0 | 0 | 0 | Unit-1,2 Under maint. |
| | Ghorasal Repowered CCPP Unit-3 | PDB | 1*210 | 170 | 0 | 0 | 0 | Gas shortage |
| | Ghorasal Repowered CCPP Unit-4 | PDB | 1*210 | 180 | 0 | 0 | 0 | Under maint. |
| | Ghorasal TPP Unit-5 | PDB | 1*210 | 190 | 115 | 272000 | 0 | Gas shortage |
| 2 | Ghorasal 365 MW CCPP Unit-7 | PDB | 1*243+1*122 | 365 | 300 | 7087182 | 0 | Gas shortage |
| | Ghorasah 78.5 MW PP(MAX) | QRPP | 2*40 | 78 | 0 | 0 | 0 | Gas shortage |
| | Ghorasah 108MW PP (Regent) | IPP | 3*43.35 | 108 | 101 | 2247727 | 0 | |
| 4 | Hanipur GTPP | SEU, PDB | 2*32 | 20 | 0 | 0 | 0 | Under maint. |
| | Hanipur 412 MW CCPP | LECOB | 1*273+1*139 | 412 | 363 | 8629200 | 0 | FGMO |
| | Hanipur 360MW CCPP(HPL) | IPP | 1*235+1*125 | 360 | 301 | 5274000 | 0 | Gas shortage |
| 8 | Meghnaghat 450 MW CCPP(MPL) | IPP | 2*150+1*150 | 450 | 300 | 7194500 | 0 | Gas shortage |
| 9 | Meghnaghat 100 MW(LEL) | QRPP | 12*8.9 | 100 | 100 | 1942080 | 0 | |
| 10 | Meghnaghat CCPP(Summit) | IPP | 2*110+1*110 | 305 | 0 | 0 | 0 | Gas shortage |
| 11 | Madangan 102 PP(Summit) | QRPP | 6*17 | 100 | 48 | 305376 | 0 | Low demand |
| 12 | Madangan 35 MW PP(Summit) | IPP | 3*11.08+1*11.3 | 55 | 55 | 711865 | 0 | |
| 13 | Keraniganj 100 MW PP (Powerpac) | QRPP | 8*13.45 | 100 | 0 | 0 | 0 | Fuel shortage |
| 14 | Narshingdi 22 MW PP (Doreen) | SIPP, REB | 8*2.90 | 22 | 16 | 314784 | 0 | Engine problem |
| 15 | 210 MW Siddhirgonj TPP | PDB | 1*210 | 115 | 0 | 0 | 0 | Under maint. |
| 16 | Siddhirgonj 2*120 MW GTPP | EGCB | 2*105 | 210 | 0 | 0 | 0 | Gas shortage |
| 17 | Siddhirgonj 100 PPI/Dutch Bangla | QRPP | 12*8.9 | 100 | 100 | 767040 | 0 | |
| 18 | Siddhirgonj 335 MW CCPP | ECOB | 1*21+1*18 | 335 | 0 | 0 | 0 | Under maint. |
| 19 | Gagragar 102 MW PP (Digital Po | IPP | 12*8.924 | 102 | 7 | 100800 | 0 | Low demand |
| 20 | Kalpott 52 MW PP (Sinha) | IPP | 7*7.9 | 51 | 6 | 11664 | 0 | Low demand |
| 21 | Kamalaghat 54 MW PP(Banco En | IPP | 3*18 | 54 | 54 | 1287360 | 0 | |
| 22 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 64 | 279840 | 0 | Low demand |
| 23 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 55 | 933768 | 0 | |
| 24 | Nababganj 55 MW PP (Southern) | IPP | 3*19.3 | 55 | 17 | 302017 | 0 | Low demand |
| 25 | Bostia 108MW PP(CLOP) | IPP | 12*8.775+1*9.5 | 108 | 0 | 0 | 0 | Fuel shortage |
| 26 | Summit Power (Madhabdi+Ashuli) | SIPP, REB | 3*3.67+4*8.73 | 80 | 57 | 1270140 | 0 | Engine problem |
| 27 | Mona 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 25 | 481200 | 0 | Engine problem |
| 28 | Rugganj 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 33 | 831000 | 0 | |
| 29 | Gazipur 52 MW PP | IPP | 6*8.9 | 52 | 40 | 144756 | 0 | Engine problem |
| 30 | Tongi 80 MW GTPP | PDB | 1*105 | 105 | 0 | 0 | 0 | Under maint. |
| 31 | Kodda 300 MW PP Unit-2 (Summ | IPP | 18*17.076 | 300 | 300 | 3613089 | 0 | |
| 32 | Keraniganj 300 MW PP (APR) | IPP | 256*1.4 | 300 | 0 | 0 | 0 | Reserve. |
| 33 | Bramhangaan 100 MW PP (Aggr | IPP | 100 | 100 | 0 | 0 | 0 | Reserve. |
| 34 | Aurahati 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 100 | 0 | 0 | 0 | Reserve. |
| 35 | Kodda 149 MW PP Unit-1 (Summ | IPP | 149 | 149 | 140 | 1088500 | 0 | Engine problem |
| 36 | Gazipur 100 MW PP | RPCL | 100 | 105 | 47 | 98004 | 0 | Low demand |
| | Meghnaghat 104 MW PP (QPCL) | IPP | 18*5.8 | 104 | 90 | 2174520 | 0 | Engine problem |
| | Manikganj 162MW PP(MPGL) | IPP | 9*18 | 162 | 0 | 0 | 0 | On test |
| Dhaka area Total | | | | 8057 | 2734 | 51485868 | | |
| 37 | Chattogram TPP-1 | PDB | 1*210 | 180 | 0 | 0 | 0 | Gas shortage. |
| | Chattogram TPP-2 | PDB | 1*210 | 180 | 0 | 0 | 0 | Gas shortage |
| 38 | Razzan 25 MW PP | IPP | 3*8.9 | 25 | 0 | 0 | 0 | Reserve. |
| 39 | Teknaf 20MW PP (SolarTech) | Teknaf SolarTech | Energ | 20 | 20 | 0 | 111915 | |
| 40 | Paterga 50MW PP (Baraka) | IPP | 8*6.88 | 50 | 50 | 986240 | 0 | |
| 41 | Kaptai Hydro Unit-1,2,3,4, 5 | PDB | 2*40+3*50 | 230 | 44 | 1108015 | 0 | Unit-2 under maint |
| 42 | Sikalbaha 225MW | PDB | 1*150+1*175 | 225 | 204 | 4749421 | 0 | |
| 43 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 0 | 0 | 0 | Gas shortage |
| 44 | Sikalbaha 105 MW PP (Baraka Si | IPP | 105 MW | 105 | 0 | 0 | 0 | Reserve. |
| 45 | Hatbahari 100 MW peaking PP | PDB | 11*8.9 | 98 | 0 | 0 | 0 | Under maint. |
| 46 | Dahazari-Kalaha 100 MW Peakin | PDB | 6*17 | 102 | 68 | 185586 | 0 | Low demand |
| 47 | Judiah 100 MW Unit-1 (Acorn) | QRPP | 8*13.45 | 100 | 0 | 0 | 0 | Reserve. |
| 48 | Judiah 100 MW PP Unit-3 (Acorn) | IPP | 0 | 100 | 100 | 1725120 | 0 | |
| 49 | Baratkunda 22 MW PP (Regent) | SIPP, PDB | 8*2.90 | 22 | 17 | 400992 | 0 | Engine problem |
| * | Malanchara Ctg. EPZ (United) | | 5*8.73+3*9.34 | 0 | 10 | 479520 | 0 | |
| 50 | Chattogram 108 MW PP (ECPV) | IPP | 16*7 | 108 | 7 | 24000 | 0 | Low demand |
| 51 | Kaptai 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 24721 | 0 | |
| 52 | Anwara 300 MW Solar PP (United) | IPP | 300 MW | 300 | 161 | 3477660 | 0 | |
| 53 | Jodiad Power | IPP | 3*18.55+1*3.6 | 54 | 54 | 1284141 | 0 | Transformer OIL |
| 54 | Karnaphuli Power Ltd. | IPP | 110 | 110 | 0 | 0 | 0 | Reserve. |
| | Judiah unit-2 (Acorn) | IPP | 8*13.6 | 100 | 100 | 965760 | 0 | |
| | Anilma Energy Ltd. | IPP | 6*21.2 | 0 | 0 | 43909 | 0 | |
| Chattogram area Total | | | | 2266 | 815 | 15466940 | | |
| 55 | Ashuganj TPP Unit-3 | APSCL | 1*150 | 135 | 0 | 0 | 0 | Gas shortage |
| | Ashuganj TPP Unit-4 | APSCL | 1*150 | 129 | 80 | 2305535 | 0 | Gas shortage |
| | Ashuganj TPP Unit-5 | APSCL | 1*150 | 134 | 0 | 0 | 0 | Gas shortage |
| 56 | Ashuganj 225 MW CCPP | APSCL | 1*142+1*75 | 221 | 181 | 4783000 | 0 | Gas shortage |
| 57 | Ashuganj 450 MW CCPP(North) | APSCL | 1*360 | 360 | 0 | 0 | 0 | Under maint |
| 58 | Ashuganj 450 MW CCPP(South) | APSCL | 1*360 | 360 | 220 | 3227000 | 0 | Gas shortage |
| 59 | Ashuganj 50 MW PP | APSCL | 14*3.968 | 45 | 26 | 409464 | 0 | Gas shortage |
| 60 | Ashuganj 55 MW PP (Precision) | RPP | 15*4 | 55 | 5 | 142080 | 0 | Gas shortage |
| 62 | Ashuganj 195MW APSCL-Un | IPP | 20*9.73+1*16 | 195 | 16 | 351272 | 0 | Gas shortage |
| 63 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 51 | 1170090 | 0 | |
| 64 | Ashuganj 150MW PP (Midland) | IPP | 23*7.015 | 150 | 143 | 2845309 | 0 | |
| 66 | Tilas 50 MW Peaking PP | PDB | 6*8.92 | 52 | 0 | 0 | 0 | Reserve. |
| 67 | Chandpur 150 MW CCPP | PDB | 1*106+1*57 | 163 | 48 | 247870 | 0 | |
| 68 | Chandpur 200MW (Desh energy) | IPP | 0 | 200 | 68 | 1632480 | 0 | Low demand |
| 69 | Feni 22MW PP (Green) | SIPP, PDB | 8*2.90 | 22 | 21 | 483552 | 0 | |
| 70 | Feni 11 MW PP (Doreen) | SIPP, REB | 4*2.90 | 11 | 11 | 190980 | 0 | Engine problem |
| ** | Impoport (Tripura) | Imported power | 0 | 160 | 108 | 2059200 | 0 | |
| 71 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4*8.73 | 33 | 25 | 483600 | 0 | Engine problem |
| 72 | Jangalia 52 MW PP (Lakdanav) | IPP | 6*8.92 | 52 | 8 | 105576 | 0 | Low demand |
| 73 | Corulla 25 MW PP (Summit) | SIPP, PDB | 3*3.67+2*6.97 | 25 | 21 | 432360 | 0 | |
| 74 | Daudkarna 200 MW PP (B. Trac) | IPP | 154*1.4 | 200 | 0 | 0 | 0 | Reserve. |
| | Feni Lanka Power | IPP | 7*18.415+1*9.78 | 114 | 0 | 0 | 0 | Reserve. |
| | Chowmuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 26 | 487040 | 0 | |
| Cumilla Area Total | | | | 2880 | 1055 | 21336408 | | |
| 75 | RPCL 210MW CCPP | IPP | 4*35+1*70 | 202 | 90 | 2388760 | 0 | Gas shortage |
| 76 | Tangail 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 20 | 424224 | 0 | |
| 77 | Jamalpur 95 MW PP(Powerpac) | IPP | 12*8.924 | 95 | 95 | 493440 | 0 | |
| 78 | Sarishabari 3 MW Solar Plant | IPP | 1*3 | 3 | 0 | 4900 | 0 | |
| 79 | Mymensingh 200 MW PP (United) | IPP | 200 MW | 200 | 8 | 526800 | 0 | |
| 80 | Jamalpur 115 MW PP (United) | IPP | 115 MW | 115 | 115 | 1734000 | 0 | #REF! |
| | Sulakhali 50 MW Solar PP | IPP | 50 | 50 | 0 | 91250 | 0 | |
| | Tangail Palli Power Gen 22 MW | SIPP | 4*6.7 | 0 | 26 | 612480 | 0 | |
| Mymensingh Area Total | | | | 687 | 354 | 5801854 | | |
| 81 | Fenchuganj CCPP Phase-1 | PDB | 2*32+1*33 | 70 | 20 | 522000 | 0 | Gas shortage |
| 82 | Fenchuganj CCPP Phase-2 | PDB | 2*35+1*35 | 90 | 43 | 1030680 | 0 | |
| 83 | Kushlira 163 MW CCPP (KP) | IPP | 1*108+1*54 | 163 | 163 | 3538518 | 0 | |
| 84 | Shahbazar 330 MW CCPP | PDB | 3*110 | 330 | 121 | 3211000 | 0 | |
| 85 | Fenchuganj 51 MW PP (Barakata) | RPP | 19*2.90 | 51 | 52 | 822000 | 0 | Gas shortage & GT-2 under |
| 86 | Fenchuganj 44MW (Energyprima) | RPP | 12*3.3+5*2 | 44 | 43 | 811008 | 0 | |
| 87 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 4*2.90 | 11 | 8 | 120000 | 0 | |
| 88 | Shahbazar GTPP Unit- 8 & 9 | PDB | 2*35 | 66 | 36 | 775104 | 0 | Unit-9 under maint. |
| 89 | Shahbazar 60MW PP (Shahbaz | RPP | 32*2.90 | 96 | 74 | 1776880 | 0 | |
| 90 | Shahbazar 100 MW GTPP | PDB | 1*100 | 0 | 0 | 303000 | 0 | |
| 91 | Sylhet 225 MW CCPP | PDB | 1*142+1*89 | 231 | 96 | 2379320 | 0 | |
| 92 | Sylhet 20 MW GTPP | PDB | 1*20 | 20 | 18 | 404000 | 0 | |
| 93 | Sylhet 56MW PP (EPL) | RPP | 27*2 | 50 | 0 | 0 | 0 | Contract Expired |
| 94 | Shahajanulla 25 MW PP | SIPP, REB | 3*9.34 | 25 | 16 | 284952 | 0 | Engine problem |
| 95 | Bibiana-II 341 MW CCPP (Summ | IPP | 1*222+1*119 | 341 | 0 | 0 | 0 | FGMO |
| 96 | Bibiana-450 MW CCPP | PDB | 450 MW | 400 | 120 | 5775000 | 0 | Gas shortage |
| 97 | Sylhet 100MW PP (Desh) | RPP | 6*1.95 | 100 | 0 | 0 | 0 | Engine problem |
| | Bibiana South 400 MW | PDB | 400 MW | 0 | 130 | 3285600 | 0 | On test |
| Sylhet Area Total | | | | 1988 | 940 | 24788062 | | |
| 98 | Bheramara GTPP Unit-3 | PDB | 1*20 | 16 | 0 | 0 | 0 | Reserve. |
| ** | Bheramara (HVDC) | Imported power | 2*500 | 1000 | 783 | 12856000 | 0 | |
| 99 | Khulna 115 MW PP (KPCL-2) | QRPP | 7*17 | 115 | 66 | 192960 | 0 | Low demand |
| 100 | Fandpur 50 MW Peaking PP | PDB | 8*6.89 | 54 | 0 | 50 | 0 | Reserve. |
| 101 | Khulna 225 MW CCPP | NWPGCL | 1*150+1*75 | 230 | 0 | 0 | 0 | Reserve. |
| 102 | Gopalganj 100 MW Peaking PP | PDB | 16*6.88 | 109 | 0 | 0 | 0 | Reserve. |
| 103 | Bheramara 410 MW CCPP | NWPGCL | 1*278+1*132 | 410 | 210 | 6062688 | 0 | Gas shortage |
| 104 | Noapara 40 MW PP (Khanjahan A | QRPP | 5*8.5 | 40 | 0 | 0 | 0 | Reserve. |
| 105 | Noapara 100 MW PP (Bangla Tra | IPP | 70*1.4 | 100 | 0 | 0 | 0 | Reserve. |
| 106 | Rupsha 105 MW PP (Orion rupsh | IPP | 6*18.445 | 105 | 90 | 1521600 | 0 | Engine problem |
| 107 | Mochmuri 100 MW PP | SWPGCL | 100 MW | 105 | 0 | 0 | 0 | Reserve. |
| Khulna Area Total | | | | 2284 | 1149 | 20633248 | | |
| 108 | Barisal 110 MW PP (Summit) | IPP | 7*17.076 | 110 | 64 | 273600 | 0 | High Voltage. |
| 110 | Bhola 33 MW PP (Venture) | RPP | 1*34.50 | 33 | 20 | 461300 | 0 | Engine problem |
| 111 | Bhola 225 MW CCPP | PDB | 2*63+1*68 | 194 | | | | |