

Sl. No.	Name of the Power Stations	Producer	Installed Capacity Unit No. X Capacity	Present		Peak		Energy Generated	Remarks
				Capacity MW	Hour	Hour	Generation MW		
1	Ghorasal TPP (Unit-1&2)	PDB	2*55	85	0	0	0	0	Unit-1,2 Under maint.
	Ghorasal Repowered CCPP Unit-1	PDB	1*210	170	94	2465500			Gas shortage
	Ghorasal Repowered CCPP Unit-2	PDB	1*210	180	0	0			Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0			Under maint.
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	330	7628255			
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0			Gas shortage
4	Ghorasal 108MW PP (Regent)	IPP	3*4*3.35	108	12	305272			Gas shortage
5	Harpur GTPP	SBU, PDB	2*32	20	0	0			Under maint.
6	Harpur 412 MW CCPP	UBCL	1*273+1*139	412	375	8649410			FGMO
7	Harpur 360MW CCPP(HPL)	IPP	1*235+1*125	360	357	7692000			
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	225	4734000			Gas shortage
9	Meghnaghat 100 MW(LEL)	QRPP	12*8.9	100	65	623040			Low demand
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0			Low demand
11	Madangan 102 PP(Summit)	QRPP	6*17	100	15	60192			Low demand
12	Madangan 35 MW PP(Summit)	IPP	3*11.08+1*11.3	55	15	183385			Low demand
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	60	925209			Low demand
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	327492			Engine problem
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0			Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	181000			Gas shortage
17	Siddhirgonj 100 PPI/Dutch Bangla	QRPP	12*8.9	100	50	185280			Low demand
18	Siddhirgonj 335 MW CCPP	EGCB	1*21*118	335	0	0			Under maint.
19	Gagragar 102 MW PP (Digital Po	IPP	12*8.924	102	0	0			Reserve.
20	Kalpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	0			Reserve.
21	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1211760			
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	48	464160			Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	929276			
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	0	0			Reserve.
25	Bostia 108MW PP/CLD	IPP	12*8.775+1*9.5	108	0	0			Fuel shortage
26	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	57	1181400			Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	14	396900			Engine problem
28	Ruggan 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	836400			
29	Gazipur 52 MW PP	IPP	6*8.9	52	0	0			Reserve.
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0			Under maint.
31	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	145	9710178			Low demand
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0			Reserve.
33	Bramhangonj 100 MW PP (Aggr	IPP	100	100	0	0			Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0			Reserve.
35	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	24	275040			Low demand
36	Gazipur 100 MW PP	RPCL	100 MW	105	0	0			Reserve.
	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.5	104	104	1850880			
	Meghnaghat 162MW PP(MPGL)	IPP	9*18	162	0	0			Reserve.
Dhaka area Total				8057	2148	50958029			
37	Chattogram TPP-1	PDB	1*210	180	0	0			Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0			Gas shortage
38	Razan 25 MW PP	IPP	3*8.9	25	0	0			Reserve.
39	Teknaf 20MW PP (SolarTech/Teknaf SolarTech Energy		20	20	0	120015			
40	Palenga 50MW PP (Baraka)	IPP	8*6.88	50	25	626960			Low demand
41	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	47	1089250			Unit-2 under maint.
42	Sikalbaha 225MW	PDB	1*150+1*175	225	100	2814375			Gas shortage & ST under ma
43	Sikalbaha Peaking GT	PDB	1*150	150	0	0			Gas shortage
44	Sikalbaha 105 MW PP (Baraka Si	IPP	105 MW	105	0	0			Reserve.
45	Hatthazari 100 MW peaking PP	PDB	11*8.9	98	0	0			Under maint.
46	Dahazari-Kalaha 100 MW Peaki	PDB	6*17	102	17	110516			Low demand
47	Judah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	0	0			Reserve.
48	Judah 100 MW PP Unit-3 (Acorn)	IPP	0	100	60	1731840			Low demand
49	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	19	454080			
*	Malancha, Ctg, EPZ (United)		5*8.73+3*9.34	0	42	939360			
50	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0			Reserve.
51	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	25200			
52	Anwara 300 MW Solar PP (United)	IPP	300 MW	300	106	3039862			Transformer OIL
53	Jodiad Power	IPP	3*18.55+1*3.6	54	54	1290308			
54	Karnaphuli Power Ltd.	IPP	110	110	12	81963			Low demand
	Judah unit-2 (Acorn)	IPP	8*13.6	100	30	409920			Low demand
	Anlima Energy Ltd.	IPP	6*21.2	0	0	0			
Chattogram area Total				2266	512	12826769			
55	Ashuganj TPP Unit-3	APSCL	1*150	135	80	2283666			Gas shortage
	Ashuganj TPP Unit-4	APSCL	1*150	129	100	2543015			Gas shortage
	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0			Gas shortage
56	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	0	0			Under maint.
57	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	0	0			Under maint.
58	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	320	6842000			
59	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	554904			Gas shortage
60	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	54	1288800			
62	Ashuganj 195MW APSCL-Un	IPP	20*9.73+1*16	195	8	36127			Gas shortage
63	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1200800			
64	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	138	1821600			Engine problem
66	Tilas 50 MW Peaking PP	PDB	6*8.92	52	0	0			Reserve.
67	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	51	1152470			ST under maint.
68	Chandpur 200MW (Desh energy)	IPP	0	200	85	1298940			Low demand
69	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	18	435996			Engine problem
70	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	228190			
**	Impoport (Tripura)	Imported power	0	160	96	1678080			
71	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	787900			
72	Jangalia 52 MW PP (Lakdanav)	IPP	6*8.92	52	0	0			Reserve.
73	Comilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	22	464310			
74	Daudkarna 200 MW PP (B. Trac)	IPP	154*1.4	200	0	0			Reserve.
	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0			Reserve.
	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	0	0			Reserve.
Comilla Area Total				2880	1083	22966888			
75	RPCL 210MW CCPP	IPP	4*35+1*70	202	130	2949080			Gas shortage
76	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	434592			
77	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.928	95	91	458880			
78	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12050			
79	Mymensingh 200 MW CCPP (United)	IPP	200	200	0	0			
80	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	1578000			#REF!
	Sulakhali 50 MW Solar PP	IPP	50	50	0	27520			
	Tangail Pali Power Gen 22 MW	SIPP	4*6.7	0	0	0			
Mymensingh Area Total				687	356	5705122			
81	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	30	716000			Gas shortage & GT-2 under r
82	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	32	760920			GT-4 under maint.
83	Kushkhira 163 MW CCPP (KP)	IPP	1*109+1*54	163	130	3251781			Frequency control
84	Shahbazar 330 MW CCPP	PDB	3*110	330	155	359300			Gas shortage & GT-2 under e
85	Fenchugonj 51 MW PP (Barakata)	RPP	19*2.90	51	8	220800			High Voltage.
86	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	5	247536			High Voltage.
87	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	74048			Engine problem
88	Shahbazar GTPP Unit- 8 & 9	PDB	2*35	66	33	710784			Unit-9 under maint.
89	Shahbazar 80MW PP (Shahbaz	RPP	32*2.90	86	75	1665600			Engine problem
90	Shahbazar 100 MW GTPP	PDB	1*100	0	0	0			On test.
91	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	150	3608350			
92	Sylhet 20 MW GTPP	PDB	1*20	20	0	144000			
93	Sylhet 56MW PP (EPL)	RPP	27*2	50	0	0			Contract Expired
94	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	0	15792			Engine problem
95	Bibiana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	120	1267260			Under maint.
96	Bibiana-III 492 MW CCPP	PDB	400 MW	400	60	4520900			Gas shortage & Bibiyana sou
97	Sylhet 100MW PP (Desh)	RPP	6*1.95	10	0	0			Engine problem
	Bibiyana South 400 MW	PDB	400 MW	0	300	3482700			
Sylhet Area Total				1988	1129	24278571			
98	Bheramara GTPP Unit-3	PDB	1*20	16	0	0			Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	559	9715636			
99	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	16	58560			Low demand
100	Fandpur 50 MW Peaking PP	IPP	8*6.89	50	0	50			Reserve.
101	Khulna 225 MW CCPP	NWP/EGCL	1*150+1*75	230	0	0			Reserve.
102	Gopalganj 100 MW Peaking PP	PDB	16*6.88	109	0	0			Reserve.
103	Bheramara 410 MW CCPP	NWP/EGCL	1*278+1*132	410	235	5214528			Gas shortage
104	Noapara 40 MW PP (Khanjahan A	QRPP	5*8.5	40	0	0			Reserve.
105	Noapara 100 MW PP (Bangla Tra	IPP	70*1.4	100	0	0			Reserve.
106	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	80	1043340			Engine problem
107	Mochmuri 100 MW PP	SWP/EGCL							