

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month January, 2021			Day : Sunday				Date : 03.01.22					
Probable Maximum Demand : 9000 MW			Probable Maximum Generation : 12813 MW						Rule Curve = 102.62 ft.			
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 98.09 ft		Today = 98.03 ft		03.01.20 (Yesterday)		03.01.22 (Today)		Status of Machines under shut-down/ Maintenance	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	Actual Power Generation (MW)		Probable Peak Generation (MW)		Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		85	Under maint.
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170		Gas Shortage
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	80	90	120	120	90		Gas Shortage
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	170	330	330	330			
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	101	104	50	50			
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	336	359	360	360			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450		Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	385	366	412	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	100	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305		Gas Shortage
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	64	86	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	48	64	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	88	100	100	100			
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	24	65	100	100			
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	19	19			
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	57	57	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	24	17	17			
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	51	52	52			
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	96	105	105			
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	64	150	150			
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	1	50	50			
28	Kamalaghat 54 MW PP (Banos Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	230	300	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	111	109	149	149			
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300			
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
33	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	60	100			
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	35	35	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	55	55			
36	Bosila 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	90	90	90			
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	55	55	162	162			
Dhaka Zone Total				6281	6057	1991	2668	3386	3676	1428	725	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	43	75	75	187		Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	50	50			
45	Sikalbaha 105 MW PP (Baraka Sike)	HFO (IPP)	6x18.415	105	105	0	0	100	100			
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Gas Shortage
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Gas Shortage
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	65	0	300	300			
49	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	100	100	100			
50	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	100	100	100			
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	102	102			
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			12	28	10	20			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	81	102	102			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	48	0	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
	Anlima Energy Ltd.	HFO (IPP)				121	117	124	124			
Chattogram Zone Total				2326	2266	523	715	1396	1381	742	180	
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	100	70	0	0			
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	17	5	5			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	157	162	130	130			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	99	275	360	360			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	20	15	300	300		345	Under maint.
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	15	5	5	5	50		Gas Shortage
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	135	143	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	57	87	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	19	19			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
72	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	0	33	33			
73	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	41	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	22	21	21			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x1.4+40x1.515+15x1.05	200	200	0	0	0	0			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	26	65	113	113			
**	Impoort (Tiripura)	India		160	160	64	102	139	148			
Cumilla Zone Total				3040	2980	805	1093	1702	1961	500	345	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	118	105	110	110	97		Gas Shortage
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	66	95	95			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	24	115	115			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	130	200	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	12x8.924	3	3	2	0	1.6	0			
84	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0			
	Tangail 22 MW PP(Pali Power Gen	HFO (SIPP)				19	13	22</				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.01.20 (Yesterday)		03.01.22 (Today)		02.01.20 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
85	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	60	60	50	50			
86	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	30			
87	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	8	49	8	8			
88	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	30	50	20	20			
89	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			
90	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
91	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	32	33	33			
92	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	144	144	155	155	186		Gas Shortage
93	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	73	72	72			
94	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	189	70	100	200			
95	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	20	20	20			
96	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			
97	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0			
98	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16			
99	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	300	320	320			
100	Bibiyana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400		Gas Shortage
		Bibiyana South	400 MW	Gas (PDB)			20	396	400	400			
		Shahjibazar	100 MW GTTP	Gas (PDB)			0	0	0	0			
		Sylhet Zone Total			2033	1988	827	1201	1205	1335	586	0	
101	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16			Gas Shortage
102	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	315	245	250	250	165		Gas Shortage
103	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	35	35			
104	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70			
105	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220			
106	Khulna	115 PP MW (KPL-2)	HFO (QRPP)	7x17	115	115	52	115	115	115			
107	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	32	50	100			
108	Noapara	40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	40	40	40			
109	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	105	105	105			
110	Madhumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	67	100	100			
**	Bheramara (HVDC)	India		1000	1000		439	722	589	830			
		Khulna Zone Total			2288	2284	806	1326	1354	1881	165	0	
111	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110			
112	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	27	24	26			
113	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Under maint.
114	Bhola	95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	33	87	90	90			
115	Payra	1320 MW Unit-1	Coal (BCPCL)	1x622	622	622	0	0	0	0			
		Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				13	35	36	36			
		United Payra Power Ltd.	HFO (IPP)				0	54	0	0			
		Barishal Zone Total			1054	1054	65	251	260	262	0	194	
116	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
117		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	50			
118		Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
119		Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40			
120		Amnura 50 MW PP (Siraha)	HFO (QRPP)	7x7.79	50	50	0	24	35	35			
121		Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	44	77	100	100			
122		Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50			
123		Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50			
124		Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34			
125		Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			Gas Shortage
126		Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage
127		Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	210	170	220	220			
128		Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	410	431	400	400			
129		Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22			
130		Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			
131		Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
132		Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	52	52			
133		Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	113	113			
134		Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6'18.55	113	113	111	113	113	113			
		Rajshahi Zone Total			2193	2183	918	1063	1366	1490	601	0	
135	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage
136		Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150			
137		Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
138		Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	78	49	113	113			
139		Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
140		Majpara, Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	0	0	8	0			
		Rangpur Zone Total			685	605	228	199	271	263	170	0	
		Sub-total: Plants in operation			20595	20104	6500.0	8946	11556	12813	4289	1444	
		Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss					6108	8407	10859	12041			
(B) Contract expired power plants													
		Sub-Total: Plants under long term maintenance			0	0	0	0	0	0			
		Gross Total			20595	20104	6500	8946	11556	12813	4289	1444	
(C) Actual data of 02.01.20 (Yesterday) Saturday :													
01.	Max. Demand (Generation end) : 8946.00 MW, at = 19:00 hrs				12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand (Sub-station end) : 8407.00 MW, at = 19:00 hrs				Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end) : 8946.00 MW, at = 19:00 hrs				Dhaka	2868	2868	0	Mymensingh	699	699	0	
04.	Minimum Generation (Generation end) : 5153.00 MW, at = 4:00 hrs				Chattogram	972	972	0	Sylhet	313	313	0	
05.	Day-peak Generation (Generation end) : 6500.00 MW, at = 12:00 hrs				Khulna	1132	1132	0	Barishal	242	242	0	
06.	Evening-peak Generation (Generation end) : 8946.00 MW, at = 19:00 hrs				Rajshahi	863	863	0	Rangpur	597	597	0	
07.	Evening Peak Load-shed (Sub-station end) : 0.00 MW, at = 19:00 hrs				Cumilla	721	721	0					
08.	Actual Minimum Generation up to 8:00 hrs. : 5435.00 MW, at = 7:00 hrs								Total	8407	8407	0	
09.	Generation shortfall at evening peak due to :				13.	Fuel cost :	(a) Gas = 104121883 Taka	(c) Coal = 19928256 Taka					
	a) Gas limitation : 3932 MW						(b) Oil = 291801001 Taka	Total = 415851140 Taka					
	d) Coal supply Limitation : 170 MW				14.	Maximum Temperature in Dhaka was :	27.0° C						
	b) Low water level in Kaptai lake : 187 MW				15.	Export through East-West interconnections :							
	c) Plants under shut down/ maintenance : 1444 MW					At evening peak-hour :	-187 MW, at 19:00 hrs						
10.	Total Energy (Generation + India Import) : 160.84 MCKWh					Maximum :	-270 MW, at 20:00 hrs						
	By Gas = 98.032 MCKWh					Energy :	1.1685 MCKWh						
	By Coal = 3.677 MCKWh												
	By Hydro = 42.332 MCKWh												
	By Solar = 0.409 MCKWh												
11.	Total Gas Supplied : 781.97 MCFD												
(D) Forecast of 03.01.22 (Today) Sunday :													
01.	Maximum Demand : 9000 MW (Generation end)				04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation : 12813 MW (Generation end)				05.	Total Generation : 161.82 MCKWh							
03.	Maximum Shortage : -3813 MW (Generation end)				06.	Probable Max. Temperature in Dhaka : 26.2° C							

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation