

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month January, 2021				Day : Sunday				Date : 10.01.21				
Probable Maximum Demand : 9500 MW				Probable Maximum Generation : 13631 MW				Rule Curve = 101.29 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.66 ft		Today = 97.59 ft.		10.01.21 (Yesterday)		10.01.21 (Today)		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.01.21 (Yesterday)		10.01.21 (Today)		Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Generation (MW)	Probable Peak Generation (MW)	Day	Evening				
(A) Plants in operation:												
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		85	Under maint.
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under maint.
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	20	0	0			
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	380	300	360			
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	104	102	100	100			
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	125	307	360	360			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450		Under maint.
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	338	366	412	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	98	60	100	112		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	50	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305		Gas Shortage
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	0	50	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	0	80	100	100			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	50	86	100	100			
19	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	0	16	100	100			
20	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22			
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	23	53	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	23	25	25			
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	52	52			
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	90	105	105			
26	Kodda 150MW PP	HFO (BPD-B-RPCL)	9x17.06	149	149	0	100	150	150			
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50			
28	Kamalaghat 54 MW PP (Banoo Energy)	HFO (IPP)	3x18.69	54	54	0	17	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	145	270	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	38	128	149	149			
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300			
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+9x1.959	100	100	0	0	50	100			
33	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+9x1.959	100	100	0	0	60	100			
34	Nababganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	5	35	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	35	35			
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	44	104	90	90			
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	72	162	162			
Dhaka Zone Total				6281	6057	1321	2544	3329	3719	1070	895	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	44	48	45	45	182		Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	23	25	25	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	22	50	50	50			
45	Sikalbaha 105 MW PP (Baraka Sike	HFO (IPP)	6x18.415	105	105	0	0	100	100			
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Gas Shortage
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Gas Shortage
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	215	268	300	300			
49	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	0	100	100			
50	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	38	100	100	100			
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	102	102			
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17			
*	Malancha, Ctg EPZ (Unite)	Gas	5x8.73+3x9.34			4	26	25	35			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	31	102	102			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
	Anlima Energy Ltd.	HFO (IPP)				0	0	0	0			
Chattogram Zone Total				2326	2266	511	753	1255	1240	737	180	
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135		Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	70	70	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	184	193	180	190			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	385	315	300	330			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	260	320	300	360			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	56	56	50	50			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	26	8	8	169		Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	92	149	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	80	90	90	91			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	58	50	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	19	19			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
72	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	20	22			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x1.4+4x1.515+15x1.05	200	200	0	0	0	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	17	55	113	113			
**	Impoort (Tijura)	India		160	160	84	106	135	147			
Cumilla Zone Total				3040	2980	1397	1518	1913	2278	567	0	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	144	135	150	150	67		Gas Shortage
79	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	40	58	95	95			
81	Jamalpur 115 MW PP (Unite)	HFO (IPP)	12x9.87	115	115	0	0	115	115			
82	Mymensingh 200 MW PP (Unite)	HFO (IPP)	21x9.780	200	200	130	195	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0			
85	Tangal 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	21	22	22			
Mymensing Zone Total				717								

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.01.21 (Yesterday)		10.01.21 (Today)		09.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
86	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	45	45					
87	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	20	20					
88	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	34	53	51	51					
89	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	50	50	44	44					
90	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0					
91	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11					
92	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	67	68	68					
93	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	0	0	0	0	330	Under maint.	25/01/2021		
94	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	66	74	70	70					
95	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	163	150	200	200					
96	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20					
97	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0					
98	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	9	9	9					
99	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	16	16					
100	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	320	330	330					
101	Bibiana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400	Gas Shortage			
		Bibiyana South 400 MW	Gas (PDB)				127	130	400	400					
		Shahjibazar 100 MW GTTP	Gas (PDB)				100	0	0	0					
Sylhet Zone Total						2033	1988	913	882	1284	400	330			
102	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16					
103	Bheramara	410 MW CCPP	Gas (NWPGCL)	1 x 278+ 1 x 132	410	410	345	260	300	325	150		Gas Shortage		
104	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	3	35	35					
105	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70					
106	Khulna	225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	0	0	0	220					
107	Khulna	115 PP MW (KPCCL-2)	HFO (QRPP)	7x17	115	115	99	115	115	115					
108	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	40	0	50	100					
109	Noapara	40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	40	8	40	40					
110	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	53	105	105					
111	Madhumati	100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000		662	709	678	726					
Khulna Zone Total						2288	2284	1239	1148	1493	1852	150	0		
112	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
113	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	12	27	24	26					
114	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194	Under maint.			
115	Bhola	95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	21	21	60	61					
116	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	500	600	600					
		Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				33	42	50	56					
		United Payra Power Ltd.	HFO (IPP)				31	54	54	54					
Barishal Zone Total						1676	1676	417	644	898	907	0	194		
117	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
118		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	50					
119		Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
120		Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40					
121		Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	35	35					
122		Chapalnawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	51	93	94	94					
123		Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50					
124		Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50					
125		Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34					
126		Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	0	0	0	0			Gas Shortage		
127		Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150+ 1x75	220	220	0	0	0	0	220		Gas Shortage		
128		Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	192	180	220	220					
129		Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	319	425	400	400					
130		Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	22	22					
131		Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0					
132		Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11					
133		Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52					
134		Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	50	113	113	113					
135		Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	60	113	113	113					
Rajshahi Zone Total						2193	2183	690	958	1360	1484	601	0		
136	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
137		Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150					
138		Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
139		Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	34	113	113	113					
140		Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141		Majpara, Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
Rangpur Zone Total						685	605	188	263	271	263	170	0		
Sub-total: Plants in operation						21239	20748	7014.0	9141	12459	13631	3762	1599		
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss								6727	8767	11949	13073				
(B) Contract expired power plants															
Sub-Total: Plants under long term maintenance						0	0	0	0	0	0	0	0		
Gross Total						21239	20748	7014	9141	12459	13631	3762	1599		
(C) Actual data of 09.01.21 (Yesterday) Saturday :															
01.	Max. Demand (Generation end)		:	9141.00	MW	at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand (Sub-station end)		:	8767.00	MW	at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)		:	9141.00	MW	at =	19:30 hrs	Dhaka	3069	3069	0	Mymensingh	761	761	0
04.	Minimum Generation (Generation end)		:	5529.00	MW	at =	5:00 hrs	Chattogram	1053	1053	0	Sylhet	329	329	0
05.	Day-peak Generation (Generation end)		:	7014.00	MW	at =	12:00 hrs	Khulna	1087	1087	0	Barishal	243	243	0
06.	Evening-peak Generation (Generation end)		:	9141.00	MW	at =	19:30 hrs	Rajshahi	913	913	0	Rangpur	579	579	0
07.	Evening Peak Load-shed (Sub-station end)		:	0.00	MW	at =	19:30 hrs	Cumilla	733	733	0				
08.	Actual Minimum Generation up to 8:00 hrs.		:	5757.00	MW	at =	7:00 hrs					Total	8767	8767	0
09.	Generation shortfall at evening peak due to :		:					13.	Fuel cost :	(a) Gas = 110842288 Taka	(c) Coal = 63761635 Taka				
	a) Gas limitation		:	3410	MW					(b) Oil = 255148335 Taka	Total = 429752257 Taka				
	d) Coal supply Limitation		:	170	MW										
	b) Low water level in Kaptai lake		:	182	MW										
	c) Plants under shut down/ maintenance		:	1599	MW										
10.	Total Energy (Generation + India Import)		:	172.14	MKWh			14.	Maximum Temperature in Dhaka was :		27.6° C				
	By Gas = 105.508 MKWh				35,269	MKWh		15.	Export through East-West interconnections :						
	By Coal = 13.658 MKWh				1.104	MKWh				At evening peak-hour	:	8	MW	at	19:30 hrs
	By Solar= 0.081 MKWh									Maximum	:	-27	MW	at	19:00 hrs
11.	Total Gas Supplied		:	808.62	MMCFD					Energy	:	0.02	MKWh		
(D) Forecast of 10.01.21 (Today) Sunday :															
01.	Maximum Demand		:	9500	MW	(Generation end)		04.	Maximum Load-shed		:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation		:	13631	MW	(Generation end)		05.	Total Generation		:	178.90	MKWh		
03.	Maximum Shortage		:	-4131	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :		29.3° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation