

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month January, 2021				Day : Sunday				Date : 17.01.21				
Probable Maximum Demand : 9500 MW				Probable Maximum Generation : 13353 MW				Rule Curve = 100.15 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.23 ft.				Today = 97.23 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.01.21 (Yesterday)		17.01.21 (Today)		16.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Power Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		85	Under maint.
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under maint.
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	156	208	215	215			
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	260	260	300	300			
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	110	12	110	110	96		Gas Shortage
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0	78		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	264	239	360	360			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450		Under maint.
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	339	331	412	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	100	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	0	0	0	0	305		Gas Shortage
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	7	100	100	100			
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	64	80	80	80			
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	40	40			
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	74	86	100	100			
19	Gagnagarj 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	16	40	100	100			
20	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	57	58	58	58			
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52			
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	105	105			
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	100	149	149			
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50			
28	Kamalaghat 54 MW PP (Banos Energy)	HFO (IPP)	3x18.69	54	54	0	17	54	54			
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	250	300	300	300			
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	62	149	149	149			
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300			
32	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
33	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	17	17	55	55			
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	35	37			
36	Bosila 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	53	90	90			
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	144	162			
Dhaka Zone Total				6281	6057	1915	2474	3488	3758	1264	895	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	47	45	46	46	185		Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	0	25			
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	33	50	50	50			
45	Sikalbaha 105 MW PP (Baraka Sike)	HFO (IPP)	6x18.415	105	105	0	0	0	100			
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Gas Shortage
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Gas Shortage
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	231	305	300	300			
49	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	0	100	100			
50	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	30	50	100	100			
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	102	102			
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	15	15	15			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	26	10	25			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	31	90	90			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
57	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
	Anlima Energy Ltd.	HFO (IPP)				0	0	0	0			
Chattogram Zone Total				2326	2266	532	752	1102	1217	740	180	
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135		Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	3	3	5	5			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	157	144	225	225			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	280	360	360			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	260	280	360	360			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	0	0	0	55		Gas shortage
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	75	81	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	35	50	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	21	21			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11			
72	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	18	20	22			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x1.4+40x1.515+15x1.05	200	200	0	0	0	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	52	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	25	46	113	113			
**	Impoort (Tijura)	India		160	160	62	114	134	146			
Cumilla Zone Total				3040	2980	1015	1187	1857	2121	640	0	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	87	80	100	100	122		Gas Shortage
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	90	95	95			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	60	115	115			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	200	200	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0			
84	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	34	0	50	0			
85	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	20	18	22	22			

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.01.21 (Yesterday)		17.01.21 (Today)		16.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	20	20	20	20					
87	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43					
88	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	8	8	8	8					
89	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	5	5	5	5					
90	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	140	110	163	163					
91	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
92	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	33	40	40					
93	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	0	0	0	0	330	Under maint.	25/01/2021		
94	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	69	71	70	70					
95	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	80	150	120	150					
96	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	20	20					
97	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0					
98	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	9	9					
99	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x3.34	25	25	8	8	8	8					
100	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	341	341					
101	Bibiana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400	Gas Shortage			
		Bibiyana South 400 MW	Gas (PDB)				270	270	270	270					
		Shahjibazar 100 MW GTTP	Gas (PDB)				100	100	100	100		On Test			
		Sylhet Zone Total			2033	1988	1070	1138	1228	1258	400	330			
102	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16					
103	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	350	345	370	370	65	Gas Shortage			
104	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	5	4	35	35					
105	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70					
106	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220					
107	Khulna	115 PP MW (KPL-2)	HFO (QRPP)	7x17	115	115	55	115	115	115					
108	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100					
109	Noapara	40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	40	40	40					
110	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	90	90	90					
111	Madhumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India			1000	1000	727	856	741	885					
		Khulna Zone Total			2288	2284	1172	1450	1611	2041	65	0			
112	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
113	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	28	24	28					
114	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194	Under maint.			
115	Bhola	95 MW PP (Agreko)	Gas (QRPP)	1,1x96	95	95	30	48	80	80					
116	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	370	470	600	600					
		Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				37	41	50	56					
		United Payra Power Ltd.	HFO (IPP)				45	45	0	0					
		Barishal Zone Total			1676	1676	499	632	864	874	0	194			
117	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage			
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage			
118		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	0	50					
119		Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
120		Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40					
121		Ammura 50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	0	0	28	28					
122		Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	102	104	104					
123		Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50					
124		Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	50	50	50					
125		Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	34					
126		Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage			
127		Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage			
128		Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage			
129		Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	382	324	400	400					
130		Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
131		Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0					
132		Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11					
133		Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	44	52	52					
134		Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	70	113	113	113					
135		Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113					
		Rajshahi Zone Total			2193	2183	592	801	1143	1267	821	0			
136	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage			
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage			
137		Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	149	150	150	150					
138		Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
139		Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2'3	113	113	107	113	113	113					
140		Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
141		Majpara, Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	1	0	8	0					
		Rangpur Zone Total			685	605	257	263	271	263	170	0			
		Sub-total: Plants in operation			21239	20748	7421.0	9165	12170	13353	4222	1599			
		Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss					7102	8771	11646	12779					
(B) Contract expired power plants															
		Sub-Total: Plants under long term maintenance			0	0	0	0	0	0					
		Gross Total			21239	20748	7421	9165	12170	13353	4222	1599			
(C) Actual data of 16.01.21 (Yesterday) Saturday :															
01.	Max. Demand (Generation end) : 9165.00 MW, at = 19:30 hrs				12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand (Sub-station end) : 8771.00 MW, at = 19:30 hrs				Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end) : 9165.00 MW, at = 19:30 hrs					MW	MW	MW		MW	MW	MW			
04.	Minimum Generation (Generation end) : 5310.00 MW, at = 4:00 hrs				Dhaka	2990	2990	0	Mymensingh	779	779	0			
05.	Day-peak Generation (Generation end) : 7421.00 MW, at = 12:00 hrs				Chattogram	1007	1007	0	Sylhet	326	326	0			
06.	Evening-peak Generation (Generation end) : 9165.00 MW, at = 19:30 hrs				Khulna	1095	1095	0	Barishal	245	245	0			
07.	Evening Peak Load-shed (Sub-station end) : 0.00 MW, at = 19:30 hrs				Rajshahi	929	929	0	Rangpur	634	634	0			
08.	Actual Minimum Generation up to 8:00 hrs. : 5531.00 MW, at = 7:00 hrs				Cumilla	766	766	0							
09.	Generation shortfall at evening peak due to :								Total	8771	8771	0			
	a) Gas limitation : 3867 MW				13.	Fuel cost :	(a) Gas = 99974904 Taka	(c) Coal = 66281827 Taka							
	d) Coal supply Limitation : 170 MW						(b) Oil = 288399700 Taka	Total = 454656431 Taka							
	b) Low water level in Kaptai lake : 185 MW														
	c) Plants under shut down/ maintenance : 1599 MW														
10.	Total Energy (Generation + India Import) : 173.62 MKWh				14.	Maximum Temperature in Dhaka was : 23.6° C									
	By Gas = 99.725 MKWh				15.	Export through East-West interconnections :									
	By Coal = 14.236 MKWh					At evening peak-hour : 66 MW, at 19:30 hrs									
	By Solar = 0.293 MKWh					Maximum : 33 MW, at 20:00 hrs									
	By Hydro = 4.065 MKWh					Energy : 0.014 MKWh									
11.	Total Gas Supplied : 756.85 MMCFD														
(D) Forecast of 17.01.21 (Today) Sunday :															
01.	Maximum Demand : 9500 MW (Generation end)				04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation : 13353 MW (Generation end)				05.	Total Generation : 179.97 MKWh									
03.	Maximum Shortage : -3853 MW (Generation end)				06.	Probable Max. Temperature in Dhaka : 25.7° C									

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazool Islam Shaker)
Deputy Secretary, Generation