

**EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : 27-Jan-21

Page -2

| Sl. No.                      | Name of the Power Stations      | Producer       | Installed Capacity | Present Capacity | Peak Hour   | Enerov Generated | Remarks                            |
|------------------------------|---------------------------------|----------------|--------------------|------------------|-------------|------------------|------------------------------------|
|                              |                                 |                |                    |                  |             |                  |                                    |
| 1                            | Ghorasal TPP (Unit-1&2)         | PDB            | 2*55               | 85               | 0           | 0                | Unit-1,2 Under maint.              |
|                              | Ghorasal Repowered CCPP Unit    | PDB            | 1*210              | 170              | 0           | 0                | Under maint.                       |
|                              | Ghorasal Repowered CCPP Unit    | PDB            | 1*210              | 180              | 0           | 0                | Under maint.                       |
|                              | Ghorasal TPP Unit-5             | PDB            | 1*210              | 190              | 180         | 4315500          |                                    |
| 2                            | Ghorasal 365 MW CCPP Unit-7     | PDB            | 1*243+1*122        | 365              | 0           | 0                | Under maint.                       |
| 3                            | Ghorasal 78.5 MW PP(MAX)        | QRPP           | 2*40               | 78               | 0           | 0                | Contract Expired                   |
| 4                            | Ghorasal 108MW PP (Regent)      | IPP            | 34*3.35            | 108              | 109         | 2485045          |                                    |
| 5                            | Haripur GTPP                    | SBU, PDB       | 2*32               | 20               | 0           | 0                | Under maint.                       |
| 6                            | Haripur 412 MW CCPP             | EGCB           | 1*273+1*139        | 412              | 0           | 0                | Under maint.                       |
| 7                            | Haripur 360MW CCPP(HPL)         | IPP            | 1*235+1*125        | 360              | 356         | 8220000          |                                    |
| 8                            | Meghnaghat 450 MW CCPP(MP)      | IPP            | 2*150+1*150        | 450              | 0           | 0                |                                    |
| 9                            | Meghnaghat 100 MW(IEI)          | QRPP           | 12*8.9             | 100              | 100         | 1392000          |                                    |
| 10                           | Meghnaghat CCPP(Summit)         | IPP            | 2*110+1*110        | 305              | 275         | 6678865          | Gas shortage                       |
| 11                           | Madanganj 102 PP(Summit)        | QRPP           | 6*17               | 100              | 90          | 1679424          | Engine problem                     |
| 12                           | Madanganj-55 MW PP(Summit)      | (IPP)          | 3*17.08+1*11.3     | 55               | 55          | 942284           |                                    |
| 13                           | Keraniganj 100 MW PP (Power)    | QRPP           | 8*13.45            | 100              | 52          | 1538145          | Engine problem                     |
| 14                           | Narshingdi 22 MW PP (Doreen)    | SIPP, REB      | 8*2.90             | 22               | 16          | 381276           | Engine problem                     |
| 15                           | 210 MW Siddhirganj TPP          | PDB            | 1*210              | 115              | 0           | 0                | Under maint.                       |
| 16                           | Siddhirganj 2*120 MW GTTP       | EGCB           | 2*105              | 210              | 182         | 4077000          |                                    |
| 17                           | Siddhirganj 100 PP(Dutch Bangl) | QRPP           | 12*8.9             | 100              | 100         | 1317120          |                                    |
| 18                           | Siddhirganj 335 MW CCPP         | EGCB           | 1*217+118          | 335              | 0           | 0                | Under maint.                       |
| 19                           | Gagnagar 102 MW PP (Digital P   | IPP            | 12*8.924           | 102              | 102         | 823824           |                                    |
| 20                           | Katpoti 52 MW PP (Sinha)        | IPP            | 7*7.9              | 51               | 0           | 0                | Reserve.                           |
| 21                           | Kamalaghat 54 MW PP(Banco E     | IPP            | 3*18               | 54               | 54          | 441000           |                                    |
| 22                           | Kodda 150MW PP                  | BPDB-RPCL      | 9*17.06            | 149              | 150         | 949440           |                                    |
| 23                           | Manikganj 55 MW PP (Northern    | IPP            | 3*19.3             | 55               | 35          | 422130           | Engine problem                     |
| 24                           | Nabaganj 55 MW PP (Southern     | IPP            | 3*19.3             | 55               | 9           | 771066           | Engine problem                     |
| 25                           | Bosila 108MW PP(ELC)            | IPP            | 12*8.775+1*13.5    | 108              | 0           | 0                | Fuel shortage                      |
| 26                           | Summit Power (Madhabdi+Ashu)    | SIPP, REB      | 3*3.67+4*8.73      | 80               | 53          | 1282200          | Engine problem                     |
| 27                           | Maona 33 MW PP(Summit)          | SIPP, REB      | 4*8.73             | 33               | 17          | 421800           | Engine problem                     |
| 28                           | Rupganj 33 MW PP(Summit)        | SIPP, REB      | 4*8.73             | 33               | 33          | 838800           |                                    |
| 29                           | Gazipur 52 MW PP                | IPP            | 6*8.9              | 52               | 0           | 0                | Reserve.                           |
| 30                           | Tongi 80 MW GTTP                | PDB            | 1*105              | 105              | 0           | 0                | Under maint.                       |
| 31                           | Kodda 300 MW PP Unit-2 (Sum     | IPP            | 18*17.076          | 300              | 267         | 5223925          | Engine problem                     |
| 32                           | Keraniganj 300 MW PP (APR)      | IPP            | 256*1.4            | 300              | 70          | 142903           | Low demand                         |
| 33                           | Bramhangsanj 100 MW PP (Ag      | IPP            | 100                | 0                | 0           | 0                | Reserve.                           |
| 34                           | Aurahati 100MW PP (Aggreko)     | IPP            | 0.85*23+0.95*91    | 100              | 27          | 33237            | Low demand                         |
| 35                           | Kodda 149 MW PP Unit-1 (Sum     | IPP            | 149                | 149              | 149         | 2411140          |                                    |
| 36                           | Gazipur 100 MW PP               | RPCL           | 100 MW             | 105              | 90          | 432336           | Engine problem                     |
| 37                           | Meghnaghat 104 MW PP (OPCL      | IPP            | 18.5*6             | 104              | 36          | 1600320          | Engine problem                     |
| 38                           | Manikganj 162MW PP(MPGL)        | IPP            | 9*18               | 162              | 144         | 2825280          | Engine problem                     |
| <b>Dhaka area Total</b>      |                                 |                |                    | <b>6057</b>      | <b>2751</b> | <b>5164060</b>   |                                    |
| 39                           | Chattogram TPP-1                | PDB            | 1*210              | 180              | 0           | 0                | Gas shortage.                      |
|                              | Chattogram TPP-2                | PDB            | 1*210              | 180              | 0           | 0                | Gas shortage                       |
| 40                           | Razzan 25 MW PP                 | IPP            | 3*8.9              | 25               | 25          | 140020           |                                    |
| 41                           | Teknaf 20MW PP (Solar)Solar     | SolarTech Ener | 20                 | 20               | 0           | 111105           |                                    |
| 42                           | Palenga 50MW PP (Baraka)        | IPP            | 8*6.98             | 50               | 19          | 450720           | Engine problem                     |
| 43                           | Kaptai Hydro Unit-1,2,3,4, 5    | PDB            | 2*40+3*50          | 230              | 67          | 1482698          | Unit-2 under maint                 |
| 44                           | Sikalbaha 225MW                 | PDB            | 1*150+1*175        | 225              | 0           | 0                | Gas shortage                       |
| 45                           | Sikalbaha Peaking GT            | PDB            | 1*150              | 150              | 0           | 0                | Gas shortage                       |
| 46                           | Sikalbaha 105 MW PP (Baraka)    | IPP            | 105 MW             | 105              | 0           | 56872            | Reserve.                           |
| 47                           | Hathazari 100 MW peaking PP     | PDB            | 11*8.9             | 98               | 0           | 0                | Under maint.                       |
| 48                           | Dohazari-Kalash 100 MW Peak     | PDB            | 6*17               | 102              | 85          | 596517           |                                    |
| 49                           | Juldah 100 MW Unit-1 (Accor)    | QRPP           | 8*13.45            | 100              | 0           | 56040            | High Voltage.                      |
| 50                           | Juldah 100 MW PP Unit-3 (Acco   | IPP            | 0                  | 100              | 100         | 153440           |                                    |
| 51                           | Barabkunda 22 MW PP (Regen      | SIPP, PDB      | 8*2.90             | 22               | 17          | 437152           | Engine problem                     |
|                              | Malancha, Ctg. EPZ (United)     |                | 5*8.73+3*9.34      | 0                | 42          | 997920           |                                    |
| 52                           | Chattogram 108 MW PP (ECPV      | IPP            | 16*7               | 108              | 12          | 128640           | Low demand                         |
| 53                           | Kaptai 7 MW Solar PP            | PDB            | 7.4 MW             | 7                | 0           | 27840            |                                    |
| 54                           | Anwara 300 MW PP (United)       | IPP            | 300 MW             | 300              | 303         | 7133345          |                                    |
| 55                           | Jodiad Power                    | IPP            | 3*18.55+1*3.6      | 54               | 54          | 773109           |                                    |
| 56                           | Karnagshuli Power Ltd.          | IPP            | 110                | 110              | 0           | 0                | Reserve.                           |
| 57                           | Juldah unit-2 (Accor)           | IPP            | 8*13.6             | 100              | 100         | 2433600          |                                    |
|                              | Anlima Energy Ltd.              | IPP            | 6*21.2             | 0                | 0           | 0                | on test                            |
| <b>Chattogram area Total</b> |                                 |                |                    | <b>2266</b>      | <b>824</b>  | <b>16395978</b>  |                                    |
| 58                           | Ashuganj TPP Unit- 3            | APSCL          | 1*150              | 135              | 100         | 2323210          | Gas shortage                       |
|                              | Ashuganj TPP Unit- 4            | APSCL          | 1*150              | 129              | 0           | 0                | Gas shortage                       |
|                              | Ashuganj TPP Unit- 5            | APSCL          | 1*150              | 134              | 0           | 0                | Gas shortage                       |
| 59                           | Ashuganj 225 MW CCPP            | APSCL          | 1*142+1*75         | 221              | 183         | 4560000          | Gas shortage                       |
| 60                           | Ashuganj 450 MW CCPP(North      | APSCL          | 1*360              | 360              | 0           | 0                | Gas shortage                       |
| 61                           | Ashuganj 450 MW CCPP(South      | APSCL          | 1*360              | 360              | 300         | 7733000          | FGMO                               |
| 62                           | Ashuganj 50 MW PP (Precision    | APSCL          | 14*3.68            | 45               | 26          | 571032           | Gas shortage                       |
| 63                           | Ashuganj 55 MW PP (Precision    | RPP            | 15*4               | 55               | 30          | 328320           | Gas shortage                       |
| 64                           | Ashuganj 195MW PP (APSCL-L      | IPP            | 20*9.73+1*16       | 195              | 26          | 652363           | Gas shortage                       |
| 65                           | Ashuganj 51 MW PP (Midland)     | IPP            | 6*9.34             | 51               | 51          | 1254553          |                                    |
| 66                           | Ashuganj 150MW PP (Midland)     | IPP            | 23*7.015           | 150              | 18          | 709236           | Engine problem                     |
| 67                           | Titas 50 MW Peaking PP          | PDB            | 6*8.92             | 52               | 42          | 59704            | Engine problem                     |
| 68                           | Chandpur 150 MW CCPP            | PDB            | 1*106+1*57         | 163              | 100         | 2330080          | Machine problem                    |
|                              | Chandpur 20MW (Desh energy      | IPP            | 0                  | 200              | 17          | 431520           | High Voltage.                      |
| 69                           | Feni 22MW PP (Doreen)           | SIPP, PDB      | 8*9.30             | 22               | 16          | 413352           | Engine problem                     |
| 71                           | Feni 11 MW PP (Doreen)          | SIPP, REB      | 4*2.90             | 11               | 8           | 194400           | Engine problem                     |
| **                           | Impoort (Tripura)               | Imported power | 0                  | 160              | 106         | 2021760          |                                    |
| 72                           | Jangalia 33MW PP (Summit)       | SIPP, PDB      | 4*8.73             | 33               | 33          | 694700           |                                    |
| 73                           | Jangalia 52 MW PP (Lakdanavi)   | IPP            | 6*8.92             | 52               | 0           | 0                | Reserve.                           |
| 74                           | Cumilla 25 MW PP (Summit)       | SIPP, PDB      | 3*3.67+2*6.97      | 25               | 22          | 547890           |                                    |
| 75                           | Daudkandi 200 MW PP (B.Trac)    | IPP            | 154*1.4            | 200              | 0           | 0                | Reserve.                           |
| 76                           | Feni Lanka Power                | IPP            | 7*18.415+1*9.78    | 114              | 0           | 0                | Reserve.                           |
| 77                           | Chowmuhani 113 MW               | IPP            | 12*9.78+2*3.1      | 113              | 81          | 993600           | Low demand                         |
| <b>Cumilla Area Total</b>    |                                 |                |                    | <b>2980</b>      | <b>1159</b> | <b>2584270</b>   |                                    |
| 78                           | RPCL 210MW CCPP                 | IPP            | 4*35+1*70          | 202              | 77          | 2186750          | Gas shortage                       |
| 79                           | Tangal 22 MW PP (Doreen)        | SIPP, PDB      | 8*2.90             | 22               | 0           | 445572           |                                    |
| 80                           | Jamalpur 95 MW PP(Powerpac)     | IPP            | 12*8.924           | 95               | 25          | 488640           | Engine problem                     |
| 81                           | Sarishabari 3 MW Solar Plant    | IPP            | 1*3                | 3                | 0           | 5000             |                                    |
| 82                           | Mymensingh 200 MW PP (Unit      | IPP            | 200                | 200              | 200         | 3784800          |                                    |
| 83                           | Jamalpur 115 MW PP (United)     | IPP            | 115 MW             | 115              | 104         | 867600           |                                    |
| 84                           | Sutiakhali 50 MW Solar PP       | IPP            | 50                 | 50               | 0           | 165390           |                                    |
| 85                           | Tangal Palli Power Gen 22 MW    | IPP            | 4*6.7              | 22               | 0           | 386720           | Engine problem                     |
| <b>Mymensingh Area Total</b> |                                 |                |                    | <b>709</b>       | <b>406</b>  | <b>8310462</b>   |                                    |
| 86                           | Fenchuganj CCPP Phase-1         | PDB            | 2*32+1*33          | 70               | 30          | 713300           | Gas shortage & GT-2 under maint.   |
| 87                           | Fenchuganj CCPP Phase-2         | PDB            | 2*35+1*35          | 90               | 0           | 0                | Under maint.                       |
| 88                           | Kushara 163 MW CCPP (KP)        | IPP            | 1*109+1*54         | 163              | 163         | 3470072          |                                    |
| 89                           | Shajibazar 330 MW CCPP          | PDB            | 3*110              | 330              | 0           | 0                | Under maint.                       |
| 90                           | Fenchuganj 51 MW PP (Baraka)    | RPP            | 19*2.90            | 51               | 50          | 1177800          |                                    |
| 91                           | Fenchuganj 44MW (Energyprim     | RPP            | 12*3.3+5*2         | 44               | 50          | 1110096          |                                    |
| 92                           | Hobiganj 11MW PP Confidence-1   | SIPP, REB      | 4*2.90             | 11               | 11          | 262000           |                                    |
| 93                           | Shajibazar GTPP Unit- 8 & 9     | PDB            | 2*35               | 66               | 0           | 0                | GT-8,9 Under maint.                |
| 94                           | Shajibazar 80MW PP (Shahjib     | RPP            | 32*2.90            | 80               | 74          | 1634880          | Engine problem                     |
|                              | Shajibazar 100 MW GTPP          | PDB            | 1*100              | 0                | 100         | 2241000          | On test.                           |
| 95                           | Sylhet 225 MW CCPP              | PDB            | 1*142+1*89         | 231              | 150         | 2706830          |                                    |
| 96                           | Sylhet 20 MW GTTP               | PDB            | 1*20               | 20               | 19          | 444000           |                                    |
| 97                           | Sylhet 50MW PP (EPL)            | RPP            | 27*2               | 50               | 0           | 0                | Contract Expired                   |
| 98                           | Shahjahanulla 25 MW PP          | SIPP, REB      | 3*9.34             | 25               | 8           | 191055           | Engine problem                     |
| 99                           | Bibiana-II 341 MW CCPP (Sumr    | IPP            | 1*222+1*119        | 341              | 310         | 7425000          | FGMO                               |
| 100                          | Bibiyana-III 400 MW CCPP        | PDB            | 400 MW             | 400              | 0           | 0                | Gas shortage & Bibiyana south test |
| 101                          | Sylhet 10MW PP (Desh)           | RPP            | 6*1.95             | 10               | 5           | 167760           |                                    |
|                              | Bibiyana South 400 MW           | PDB            | 400 MW             | 0                | 400         | 5869000          | On test                            |
| <b>Sylhet Area Total</b>     |                                 |                |                    | <b>1988</b>      | <b>1370</b> | <b>27411993</b>  |                                    |
| 102                          | Bheramara GTPP Unit-3           | PDB            | 1*20               | 16               | 0           | 0                | Reserve.                           |
| **                           | Bheramara (HVDC )               | Imported power | 2*500              | 1000             | 718         | 15962909         |                                    |
| 103                          | Khulna 115 PP MW (KPCL-2)       | QRPP           | 7*17               | 115              | 115         | 1191360          |                                    |
| 104                          | Fairidpur 50 MW Peaking PP      | PDB            | 8*6.89             | 54               | 19          | 197760           |                                    |
| 105                          | Khulna 225 MW CCPP              | NWPGCL         | 1*150+1*75         | 230              | 0           | 0                | Reserve.                           |
| 106                          | Gopalganj 100 MW Peaking PP     | PDB            | 16*6.98            | 109              | 11          | 48304            | Low demand                         |
| 107                          | Bheramara 410 MW CCPP           | NWPGCL         | 1*278+1*132        | 410              | 345         | 8865068          |                                    |
| 108                          | Noapara 40 MW PP (Summit)       | QRPP           | 6*8.5              | 40               | 33          | 196875           | Engine problem                     |
| 109                          | Noapara 100 MW PP (Bangla T     | IPP            | 70*1.4             | 100              | 50          | 103680           | Low demand                         |
| 110                          | Rupsha 105 MW PP (Onon nups     | IPP            | 6*18.445           | 105              | 95          | 1529760          | Engine problem                     |
| 111                          | Madhumati 100 MW PP             | SWPGCL         | 100 MW             | 105              | 50          | 117936           | Low demand                         |
| <b>Khulna Area Total</b>     |                                 |                |                    | <b>2284</b>      | <b>1436</b> | <b>28233672</b>  |                                    |
| 112                          | Barisal 110 MW PP (Summit )     | IPP            | 7*17.076           | 110              | 80          | 1306560          | Low demand                         |
| 113                          | Bhola 33 MW PP (Venture)        | RPP            | 1*34.50            | 33               | 25          | 469000           | Engine problem                     |
| 114                          | Bhola 225 MW CCPP               | PDB            | 2*63+1*68          | 194              | 0           | 0                | Under maint.                       |
| 115                          | Bhola 95 MW PP (Aggreko)        | QRPP           | 96*1.10            | 95               | 91          | 2063820          |                                    |
| 116                          | Payra 1320 MW                   | BCPCL          | 2*622              | 1244             | 0           | 0                | Under maint.                       |
|                              | Bhola Nulian Bypass BDLTD       | IPP            | 0                  | 35               | 35          | 206372           | On test.                           |
|                              | United Power Ltd.               | IPP            | 8*18.5+1*9.5       | 0                | 35          | 115200           | On test.                           |
| <b>Barisal Area Total</b>    |                                 |                |                    | <b>1676</b>      | <b>266</b>  | <b>4160952</b>   |                                    |
| 117                          | Baghabari 71 MW GTTP            | PDB            | 1*71               | 71               | 0           | 0                | Gas shortage.                      |
|                              | Baghabari 100 MW GTTP           | PDB            | 1*100              | 100              | 0           | 0                | Gas shortage.                      |
| 118                          | Baghabari 50 MW Peaking PP      | PDB            | 6*8.9              | 52               | 50          | 499049           |                                    |
| 119                          | Bera 70 MW Peaking PP           | PDB            | 9*8.29             | 71               | 42          | 190720           | Low demand                         |
| 120                          | Amnura 50 MW PP(Sinha)          | QRPP           | 7*7.9              | 50               | 25          | 429540           | Engine problem                     |
| 121                          | Katakhal 50 MW PP (Northern     |                |                    |                  |             |                  |                                    |