

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month January, 2021				Day: Sunday				Date : 31.01.21						
Probable Maximum Demand :		9300 MW		Probable Maximum Generation :		13415 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday =	95.92 ft		Today =	95.92 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.01.21 (Yesterday)		31.01.21 (Today)		Rule Curve = 97.20 ft	30.01.21 (Yesterday) Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Generation (MW)	Probable Peak Generation (MW)	Day	Evening						
(A) Plants in operation:														
1	a) Ghorasal TPP (Unit-1&2)	Gas (PDB)	2 x 55	110	85	0	0	0	0		85	Under maint.		
	b) Ghorasal Repowered CCPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under maint.		
	c) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
	d) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
2	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.		
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	105	108	108	108					
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0			Contract Expired		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	310	358	360	360					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450		Under maint.	9/2/2021	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0		412	Under Maint.	8/2/2021	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	190	155	200	200	55		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	7	50	100	100					
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	230	280	305	305					
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	24	24	100	100					
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	99	100	100	100					
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	42	45	55	55					
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	60	84	100	100					
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	0	40	100	100					
20	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22					
21	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+6x7.3	80	80	37	53	58	58					
22	Macona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	25	25	25					
23	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
24	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52					
25	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	50	105	105					
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	100	149	149					
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	50	50					
28	Kamalaghat 54 MW PP (Banos Energy)	HFO (IPP)	3x18.69	54	54	17	35	54	54					
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	65	145	300	300					
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	102	130	149	149					
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300					
32	Bramhanagan 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100					
33	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100					
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	55	55	55	55					
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	35	35					
36	Bosila 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	90	104	104					
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	144	144	144					
	Dhaka Zone Total			6281	6057	1789	2341	3293	3543	630	1662			
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	54	54	68	68	176		Low Water Level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0					
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25					
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	45	46	46	46					
45	Sikalbaha 105 MW PP (Baraka Sike)	HFO (IPP)	6x18.415	105	105	0	0	0	100					
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Gas Shortage		
47	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		Gas Shortage		
48	Anwara 300 MW PP (Uniled)	HFO (IPP)	17x17.076+ 3x8.04	300	300	265	307	300	300					
49	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	0	100	100					
50	Juldah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	95	50	100	100					
51	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	92	85	100					
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0					
53	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22					
*	Malancha, Ctg EPZ (Uniled)	Gas	5x8.73+3x9.34			14	28	25	40					
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	3	97	97					
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	54	54					
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110					
57	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	70	100	100					
	Anlima Energy Ltd.	HFO (IPP)				0	0	0	0					
	Chattogram Zone Total			2326	2266	613	712	1157	1262	731	180			
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	100	130	100	100	5		Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	20	26	26	25		Gas Shortage		
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	212	184	225	225					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	350	350	350	350					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0		360	Under Maint.	3/2/2021	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	8	8	8	47		Gas Shortage		
64	Ashuganj 195MW PP (APSCL-Uniled)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	105	144	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	100	95	100	100					
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	50	200	200					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	22	22					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
72	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
73	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	22	22					
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x1.4+4x1.515+15x1.05	200	200	0	0	0	200					
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	16	16	113	113					
**	Import (Tiripura)	India		160	160	80	114	135	147					
	Cumilla Zone Total			3040	2980	1125	1256	1720	1982	527	360			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	113	106	110	110	96		Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	22	22	22					
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	82	90	90					
81	Jamalpur 115 MW PP (Uniled)	HFO (IPP)	12x9.87	115	115	0	16	115	115					
82	Mymensingh 200 MW PP (Uniled)	HFO (IPP)	21x9.780	200	200	200	200	200	200					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
84	Sutiaikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	35	0	50	0					
85	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	18	23	22	22					
	Mymensingh Zone Total			717	709	376	449	611	559	96	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.01.21 (Yesterday)		31.01.21 (Today)		30.01.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	29	30	30	30				
87	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0				
88	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	5	51	51	51				
89	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	5	50	50	50				
90	Kushiana	163 MW CCPP (KF)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0				
91	Hobiganj	11MW PP Cofidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0		66	Under maint.	
93	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	0	0	0	0	330		Gas Shortage	
94	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	69	74	74	74				
95	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	30	0	0	0				
96	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
97	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0				
98	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	10				
99	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x3.34	25	25	0	16	16	16				
100	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	341	300	341	341				
101	Bibiana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	303	150	320	320	250		Gas Shortage	
		Bibiyana South	400 MW	Gas (PDB)			408	415	415	415				
		Shahjibazar	100 MW GTTP	Gas (PDB)			100	100	100	100			On Test	
Sylhet Zone Total					2033	1988	1301	1197	1418	1418	580	66		
102	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
103	Bheramara	410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	395	345	410	410				
104	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25				
105	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	70	70				
106	Khulna	225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	0	0	0	220				
107	Khulna	115 PP MW (KPLC-2)	HFO (QRPP)	7x17	115	115	0	99	115	115				
108	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
109	Noapara	40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	40	40				
110	Rupsha	105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	76	94	95	95				
111	Madhumati	100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	700	887	719	911					
Khulna Zone Total					2288	2284	1171	1425	1624	2102	0	0		
112	Barisal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110				
113	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	27	22	22				
114	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0		194	Under maint.	
115	Bhola	95 MW PP (Agreko)	Gas (QRPP)	1,1x96	95	95	55	88	95	95				
116	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	450	520	620	620				
		Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	35	35				
		United Payra Power Ltd.	HFO (IPP)				0	0	50	150				
Barishal Zone Total					1676	1676	525	683	932	1032	0	194		
117	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
118		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	0	50				
119		Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
120		Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
121		Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	25	25	25	25				
122		Chapanawaganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	102	104	104				
123		Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	50	50				
124		Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
125		Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	4	0	34				
126		Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127		Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150 + 1x75	220	220	211	151	220	220				
128		Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	197	161	220	220				
129		Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0		414	Under Maint.	
130		Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22				
131		Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0				
132		Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
133		Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	25	25	52	52				
134		Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	35	113	113	113				
135		Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6'18.55	113	113	0	113	113	113				
Rajshahi Zone Total					2193	2183	526	752	1130	1254	381	414		
136	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
137		Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	149	150	150				
138		Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139		Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	111	113	113				
140		Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141		Majpara, Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
Rangpur Zone Total					685	605	152	260	271	263	170	0		
Sub-total: Plants in operation					21239	20748	7578.0	9075	12156	13415	3115	2876		
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss							7178	8596	11514	12707				
(B) Contract expired power plants														
Sub-Total: Plants under long term maintenance					0	0	0	0	0	0	0	0	0	0
Gross Total					21239	20748	7578	9075	12156	13415	3115	2876		

(C) Actual data of 30.01.21 (Yesterday) Saturday :													
01. Max. Demand (Generation end) : 9075.00 MW, at = 19:30 hrs					12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02. Max. Demand (Sub-station end) : 8596.00 MW, at = 19:30 hrs					Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03. Highest Generation (Generation end) : 9075.00 MW, at = 19:30 hrs					MW	MW	MW	MW	MW	MW	MW	MW	
04. Minimum Generation (Generation end) : 5459.00 MW, at = 5:00 hrs					Dhaka	2895	2895	0	Mymensingh	752	752	0	
05. Day-peak Generation (Generation end) : 7578.00 MW, at = 12:00 hrs					Chattogram	887	887	0	Sylhet	355	355	0	
06. Evening-peak Generation (Generation end) : 9075.00 MW, at = 19:30 hrs					Khulna	1090	1090	0	Barishal	238	238	0	
07. Evening Peak Load-shed (Sub-station end) : 0.00 MW, at = 19:30 hrs					Rajshahi	952	952	0	Rangpur	673	673	0	
08. Actual Minimum Generation up to 8:00 hrs. : 5628.00 MW, at = 7:00 hrs					Cumilla	754	754	0					
09. Generation shortfall at evening peak due to :					Total				Total 8596 8596 0				
a) Gas limitation : 2769 MW					13. Fuel cost :			(a) Gas = 98054602 Taka	(c) Coal = 6350719 Taka				
d) Coal supply Limitation : 170 MW					(b) Oil = 267284437 Taka			Total = 430689757 Taka					
b) Low water level in Kaptai lake : 176 MW					14. Maximum Temperature in Dhaka was : 23.8° C								
c) Plants under shut down/ maintenance : 2876 MW					15. Export through East-West interconnections :								
10. Total Energy (Generation + India Import) : 174.51 MKWh					At evening peak-hour : -76 MW, at 19:30 hrs								
					Maximum : -206 MW, at 8:00 hrs								
					Energy : 1.1265 MKWh								
11. Total Gas Supplied : 815.03 MMCFD													

(D) Forecast of 31.01.21 (Today) Sunday :				
01. Maximum Demand : 9300 MW (Generation end)		04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)		
02. Maximum Generation : 13415 MW (Generation end)		05. Total Generation : 178.84 MKWh		
03. Maximum Shortage : -4115 MW (Generation end)		06. Probable Max. Temperature in Dhaka : 24.4° C		

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00
 * Captive Power ** Imported Power
 (Faouzi Islam Shaker)
 Deputy Secretary, Generation