

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present			Remarks	
				Capacity	Peak Hour	Energy Generated		
			Unit No. X Capacity	MW	MW	MW		
1	Ghorasal TPP (Unit-1&2)	PDB	2*35	85	0	0	Unit-1,2 Under maint.	
36	Ghorasal Repowered CCPP Unit-	PDB	1*210	170	0	0	Gas shortage	
37	Ghorasal Repowered CCPP Unit-	PDB	1*210	180	0	2006000	Gas shortage	
38	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.	
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	330	7534282		
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0	Gas shortage	
4	Ghorasal 108MW PP (Regent)	IPP	3*43.35	108	98	1544136		
5	Hariapur GTPP	SEB, PDB	2*32	20	0	0	Under maint.	
6	Hariapur 412 MW CCPP	EGCB	1*273+1*139	412	351	8500220		
7	Hariapur 360MW CCPP(HPL)	IPP	1*235+1*125	360	359	7418000		
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	0	0	Under maint.	
9	Meghnaghat 100 MW(EL)	QRPP	12*8.9	100	0	48000	Reserve.	
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	0	0	Gas shortage	
11	Madaganj 102 PP(Summit)	QRPP	6*14	90	15	226532	Low demand	
12	Madaganj 55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	0	26570	Reserve.	
13	Keraniganj 100 MW PP (Powerpa)	QRPP	8*13.45	100	85	979449	Engine problem	
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	451116		
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.	
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage	
17	Siddhirgonj 100 MW Dutch Bangle	QRPP	12*8.9	100	0	21120	Reserve.	
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	0	0	Under maint.	
19	Gagnagar 102 MW PP (Digital Po)	IPP	12*8.924	102	0	27216	Reserve.	
20	Kalpotti 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Reserve.	
21	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	17	110160	Low demand	
22	Kodda 150MW PP	BPDB- RPCL	9*17.06	149	16	48960	Low demand	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	0	0	Reserve.	
24	Nabaganj 55 MW PP (Southern)	IPP	3*19.3	55	55	301020		
25	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage	
26	Summit Power, (Madhabdi+Ashula)	SIPP, REB	3*3.67+4*8.73	80	53	1154760	Engine problem	
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	17	463400	Engine problem	
28	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	491100	Engine problem	
29	Gazpur 52 MW PP	IPP	6*8.9	52	0	0	Reserve.	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.	
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	245	2473963	High Voltage.	
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Reserve.	
33	Bramhangan 100 MW PP (Aggr)	IPP	100	100	0	0	Reserve.	
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.	
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	17	104976	Low demand	
36	Gazpur 100 MW PP (Summit)	RPCL	105	105	0	27096	Reserve.	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18*56	104	53	619200	Low demand	
38	Manikganj 162MW PP(MFGL)	IPP	9*18	162	72	1720800	Engine problem	
<b>Dhaka area Total</b>				<b>6057</b>	<b>1830</b>	<b>36298176</b>		
39	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage.	
40	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage	
41	Raazan 25 MW PP	IPP	3*9.9	25	0	138189		
41	Teknaf 20MW PP SolarTech/Teknaf Solar	Energy	20	20	0	121099		
42	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	603360		
43	Kapta Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	46	1055127	Unit-2 under maint	
44	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.	
45	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Gas shortage	
46	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	0	0	Reserve.	
47	Hathazari 100 MW peaking PP	PDB	11*9.9	99	0	0	Under maint.	
48	Dohazari-Kalash 100 MW Peaki	PDB	6*17	102	102	654638		
49	Judadh 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	0	0	Reserve.	
50	Judadh 100 MW PP Unit-3 (Acom)	IPP	0	100	100	465600		
51	Baratkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	17	396384	Engine problem	
*	Malancha, Ctg. EPZ (Uniled)	IPP	5*8.73+3*9.34	0	40	932640		
52	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	31680	Reserve.	
53	Kapta 7 MW Solar PP	PDB	7.4	7.4	7	28199		
54	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	124	3899127	Low demand	
55	Jodac Power	IPP	3*18.55+1*3.6	54	54	1299404		
56	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.	
57	Judadh unit-2 (Acom)	IPP	8*13.6	100	100	1830720		
58	Anilma Energy Ltd.	IPP	6*21.2	0	0	0	on test	
<b>Chattogram area Total</b>				<b>2266</b>	<b>633</b>	<b>11454123</b>		
58	Ashuganj TPP Unit-3	APSCCL	1*150	135	0	0	Gas shortage	
59	Ashuganj TPP Unit-4	APSCCL	1*150	129	0	0	Gas shortage	
59	Ashuganj TPP Unit-5	APSCCL	1*150	134	0	0	Gas shortage	
60	Ashuganj 225 MW CCPP	APSCCL	1*142+1*75	221	185	4102000	FGMO	
61	Ashuganj 450 MW CCPP(North)	APSCCL	1*360	360	325	7759000		
61	Ashuganj 450 MW CCPP(South)	APSCCL	1*360	360	330	7336000		
62	Ashuganj 50 MW PP	APSCCL	14*3.968	45	26	281880	Gas shortage	
63	Ashuganj 55 MW PP (Precision)	IPP	15*4	55	53	390360	Gas shortage	
64	Ashuganj 195MW PP (APSCCL-Ur)	IPP	20*9.73+1*16	195	8	217454	Gas shortage	
65	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1238720		
66	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	149	2301672		
67	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	Reserve.	
68	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	91	1975980		
69	Chandpur 205MW (Desh energy)	IPP	200	200	68	1498980	High Voltage.	
70	Feni 220MW (Doreen)	SIPP, PDB	8*2.90	22	19	414576	Engine problem	
71	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	224460	Engine problem	
**	Import (Tirupura)	Imported power	0	160	98	1882560		
72	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	820300		
73	Jangalia 52 MW PP (Lakdnavi)	IPP	6*8.92	52	0	13613	Reserve.	
74	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*8.67+2*6.97	25	21	490700	Engine problem	
75	Daudkandi 20 MW PP (B. Trac)	IPP	15*1.4	200	0	0	Reserve.	
76	Feni Lanka Power	IPP	7*18.415+1*9.76	114	0	0	Reserve.	
77	Chowmahani 113 MW	IPP	12*9.78+2*3.1	113	26	367920	Low demand	
<b>Cumilla Area Total</b>				<b>2980</b>	<b>1491</b>	<b>31324375</b>		
78	RPCL 210MW CCPP	IPP	4*35+1*70	202	161	3687080	Gas shortage	
79	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	502884		
80	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	40	135360	Low demand	
81	Sarishabari 3 MW Solar Plant	IPP	3	3	0	9260		
82	Mymensingh 200 MW PP (Uniled)	IPP	200	200	182	2200800	High Voltage.	
83	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	0	39600	#REF!	
84	Sultakhalhi 50 MW Solar PP	IPP	50	50	0	224520		
85	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	24	169680		
<b>Mymensingh Area Total</b>				<b>709</b>	<b>429</b>	<b>6969124</b>		
86	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	0	0	Gas shortage & GT-2 under r	
87	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	0	0	GT-4 under maint.	
88	Koshiara 163 MW CCPP (KP)	IPP	1*109+1*54	163	0	0	Line Out	
89	Shahbazar 330 MW CCPP	PDB	3*110	330	0	0	Gas shortage	
90	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	53	447600		
91	Fenchugonj 44MW (Energyprima)	RPP	12*3.3+5*2	44	44	564120		
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	153000		
93	Shahbazar GTTP Unit- 8 & 9	PDB	2*35	66	40	1324224	Low demand	
94	Shahbazar 330 MW PP (Shahbazar)	RPP	3*27.0	86	75	1560160	Engine problem	
95	Shahbazar 100 MW GTTP	PDB	1*100	0	100	920000	On test.	
95	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	164	4101000		
96	Sylhet 20 MW GTTP	PDB	1*20	20	18	437000		
97	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	Contract Expired	
98	Shahajahanulla 25 MW PP	SIPP, REB	3*8.34	25	8	261120	Engine problem	
99	Barisal 34 MW CCPP (Summit)	IPP	1*222+1*119	341	300	7368300	Gas shortage	
100	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	0	0	Gas shortage & Bibiyana sou	
101	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	204120		
102	Bibiyana South 400 MW	PDB	400 MW	0	130	4293600	On test.	
<b>Sylhet Area Total</b>				<b>1888</b>	<b>952</b>	<b>21672244</b>		
102	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.	
**	Bheramara (HWC J)	Imported power	2*500	1000	707	11680000		
103	Khulna 115 MW PP (WCL-2)	PDB	7*17	115	115	2375940		
104	Fairdipur 50 MW Peaking PP	PDB	8*6.89	54	4	30240	Low demand	
105	Khulna 225 MW CCPP	NWPGL	1*150+1*75	230	0	0	Reserve.	
106	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.	
107	Bheramara 410 MW CCPP	NWPGL	1*278+1*132	410	260	6006816	Gas shortage	
108	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	0	0	Reserve.	
109	Noapara 105 MW PP (Bengla Tra)	IPP	70*1.4	100	0	0	Reserve.	
110	Rupsha 105 MW PP (Orion rupsh	IPP	8*18.445	105	35	490560	Low demand	
111	Madrhumati 100 MW PP	SWPGL	100 MW	105	0	0	Reserve.	
<b>Khulna Area Total</b>				<b>2284</b>	<b>1121</b>	<b>20582656</b>		
112	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	High Voltage.	
113	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	26	495600	Engine problem	
114	Bhola 225 MW CCPP	PDB	2*63+1*68	194	0	0	Under maint.	
115	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	60	1068196		
116	Payra 1320 MW	BCRL	2*622	1244	420	10415700	High Voltage.	
	Bhola Nulam Bidut BD LTD	IPP	220	0	55	683100	On test.	
	Uniled Payra Power Ltd.	IPP	8*18.5+1*9.5	0	55	897600	On test.	
<b>Barisal Area Total</b>				<b>1676</b>	<b>616</b>	<b>13590196</b>		
117	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage.	
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.	
118	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	Reserve.	
119	Bara 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.	
120	Amnura 50 MW PP(Sinha)	QRPP	7*7.70	50	0	0	Reserve.	
121	Katakhalhi 50 MW PP (Northern)							