

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2021				Day : Monday				Date : 01.03.21			
Probable Maximum Demand :		10800 MW		Yesterday = 91.67 ft		Today = 91.43 ft		Probable Maximum Generation : 14240 MW		Rule Curve = 93.00 ft.	
Water Level of Kaptai Lake at 06:00 AM											
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.02.21 (Yesterday)		01.03.21 (Today)		28.02.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Machines shut down (MW)		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Probable start-up date	
(A) Plants in operation:											
1	a) Ghorassal Repowered CAPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.
	b) Ghorassal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	c) Ghorassal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
2	Ghorassal 365 MW CAPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	300	300	300	300		
3	Ghorassal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	12	12	12	12		
4	Ghorassal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235-1x125	360	360	0	0	0	0	360	Under maint. 7/3/2021
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140-1x170	450	450	420	400	450	450	50	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273-1x139	412	412	372	352	412	412		
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217-1x118	335	335	0	0	0	0	335	Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100		
14	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110-1x110	305	305	235	220	300	300		
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	20	92	100	100		
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	48	98	100	100		
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08-1x11.3	55	55	40	40	55	55		
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	85	73	100	100		
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	30	102	100	102		
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIIPP, REB)	8x2.90	22	22	22	22	22	22		
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIIPP, REB)	6x3.67-7x8.73	80	80	55	44	58	58		
22	Maona 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	33	31	35	35		
23	Rupganj 33 MW PP(Summit)	Gas (SIIPP, REB)	4x8.73	33	33	33	33	23	23		
24	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	12	52	52		
25	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	45	105	105		
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	82	150	149	149		
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	12	50	50		
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	247	300	300	300		
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149		
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	0	0	100	300		
32	Bramhargan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85-91x.959	100	100	0	0	50	100		
33	Aurabahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85-91x.959	100	100	0	0	100	100		
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	48	35	55	55		
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	55	55		
36	Boslia 108MW PP(CLC)	HFO (IPP)	12x8.775-1x3.5	108	108	0	0	0	0		
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	101	104	104		
38	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	108	144	144		
	Spectra Solar Plant Ltd.	Solar (IPP)				32	0	30	0		
Dhaka Zone Total				6171	5972	2736	3100	3844	4066	385	1160
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
42	Raazan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	46	46		
45	Sikalbaha 105 MW PP (Baraka Sik)	HFO (IPP)	6x18.415	105	105	0	0	50	100		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	120	100	100	30	Gas Shortage
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150-1 x 75	225	225	0	0	0	0	225	Gas Shortage
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	306	306	300	300		
49	Juldah 100 MW Unit-1 (Accorn)	HFO (ORPP)	8x13.45	100	100	0	50	100	100		
50	Juldah 100 MW Unit-3 (Accorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	85	85		
52	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIIPP, PDB)	8x2.90	22	22	16	16	22	22		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	17	12	25		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	34	102	102		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	41	35	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
57	Juldah unit-2 (Accorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
58	Chattogram 116 MW PP (Anima Er)	HFO (IPP)	6x21.06	116	116	0	17	116	116		
Chattogram Zone Total				2442	2382	706	1025	1417	1455	595	180
59	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	10	10	10	10	35	Gas Shortage
61	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	203	213	225	225		
62	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	240	240	300	300		
63	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	285	285	300	300		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas shortage
65	Ashuganj 185MW PP (APSCCL United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	8	8	195	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	33	0	50		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	137	125	125	125		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	108	155	200	200		
71	Feni 22MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	21	21	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIIPP, REB)	4x2.90	11	11	11	8	11	11		
73	Jangala 33MW PP (Summit)	Gas (SIIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jangala 52 MW PP (Lakdhanavi)	HFO (IPP)	6x8.92	52	52	0	13	52	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIIPP, REB)	3x3.67-2x6.97	25	25	20	20	20	20		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14-4x8.175+1x8.046	200	200	0	0	0	200		
77	Feni 114 MW Power Plant(Lakdhanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	71	113	113		
**	Impoport (Tripura)	India		160	160	120	142	135	147		
	Bhairab 54.5 MW	HFO (IPP)				0	0	0	0		
Cumilla Zone Total				3040	2980	1193	1374	1673	1935	879	0
79	RPCL 210MW CAPP	Gas (IPP)	4x35-1x70	210	202	85	102	125	125		
80	Tangail 22 MW PP (Doreen)	Gas (SIIPP, PDB)	8x2.90	22	22	17	17	22	22		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	32	40	80	80		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	94	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	193	200	200	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0		
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	23	24	22	22		
Mymensingh Zone Total				717	709	512	477	616	564	0	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.02.21 (Yesterday)		01.03.21 (Today)		28.02.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0			
88	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43			
89	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	48	53	51	51			
90	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0		Contract Expired on 14/02/2021	
91	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
93	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	34	31	20	20	35	Under maint.	
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+2x110	330	330	162	161	162	162	169	Gas Shortage	
95	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	81	78	81			
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	163	162	163	163	69	Under maint.	
97	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20			
98	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0		Contract Expired on 04/01/2020	
99	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	5	5	10	10			
100	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16			
101	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	310	341	341			
102	Bibiana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	352	352	350	350			
		Bibiyana South 400 MW	Gas (PDB)				180	180	300	300			
		Shahjibazar 100 MW GTTP	Gas (PDB)				0	0	0	0		On Test	
Sylhet Zone Total						2033	1988	1582	1586	1728	1731	169	104
103	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16			
104	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	285	190	230	230	220	Gas Shortage	
105	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	4	25	25			
106	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	12	60	60			
107	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220			
108	Khulna	115 PP MW (KPL-2)	HFO (QRPP)	7x17	115	115	19	83	115	115			
109	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100			
110	Noapara	40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	40	40	40			
111	Rupsha	105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105			
112	Machumati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			
**	Bheramara (HVDC)	India		1000	1000		612	632	712	712			
Khulna Zone Total						2288	2284	1021	1066	1437	1723	220	0
113	Barsal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	64	110	110			
114	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	28	26	26			
115	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194	Under maint.	
116	Bhola	95 MW PP (Agreko)	Gas (QRPP)	1.1x96	95	95	55	45	95	95			
117	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	430	470	620	620			
118	Potukhali	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150			
Bhola Nutan Biddut BD LTD						Gas/HSD	89	47	51	51	0	194	
Barishal Zone Total						1826	1826	595	654	1052	1052	0	194
119	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	50			
121	Baghabari	200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
122	Bera	70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	6	0	40			
123	Ammura	50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	12	12	12			
124	Chapainawabganj	100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	104	104			
125	Katakali	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	50	50			
126	Katakali	50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	24	50	50			
127	Santahar	50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	20	0	34			
128	Sirajgonj	225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		Gas Shortage	
129	Sirajgonj	225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage	
130	Sirajgonj	225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	160	140	200	200			
131	Sirajgonj	400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	410	380	400	400			
132	Bogra	22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22			
133	Bogra	20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0		Contract Expired on 12/11/2020	
134	Ullapara	11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
135	Natore	52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	43	52	52			
136	Bagura	113 MW PP (Confidence) Unit-1	HFO (IPP)	6'x18.55	113	113	113	113	113	113			
137	Bagura	113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113			
Rajshahi Zone Total						2193	2183	870	1071	1327	1451	601	0
138	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
139	Barapukuria	275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150			
140	Rangpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0	20	Under Overhauling	
141	Rangpur	113 MW PP (Confidence)	HFO (IPP)	7'x16x 2'x3	113	113	107	100	113	113			
142	Saidpur	20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
143	Majpara	Tatulia 8 MW Solar PP (Sympha Pt)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
Rangpur Zone Total						685	605	262	250	271	263	170	20
Sub-total: Plants in operation						21395	20929	9477.0	10603	13365	14240	3019	1658
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss								9213	10308	12993	13844		
(B) Contract expired power plants													
Sub-Total: Plants under long term maintenance						0	0	0	0	0	0		
Gross Total						21395	20929	9477	10603	13365	14240	3019	1658
(C) Actual data of 28.02.21 (Yesterday) Sunday :													
01.	Max. Demand (Generation end)	:	10603.00 MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand (Sub-station end)	:	10308.00 MW, at = 19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	10603.00 MW, at = 19:00 hrs		Dhaka	3865	3865	0	Mymensingh	881	881	0	
04.	Minimum Generation (Generation end)	:	7236.00 MW, at = 5:00 hrs		Chattogram	901	901	0	Sylhet	365	365	0	
05.	Day-peak Generation (Generation end)	:	9477.00 MW, at = 12:00 hrs		Khulna	1303	1303	0	Barishal	279	279	0	
06.	Evening-peak Generation (Generation end)	:	10603.00 MW, at = 19:00 hrs		Rajshahi	1088	1088	0	Rangpur	675	675	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0.00 MW, at = 19:00 hrs		Cumilla	951	951	0					
08.	Actual Minimum Generation up to 8:00 hrs.	:	7475.00 MW, at = 7:00 hrs						Total	10308	10308	0	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :				(c) Coal =	72120498	Taka	
	a) Gas limitation	:	2689 MW			(a) Gas =	12502588 Taka			Total =	60964462	Taka	
	d) Coal supply Limitation	:	170 MW			(b) Oil =	412498376 Taka						
	b) Low water level in Kaptai lake	:	160 MW		14.	Maximum Temperature in Dhaka was : 33.6° C							
	c) Plants under shut down/ maintenance	:	1658 MW		15.	Export through East-West interconnections :							
10.	Total Energy (Generation + India Import)	:	214.82 MCKWh			At evening peak-hour : -372 MW, at 19:00 hrs							
	By Gas = 120.911 MCKWh		58.157 MCKWh			Maximum : -372 MW, at 19:00 hrs							
	By Coal = 15.568 MCKWh		1.676 MCKWh			Energy : 1.4635 MCKWh							
	By Solar= 0.691 MCKWh												
11.	Total Gas Supplied	:	930.67 MCMCFD										
(D) Forecast of 01.03.21 (Today) Monday :													
01.	Maximum Demand	:	10800 MW (Generation end)	04.	Maximum Load-shed			:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14240 MW (Generation end)	05.	Total Generation			:	218.81 MCKWh				
03.	Maximum Shortage	:	-3440 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :			:	34.0° C				

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation