

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity		Peak Hour	Energy Generated	Remarks
				MW	MW			
				Unit No. X Capacity				
	Ghorasal Repowered CCPP Unit-3	PDB	1*210	170	0	0	0	Under maint.
	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	0	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	190	4561200		
2	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	300	6797300		Gas shortage
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	78	0	0		Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	3*43.35	108	106	2021909		
5	Harihar GTPP	SBU, QCB	2*32	20	0	0	0	Under maint.
6	Harihar 412 MW CCPP	EGCB	1*273+1*139	412	0	0	0	Dirty fuel(Gas)
7	Harihar 360MW CCPP(HPL)	IPP	1*235+1*125	360	332	7638000		Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	0	0	0	Dirty fuel(Gas)
9	Meghnaghat 100 MW(LEL)	QRPP	12*8.9	100	50	131520		Low demand
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	240	5621033		Gas shortage
11	Madangan 102 PP(Summit)	QRPP	6*17	100	48	225384		Engine problem
12	Madangan-35 MW PP(Summit)	IPP	3*11.08+1*11.3	55	55	441524		
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	72	518022		Engine problem
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	491292		
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	112	2951000		Gas shortage
17	Siddhirgonj 100 PPI(Dutch Bangla)	QRPP	12*8.9	100	90	220800		Engine problem
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*118	335	221	4940402		Engine problem
19	Gagragar 102 MW PP (Digital Po)	IPP	12*8.924	102	50	145008		Low demand
20	Kalpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	25584		Reserve.
21	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	54	1139040		
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	10	65280		Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	148273		
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	100920		Engine problem
25	Bostia 108MW RP(CLO)	IPP	12*9.775+1*9.5	108	0	0	0	Fuel shortage
26	Summit Power (Madhabadi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	55	1235540		Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	627400		Engine problem
28	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	789400		
29	Gazipur 52 MW PP	IPP	6*8.9	52	0	5592		Reserve.
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	270	2248144		Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	0	Reserve.
33	Bramhangaoan 100 MW PP (Aggr)	IPP	100	100	0	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	131	2908800		Engine problem
36	Gazipur 100 MW PP	RPCL	100	105	105	932652		
37	Meghnaghat 104 MW PP (QPCL)	IPP	18*5.8	104	90	335680		Engine problem
38	Manikganj 162MW PP(MPGL)	IPP	9*18	162	17	120960		Low demand
39	Spectra Solar Plant Ltd.	IPP	35	0	0	225579		
Dhaka area Total				5972	2768	47818238		
39	Chattogram TPP-1	PDB	1*210	180	120	2800000		Gas shortage.
40	Chattogram TPP-2	PDB	1*210	180	0	0	0	Gas shortage
41	Raozan 25 MW PP	IPP	3*8.9	25	8	20579		Low demand
42	Teknaf 20MW PP (SolarTech)Teknaf Solar Park	IPP	20	20	0	115695		
43	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	8016000		
44	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	1680000		Unit-2 under maint
45	Sikalbaha 225MW	PDB	1*150+1*175	225	203	4872138		
46	Sikalbaha Peaking GT	PDB	1*150	150	120	2905722		
47	Sikalbaha 105 MW PP (Baraka Si)	IPP	105 MW	105	0	0	0	Reserve.
48	Hatibazar 100 MW Peaking PP	PDB	11*9.9	98	0	0	0	Under maint.
49	Dohazari-Kalesh 100 MW Peaking	PDB	6*17	102	36	374737		
50	Judah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	40	128360		High Voltage.
51	Judah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	640320		
52	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	21	485520		
53	* Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	13	505920		
54	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	42	154560		Low demand
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	28090		
56	Anwara 300 MW PP (United)	IPP	300 MW	300	198	3131345		High Voltage.
57	Jodac Power	IPP	3*18.55+1*3.6	54	34	180408		Low demand
58	Karnaphuli Power Ltd.	IPP	110	110	0	0	0	Reserve.
59	Judah unit-2 (Acom)	IPP	8*13.6	100	100	1819200		
60	Anilma Energy Ltd.	IPP	6*21.2	116	0	0	0	Reserve.
Chattogram area Total				2382	1153	20645104		
61	Ashugani TPP Unit-3	APSCL	1*150	135	0	0	0	Gas shortage
62	Ashugani TPP Unit-4	APSCL	1*150	128	0	0	0	Gas shortage
63	Ashugani TPP Unit-5	APSCL	1*150	134	120	2895202		
64	Ashugani 225 MW CCPP	APSCL	1*142+1*175	221	182	4524000		FGMO
65	Ashugani 450 MW CCPP(North)	APSCL	1*360	360	275	7158500		FGMO
66	Ashugani 450 MW CCPP(South)	APSCL	1*360	360	285	6917000		FGMO
67	Ashugani 50 MW PP	APSCL	14*3.968	45	23	523440		Gas shortage
68	Ashugani 55 MW PP (Phalson)	IPP	15*4	55	52	864000		
69	Ashugani 193MW PP (APSCL-UR)	IPP	20*9.73+1*116	193	0	0	0	Gas shortage
70	Ashugani 51 MW PP (Midland)	IPP	6*9.34	51	0	0	0	Line fault
71	Ashugani 150MW PP (Midland)	IPP	23*7.015	150	0	0	0	Line fault
72	Tilas 50 MW Peaking PP	PDB	6*8.92	52	0	0	0	Reserve.
73	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	85	1990220		Machine problem
74	Chandpur 20MW (Desh energy)	IPP	0	200	147	1525920		
75	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	469444		
76	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	217080		
77	** Impport (Tripura)	Imported power	0	160	146	3002880		
78	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	449600		
79	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	0	25992		Reserve.
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	359390		Reserve.
81	Daudkhani 200 MW PP (B. Trac)	IPP	15*14.14	200	0	0	0	Reserve.
82	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	0	Reserve.
83	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	40	183960		Low demand
84	Bhairab 54.5 MW	IPP	3*18.2	0	0	0	0	On Test
Cumilla Area Total				2980	1420	31098128		
85	RPCL 210MW CCPP	IPP	4*35+1*70	202	108	2955120		Gas shortage
86	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	449568		
87	Jamalpur 55 MW PP(Powerpac)	IPP	12*8.924	95	61	852480		Engine problem
88	Sanshabari 3 MW Solar Plant	IPP	3	3	0	15459		
89	Mymensingh 200 MW PP (United)	IPP	200	200	200	3564000		High Voltage.
90	Jamalpur 115 MW PP (United)	IPP	115 MW	115	65	327600		#REF!
91	Suliakhali 50 MW Solar PP	IPP	50	50	0	337380		
92	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	474000		
Mymensingh Area Total				709	498	8975598		
93	Fenchuganj CCPP Phase-1	PDB	2*32+1*33	70	43	1029000		Machine problem
94	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	42	983520		Machine problem
95	Kushara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3334581		
96	Shajibazar 330 MW CCPP	PDB	3*110	330	294	5812000		
97	Fenchuganj 51 MW PP (Barakati)	RPP	19*2.90	51	53	665400		
98	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	44	0	0	0	Contract Expired
99	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	264000		
100	Shajibazar GTPP Unit-3 & 8	PDB	2*35	66	35	833184		GT-9 Under maint.
101	Shajibazar 86MW PP (Shajibazar)	RPP	32*2.90	86	75	1166400		Engine problem
102	Shajibazar 100 MW GTPP	PDB	1*100	0	0	0	0	Under Shut down
103	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	148	3571510		
104	Sylhet 20 MW GTPP	PDB	1*20	20	18	422000		
105	Sylhet 50MW PP (EPL)	RPP	27*2	50	0	0	0	Contract Expired
106	Shahjahanua 25 MW PP	SIPP, REB	3*5.34	25	0	227536		Engine problem
107	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	310	7335600		FGMO
108	Bibiana-III 400 MW CCPP	PDB	400 MW	400	331	8504000		
109	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	0	96480		Engine problem
110	Bibiana South 400 MW	PDB	400 MW	383	283	6761300		On Test
Sylhet Area Total				2371	1806	41010411		
111	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	0	Reserve.
112	Bheramara (HWDC)	Imported power	2*500	1000	720	17407272		
113	Khulna 115 PP MW (KPCL-2)	QRPP	115	115	49	158400		Low demand
114	Fairpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	0	Reserve.
115	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	0	Reserve.
116	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	12	25600		Low demand
117	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	370	9024192		FGMO
118	Nopara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	40	74625		
119	Nopara 100 MW PP (Bangla Tr)	IPP	70*1.4	100	0	0	0	Reserve.
120	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	95	987840		Engine problem
121	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	0	Reserve.
Khulna Area Total				2284	1286	27677929		
122	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	64	205824		High Voltage.
123	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	24	509600		Engine problem
124	Bhola 225 MW CCPP	PDB	2*63+					