

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 15-Mar-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation		Energy Generated	Remarks
					MW	MW		
1	Ghorasal Repowered CAPP Unit-3	PDB	1'210	170	0	0	Under maint.	
2	Ghorasal Repowered CAPP Unit-4	PDB	1'210	180	0	0	Under maint.	
3	Ghorasal TPP Unit-5	PDB	1'210	190	190	4473000		
4	Ghorasal 365 MW CAPP Unit-7	PDB	1'243+1'122	365	309	7309209	Gas shortage	
5	Ghorasal 78.5 MW PPT(MAX)	QRPP	2'40	78	0	0	Contract Expired	
6	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	106	2004136		
7	Haripur GTPP	SBU, PDB	2'32	20	0	0	Under maint.	
8	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	0	0	Dirty fuel(Gas)	
9	Haripur 360MW CAPP(HPL)	IPP	1'235+1'125	360	353	7688000		
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2'150+1'150	450	0	0	Dirty fuel(Gas)	
11	Meghnaghat 100 MW (IEL)	QRPP	1'278.9	100	50	89120	Low demand	
12	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	305	220	5473164	Gas shortage	
13	Madangan 102 PP(Summit)	QRPP	6'17	100	100	437256		
14	Madangan-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	55	628799		
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	100	72	962576	Engine problem	
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	330984		
17	210 MW Siddhirgonj	PDB	1'210	115	0	0	Under maint.	
18	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	115	2957000	Gas shortage	
19	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12'8.9	100	100	396480		
20	Siddhirgonj 335 MW CAPP	EGCB	1'217+118	335	224	5304639	ST Under maint.	
21	Gaganagar 102 MW PP (Digital Power)	IPP	12'8.924	102	40	103392	Low demand	
22	Kalgotli 52 MW PP (Sinha)	IPP	7'7.9	51	18	38736	Low demand	
23	Kamatnagar 54 MW PP(Banco Energy)	IPP	3'18	54	54	1087200		
24	Kodda 150MW PP	BPOB-RPCL	9'17.06	149	64	150240	Low demand	
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	513656		
26	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	135370		
27	Bosila 108MW PP(PLC)	IPP	12'8.775+1'3.5	108	0	0	Fuel shortage	
28	Summit Power (Madhabad+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	54	1275540	Engine problem	
29	Maena 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	530300	Engine problem	
30	Rungta 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	801900		
31	Gazipur 52 MW PP	IPP	6'8.9	52	0	0	Reserve.	
32	Tongi 80 MW GTTP	PDB	1'105	105	0	0	Under maint.	
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	287	1824108		
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	0	Reserve.	
35	Bramanganj 100 MW PP (Aggreko)	IPP	0	100	0	0	Reserve.	
36	Auraha 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Reserve.	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	146	3153600		
38	Gazipur 100 MW PP	RPCL	100 MW	105	70	638484	Low demand	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	90	594240	Engine problem	
40	Manikganj 162MW PP(MPGL)	IPP	9'18	162	17	781920	Low demand	
41	Spectra Solar Plant Ltd.	IPP	35	0	0	215634		
Dhaka Area Total				5972	2915	4987663		
42	Chatto gram TPP-1	PDB	1'210	180	120	2900000	Gas shortage.	
43	Chatto gram TPP-2	PDB	1'210	180	0	0	Gas shortage.	
44	Raozan 25 MW PP	IPP	3'8.9	25	25	117711		
45	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	141210		
46	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	47	507360		
47	Kapali Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	70	1676000	Unit-2 under maint	
48	Sikalbaha 225MW	APCL	1'150+1'175	225	203	4825109	FGMO	
49	Sikalbaha Peaking GT	PDB	1'150	150	120	2892769		
50	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	0	0	Reserve.	
51	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	0	Under maint.	
52	Dohazari-Kalaish 100 MW Peaking	PDB	6'17	102	85	238954		
53	Julladah 100 MW Unit-1 (Acoron)	QRPP	8'13.45	100	40	97440	Low demand	
54	Julladah 100 MW PP Unit-2 (Acoron)	IPP	0	100	100	924480		
55	Barakkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	21	495360		
56	Malancha, Ctg. EPZ (Unlied)	IPP	5'8.73+3'9.34	0	10	435360		
57	Chatto gram 108 MW PP (ECPV)	IPP	16'7	108	51	134400	Low demand	
58	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	34836		
59	Anwara 300 MW PP (Unlied)	IPP	300 MW	300	196	2983309	Transformer O/L	
60	Jodac Power	IPP	3'18.55+1'3.6	54	0	0	Reserve.	
61	Karnaphuli Power Ltd.	IPP	110	110	0	5016	Reserve.	
62	Julladah Unit-2 (Acoron)	IPP	8'13.6	100	100	2297280		
63	Anilma Energy Ltd.	IPP	6'21.2	116	0	0	Reserve.	
Chatto gram Area Total				2382	1188	20706596		
64	Ashuganj TPP Unit- 3	APSCCL	1'150	135	0	0	Gas shortage	
65	Ashuganj TPP Unit- 4	APSCCL	1'150	129	0	286955	Gas shortage	
66	Ashuganj TPP Unit- 5	APSCCL	1'150	134	120	2885184		
67	Ashuganj 225 MW CAPP	APSCCL	1'142+1'175	221	182	4519000	FGMO	
68	Ashuganj 450 MW CAPP(North)	APSCCL	1'1360	360	285	7392000	FGMO	
69	Ashuganj 450 MW CAPP(South)	APSCCL	1'1360	360	290	6892000	FGMO	
70	Ashuganj 50 MW PP	APSCCL	14'3.968	45	26	516168	Gas shortage	
71	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	25	573600	Gas shortage	
72	Ashuganj 195MW PP (APSCCL-Unlied)	IPP	20'9.73+1'16	195	0	0	Gas shortage	
73	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	0	0	Line fault	
74	Ashuganj 50 MW PP (Midland)	IPP	2'37.015	50	0	0	Line fault	
75	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	0	Reserve.	
76	Chandpur 150 MW CAPP	PDB	1'106+1'157	163	45	1796830	Machine problem & Gas shortage	
77	Chandpur 200MW (Desh energy)	IPP	0	200	200	2268960		
78	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	507600		
79	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	11	198180		
80	Imported power (TTPP)	Imported power	0	158	160	3229440		
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	798900		
82	Jangalia 52 MW PP (Lakdanavi)	IPP	6'8.92	52	8	18821	Low demand	
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	20	343650		
84	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	0	Reserve.	
85	Feni Lanka Power	IPP	7'18.415+1'9.78	114	0	0	Reserve.	
86	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	113	362040		
87	Bishidi 51.5 MW	IPP	3'18.2	0	0	0	On Test	
Cumilla Area Total				2980	1538	32587228		
88	RPCL 210MW CAPP	IPP	4'35+1'70	202	124	2813640	Gas shortage	
89	Tangali 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	435664		
90	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	82	962880	Engine problem	
91	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	14550		
92	Mymensingh 200 MW PP (Unlied)	IPP	200	200	200	3998400	Engine problem	
93	Jamalpur 115 MW PP (Unlied)	IPP	115 MW	115	103	759400	#REF!	
94	Sutakhalai 50 MW Solar PP	IPP	50	50	0	518120		
95	Tangali Pali Power Gen 22 MW	IPP	4'6.7	22	24	304800		
Mymensingh Area Total				709	553	9704354		
96	Fenchugonj CAPP Phase-1	PDB	2'32+1'33	70	43	1025000	Machine problem	
97	Fenchugonj CAPP Phase-2	PDB	2'35+1'35	90	42	993840	Machine problem	
98	Kushiana 163 MW CAPP (KP)	IPP	1'109+1'54	163	163	3272481		
99	Shahjibazar 330 MW CAPP	PDB	3'110	330	297	6786000		
100	Fenchugonj 51 MW PP (Barakalullah)	RPP	19'2.90	51	53	970200		
101	Fenchugonj 44MW (Energyprima)	RPP	12'3.3+5'2	44	0	0	Contract Expired	
102	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	208096		
103	Shahjibazar GTTP Unit- 8 & 9	PDB	2'35	66	35	738816	GT-9 Under maint.	
104	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	78	1210560	Engine problem	
105	Shahjibazar 100 MW GTTP	PDB	1'100	0	0	0	Under Shut down	
106	Sylhet 225 MW CAPP	PDB	1'142+1'189	231	148	3565320		
107	Sylhet 20 MW GTTP	PDB	1'20	20	18	424000		
108	Sylhet 50MW PP (EPL)	RPP	2'7.2	50	0	0	Contract Expired	
109	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	329791	Engine problem	
110	Bibiana-II 341 MW CAPP (Summit)	IPP	1'222+1'119	341	285	7435000	FGMO	
111	Bibiyana-III 400 MW CAPP	PDB	400 MW	400	367	8296000		
112	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	7	113940	Engine problem	
113	Bibiyana South 400 MW	PDB	400 MW	383	290	6962400	On Test	
Sylhet Area Total				2377	1853	42331444		
114	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Reserve.	
115	Bheramara (HVDC)	Imported power	2'500	1000	713	17405091		
116	Khulna 115 PP MW (KPCL-2)	QRPP	7'17	115	99	702720	Engine problem	
117	Fariapur 50 MW Peaking PP	PDB	6'8.89	54	0	0	Reserve.	
118	Khulna 225 MW CAPP	NWPGCL	1'150+1'175	230	0	0	Reserve.	
119	Gotalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Reserve.	
120	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	330	8322336		
121	Noapara 40 MW PP (Khanjanhan Ali)	QRPP	5'8.5	40	40	79500		
122	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	60	57600	Low demand	
123	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	95	884640	Engine problem	
124	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.	
Khulna Area Total				2284	1537	27451887		
125	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	48	330816	High Voltage.	
126	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	25	454300	Engine problem	
127	Bhola 225 MW CAPP	PDB	2'63+1'68	194	0	0	Under maint.	
128	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	95	53	1114547	Machine problem	
129	Payra 1320 MW	BCPCL	2'622	1244	550	11598600		
130	Bhola Nufan Biddut BD LTD	IPP	220	0	90	2105127	On Test	
131	United Payra Power Ltd.	IPP	8'18.5+1'9.5	150	0	0	Reserve.	
Barisal Area Total				1626	786	15603390		
132	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage	
133	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage.	
134	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	43	0		
135	Bera 70 MW Peaking PP	PDB	9					