

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | Peak Hour | | Energy Generated | Remarks |
|------------------------------|-----------------------------------|-------------------------|--------------------|---------------------|-------------|-------------|------------------|--------------------|
| | | | | | Generation | Hour | | |
| | | | | Unit No. X Capacity | MW | MW | MW | |
| | Ghorasal Repowered CCPP Unit-4 | PDB | 1*210 | 170 | 0 | 0 | 0 | Under maint. |
| | Ghorasal Repowered CCPP Unit-5 | PDB | 1*210 | 190 | 0 | 0 | 0 | Under maint. |
| | Ghorasal TPP Unit-6 | PDB | 1*210 | 190 | 190 | 190 | 4567500 | Gas shortage |
| 2 | Ghorasal 365 MW CCPP Unit-7 | PDB | 1*243+1*122 | 365 | 300 | 300 | 7078818 | Contract Expired |
| 3 | Ghorasal 78.5 MW PP(MAX) | QRPP | 2*40 | 78 | 0 | 0 | 0 | Contract Expired |
| 4 | Ghorasal 108MW PP (Regent) | IPP | 3*3.35 | 108 | 106 | 106 | 2229954 | |
| 5 | Harijpur GTPP | SBU, PDB | 2*32 | 20 | 0 | 0 | 0 | Under maint. |
| 6 | Harijpur 412 MW CCPP | IPP | 1*273+1*139 | 412 | 0 | 0 | 0 | Dirty fuel(Gas) |
| 7 | Harijpur 360MW CCPP(HPL) | IPP | 1*235+1*125 | 360 | 348 | 348 | 7524000 | |
| 8 | Meghnaghat 450 MW CCPP(MPL) | IPP | 2*150+1*150 | 450 | 0 | 0 | 0 | Dirty fuel(Gas) |
| 9 | Meghnaghat 100 MW(EL) | QRPP | 12*8.9 | 100 | 17 | 17 | 51840 | Low demand |
| 10 | Meghnaghat CCPP(Summit) | IPP | 2*110+1*110 | 305 | 220 | 220 | 5174749 | FGMO |
| 11 | Madanganj 102 PPI(Summit) | QRPP | 6*17 | 100 | 100 | 100 | 463176 | |
| 12 | Madanganj-25 MW PPI(Summit) | (IPP) | 3*17.08+1*11.3 | 55 | 55 | 55 | 750087 | |
| 13 | Karaniganj 120 MW PP (Powerpac) | QRPP | 8*13.45 | 100 | 100 | 100 | 841528 | |
| 14 | Narsinghat 22 MW PP (Doreen) | SIPP, REB | 8*2.90 | 22 | 22 | 22 | 474156 | |
| 15 | 210 MW Siddhirgonj TPP | PDB | 1*210 | 115 | 0 | 0 | 0 | Under maint. |
| 16 | Siddhirgonj 2*120 MW GTPP | EGCB | 2*105 | 210 | 178 | 178 | 3342000 | FGMO |
| 17 | Siddhirgonj 100 PPI(Dutch Bangla) | QRPP | 12*8.9 | 100 | 100 | 100 | 442560 | |
| 18 | Siddhirgonj 335 MW CCPP | EGCB | 1*217+1*118 | 335 | 198 | 198 | 4929529 | ST Under maint. |
| 19 | Gagnagar 102 MW PP (Digital Po) | IPP | 12*8.924 | 102 | 64 | 64 | 351504 | Low demand |
| 20 | Katpali 52 MW PP (Sinha) | IPP | 7*7.9 | 51 | 12 | 12 | 32544 | Low demand |
| 21 | Kamalaghat 54 MW PP(Banco ER) | IPP | 3*18 | 54 | 54 | 54 | 1124640 | |
| 22 | Kodda 150MW PP | BPDB-RPCL | 9*17.06 | 149 | 48 | 48 | 234240 | Low demand |
| 23 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 55 | 55 | 604229 | |
| 24 | Nabaganj 55 MW PP (Southern) | IPP | 3*19.3 | 55 | 17 | 17 | 183395 | Low demand |
| 25 | Bosilla 108MW PPI(OLC) | IPP | 12*9.75+1*3.5 | 108 | 0 | 0 | 0 | Fuel shortage |
| 26 | Summit Power (Madhatra-Ashuli) | SIPP, REB | 3*3.67+4*8.73 | 80 | 55 | 55 | 1246920 | Engine problem |
| 27 | Maona 33 MW PPI(Summit) | SIPP, REB | 4*8.73 | 33 | 25 | 25 | 602200 | Engine problem |
| 28 | Ruganaj 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 25 | 25 | 781200 | |
| 29 | Gazipur 52 MW PP | IPP | 6*8.9 | 52 | 0 | 0 | 529992 | Reserve. |
| 30 | Tongi 80 MW GTPP | PDB | 1*105 | 105 | 0 | 0 | 0 | Under maint. |
| 31 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 18*17.076 | 300 | 300 | 300 | 3015926 | |
| 32 | Keraniganj 300 MW PP (APR) | IPP | 26*11.4 | 300 | 0 | 0 | 0 | Reserve. |
| 33 | Bramhangsan 100 MW PP (Aggr) | IPP | 100 | 100 | 0 | 0 | 0 | Reserve. |
| 34 | Aurahati 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 100 | 0 | 0 | 0 | Reserve. |
| 35 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 149 | 149 | 149 | 149 | 1743840 | |
| 36 | Gazipur 100 MW PP | RPCL | 100 MW | 105 | 90 | 90 | 1368912 | Engine problem |
| 37 | Meghnaghat 104 MW PP (OPCL) | IPP | 18*5.6 | 104 | 90 | 90 | 803520 | Engine problem |
| 38 | Manikganj 162MW PPI(MPL) | IPP | 9*18 | 162 | 35 | 35 | 260640 | Low demand |
| | Spectra Solar Plant Ltd. | IPP | 35 | 0 | 0 | 0 | 109985 | |
| Dhaka area Total | | | | 5972 | 2853 | 2853 | 50953594 | |
| 39 | Chattogram TPP-1 | PDB | 1*210 | 180 | 120 | 120 | 2900000 | Gas shortage. |
| | Chattogram TPP-2 | PDB | 1*210 | 180 | 0 | 0 | 0 | Gas shortage |
| 40 | Raazan 25 MW PP | IPP | 3*8.9 | 25 | 25 | 25 | 160794 | |
| 41 | Teknaf 20MW PP (Solartech) | Teknaf Solartech Energy | 20 | 20 | 0 | 0 | 135405 | |
| 42 | Palenga 50MW PP (Baraka) | IPP | 8*6.98 | 50 | 50 | 50 | 761280 | |
| 43 | Kaptai Hydro Unit-2,3,4, 5 | PDB | 2*40+3*50 | 230 | 70 | 70 | 1684000 | Unit-2 under maint |
| 44 | Sikalbaha 225MW | PDB | 1*150+1*175 | 225 | 202 | 202 | 4891677 | |
| 45 | Sikalbaha Peaking GT | PDB | 1*150 | 150 | 120 | 120 | 2888092 | |
| 46 | Sikalbaha 105 MW PP (Baraka Si) | IPP | 105 MW | 105 | 0 | 0 | 0 | Reserve. |
| 47 | Hathazari 100 MW peaking PP | PDB | 11*8.9 | 98 | 0 | 0 | 0 | Under maint. |
| 48 | Ashuganj-Kalan 100 MW Peaking | PDB | 6*13.45 | 102 | 102 | 102 | 429240 | |
| 49 | Juidah 100 MW Unit-1 (Acorn) | QRPP | 8*13.45 | 100 | 0 | 0 | 0 | Reserve. |
| 50 | Juidah 100 MW PP Unit-3 (Acorn) | IPP | 0 | 100 | 100 | 100 | 1306560 | |
| 51 | Baratkunda 22 MW PP (Regent) | SIPP, PDB | 8*2.90 | 22 | 20 | 20 | 456048 | |
| * | Malancha, Ctg, EPZ (Uniled) | | 5*8.73+3*9.34 | 0 | 17 | 17 | 475680 | |
| 52 | Chattogram 108 MW PP (ECPV) | IPP | 16*7 | 108 | 18 | 18 | 132480 | Low demand |
| 53 | Kaptai 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 0 | 29727 | |
| 54 | Anwara 300 MW PP (Uniled) | IPP | 300 MW | 300 | 179 | 179 | 3229200 | Transformer O/L |
| 55 | Jodiak Power | IPP | 3*16.5+1*3.6 | 54 | 0 | 0 | 0 | Reserve. |
| 56 | Karnaphuli Power Ltd. | IPP | 110 | 110 | 0 | 0 | 0 | Reserve. |
| 57 | Juidah unit-2 (Acorn) | IPP | 8*13.6 | 100 | 100 | 100 | 1810560 | |
| | Anlima Energy Ltd. | IPP | 6*21.2 | 116 | 0 | 0 | 0 | Reserve. |
| Chattogram area Total | | | | 2382 | 1123 | 1123 | 21290743 | |
| 58 | Ashuganj TPP Unit-3 | APSCL | 1*150 | 135 | 0 | 0 | 0 | Gas shortage |
| | Ashuganj TPP Unit-4 | APSCL | 1*150 | 129 | 140 | 140 | 2899235 | Gas shortage |
| | Ashuganj TPP Unit-5 | APSCL | 1*150 | 134 | 120 | 120 | 285220 | |
| 59 | Ashuganj 225 MW CCPP | APSCL | 1*142+1*75 | 221 | 182 | 182 | 4527000 | FGMO |
| 60 | Ashuganj 450 MW CCPP(North) | APSCL | 1*360 | 360 | 310 | 310 | 7724000 | FGMO |
| 61 | Ashuganj 450 MW CCPP(South) | APSCL | 1*360 | 360 | 295 | 295 | 7296000 | FGMO |
| 62 | Ashuganj 50 MW PP | APSCL | 14*3.968 | 45 | 23 | 23 | 572544 | Gas shortage |
| 63 | Ashuganj 55 MW PP (Precision) | RPP | 19*4 | 55 | 56 | 56 | 1331520 | Gas shortage |
| 64 | Ashuganj 195MW PP (APSCL-UH) | IPP | 20*9+13*11.6 | 195 | 0 | 0 | 0 | Gas shortage |
| 65 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 0 | 0 | 0 | Reserve. |
| 66 | Ashuganj 150MW PP (Midland) | IPP | 23*7.015 | 150 | 0 | 0 | 0 | Line fault |
| 67 | Titas 50 MW Peaking PP | PDB | 6*8.92 | 52 | 0 | 0 | 0 | Reserve. |
| 68 | Chandpur 150 MW CCPP | PDB | 1*106+1*57 | 163 | 0 | 0 | 201040 | Under maint. |
| 69 | Chandpur 200MW (Desh energy) | IPP | 0 | 200 | 200 | 200 | 3204000 | |
| 70 | Feni 22MW PP (Green) | SIPP, PDB | 8*2.90 | 22 | 21 | 21 | 478116 | |
| 71 | Feni 11 MW PP (Doreen) | SIPP, REB | 4*2.90 | 11 | 11 | 11 | 224460 | |
| ** | Import (Tripura) | Imported power | 0 | 160 | 134 | 134 | 3030720 | |
| 72 | Jangalia 33MW PP (Summit) | SIPP, PDB | 4*8.73 | 33 | 33 | 33 | 818000 | |
| 73 | Jangalia 52 MW PP (Lakdanav) | IPP | 6*8.92 | 52 | 8 | 8 | 32722 | Low demand |
| 74 | Camilla 25 MW PP (Summit) | SIPP, PDB | 3*3.67+2*6.97 | 25 | 20 | 20 | 413070 | |
| 75 | Daudkandi 200 MW PP (B. Trac) | IPP | 15*11.4 | 200 | 0 | 0 | 0 | Reserve. |
| 76 | Feni Lanka Power | IPP | 7*18.415+1*9.78 | 114 | 0 | 0 | 0 | Reserve. |
| 77 | Chowmuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 55 | 55 | 515760 | Low demand |
| | Bhairab 54.5 MW | IPP | 3*18.2 | 0 | 0 | 0 | 0 | On Test |
| Cumilla Area Total | | | | 2880 | 1608 | 1608 | 36173407 | |
| 78 | RPCL 210MW CCPP | IPP | 4*35+1*70 | 202 | 125 | 125 | 2934280 | Gas shortage |
| 79 | Tangail 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 17 | 17 | 390492 | |
| 80 | Jamapur 95 MW PP(Powerpac) | IPP | 12*8.924 | 95 | 81 | 81 | 838080 | Engine problem |
| 81 | Sarihashani 3 MW Solar Plant | IPP | 3 | 0 | 3 | 3 | 14500 | |
| 82 | Mymensingh 200 MW PP (Uniled) | IPP | 200 | 200 | 200 | 200 | 4125600 | |
| 83 | Jamapur 115 MW PP (Uniled) | IPP | 115 MW | 115 | 115 | 115 | 1522800 | #REF! |
| 84 | Sultakhal 50 MW Solar PP | IPP | 50 | 50 | 0 | 0 | 306910 | |
| 85 | Tangail Palli Power Gen 22 MW | IPP | 4*6.7 | 22 | 24 | 24 | 338640 | |
| Mymensingh Area Total | | | | 709 | 562 | 562 | 10471302 | |
| 86 | Fenchugonj CCPP Phase-1 | PDB | 2*32+1*33 | 70 | 44 | 44 | 1022000 | Machine problem |
| 87 | Fenchugonj CCPP Phase-2 | PDB | 2*35+1*35 | 90 | 42 | 42 | 960000 | Machine problem |
| 88 | Kushiana 163 MW CCPP (KP) | IPP | 1*109+1*54 | 163 | 163 | 163 | 3354990 | |
| 89 | Shajibazar 330 MW CCPP | IPP | 3*110 | 330 | 300 | 300 | 6817000 | |
| 90 | Fenchugonj 51 MW PP (Barakati) | RPP | 19*2.90 | 51 | 53 | 53 | 1021800 | |
| 91 | Fenchugonj 44MW (Energyprima) | RPP | 12*3.3+5*2 | 44 | 0 | 0 | 0 | Contract Expired |
| 92 | Hobiganj 11MW PP Confidence-E | SIPP, REB | 4*2.90 | 11 | 11 | 11 | 264000 | |
| 93 | Shajibazar GTPP Unit-8 & 9 | PDB | 2*35 | 66 | 35 | 35 | 765996 | GT-9 Under maint. |
| 94 | Shajibazar 86MW CCPP | RPP | 32*2.60 | 86 | 81 | 81 | 1510880 | Engine problem |
| | Shajibazar 100 MW GTPP | PDB | 1*100 | 0 | 0 | 0 | 0 | Under Shut down |
| 95 | Sylhet 225 MW CCPP | PDB | 1*142+1*89 | 231 | 148 | 148 | 3569830 | |
| 96 | Sylhet 20 MW GTPP | PDB | 1*20 | 20 | 18 | 18 | 418000 | |
| 97 | Sylhet 50MW PP (EPL) | RPP | 27*2 | 50 | 0 | 0 | 0 | Contract Expired |
| 98 | Shahjahanulla 25 MW PP | SIPP, REB | 3*9.34 | 25 | 16 | 16 | 386422 | Engine problem |
| 99 | Bibiana-II 341 MW CCPP (Summit) | IPP | 1*222+1*119 | 341 | 290 | 290 | 7429960 | FGMO |
| 100 | Bibiana-I 400 MW CCPP | IPP | 400 MW | 400 | 367 | 367 | 8844000 | |
| 101 | Sylhet 10MW PP (Desh) | RPP | 6*1.95 | 10 | 7 | 7 | 156420 | Engine problem |
| | Bibiana South 400 MW | PDB | 400 MW | 383 | 290 | 290 | 7307400 | On Test |
| Sylhet Area Total | | | | 2371 | 1865 | 1865 | 43886328 | |
| 102 | Bheramara GTPP Unit-3 | PDB | 1*20 | 16 | 0 | 0 | 0 | Reserve. |
| ** | Bheramara (HVDC) | Imported power | 2*500 | 1000 | 711 | 711 | 17158545 | |
| 103 | Khulna 115 MW (KPCL-2) | QRPP | 7*17 | 115 | 99 | 99 | 514080 | Engine problem |
| 104 | Fardpur 50 MW Peaking PP | PDB | 8*6.89 | 54 | 4 | 4 | 26350 | Low demand |
| 105 | Khulna 225 MW CCPP | NWPGCL | 1*150+1*75 | 230 | 0 | 0 | 0 | Reserve. |
| 106 | Gopalganj 100 MW Peaking PP | PDB | 16*6.98 | 109 | 0 | 0 | 4480 | Reserve. |
| 107 | Bheramara 410 MW CCPP | NWPGCL | 1*278+1*132 | 410 | 260 | 260 | 7129728 | Gas shortage |
| 108 | Noapara 40 MW PP (Khanjahan A) | QRPP | 5*8.5 | 40 | 40 | 40 | 134625 | |
| 109 | Noapara 100 MW PP (Bangla Tra) | IPP | 70*1.4 | 100 | 30 | 30 | 97990 | Low demand |
| 110 | Rupsha 105 MW PP (Orion rupsh) | IPP | 6*18.445 | 105 | 85 | 85 | 132360 | Engine problem |
| 111 | Madhumati 100 MW PP | SWPGCL | 100 MW | 105 | 0 | 0 | 0 | Reserve. |
| Khulna Area Total | | | | 2284 | 1239 | 1239 | 26468328 | |
| 112 | Barisal 110 MW PP (Summit) | IPP | 7*17.076 | 110 | 110 | 110 | 514272 | |
| 113 | Bhola 33 MW PP (Venture) | RPP | 1*34.50 | 33 | 26 | 26 | 457100 | Engine problem |
| 114 | Bhola 225 MW CCPP | PDB | 2*63+1*68 | 194 | 0 | 0 | 0 | Under maint. |
| 115 | Bhola 95 MW PP (Aggreko) | QRPP | 96*1.10 | 95 | 64 | 64 | 1853349 | Gas shortage |
| 116 | Payra 130 MW | BCPCL | 2*62.2 | 134 | 570 | 570 | 12881200 | |
| | Bhola Nuiam Bidut BD LTD | IPP | 220 | 0 | 16 | 16 | 683655 | On Test |
| | Uniled Payra Power Ltd. | IPP | 6*18.5+1*9.5 | 150 | 0 | 0 | 0 | Reserve. |
| Barisal Area Total | | | | 1826 | 786 | 786 | 16199576 | |
| 117 | Baghabari 71 MW GTPP | PDB | 1*71 | 71 | 0 | 0 | 0 | Gas shortage |
| | Baghabari 100 MW GTPP | PDB | 1*100 | 100 | 0 | 0 | 0 | Gas shortage. |
| 118 | Baghabari 50 MW Peaking PP | PDB | 6*8.9 | 52 | 43 | 43 | 73822 | |
| 119 | Bera 70 MW Peaking PP | PDB | 9*8.29 | 71 | 7 | 7 | 20552 | Reserve. |
| 120 | Amnura 50 MW PP(Sinha) | QRPP | 7*7.9 | 50 | 42 | 42 | 186330 | |
| 121 | Katakhal 50 MW PP (Northern) | QRPP | 6*8.9 | 50 | 0 | 0 | 12729 | Reserve. |
| 122 | Katakhal 50 MW Peaking PP | PDB | 6*8.7 | 50 | 12 | 12 | 32545 | Low demand |
| 123 | Sirajgonj Unit-1 225MW | NWPGCL | 1*150+1*75 | 210 | 0 | 0 | 0 | Gas shortage |
| 124 | Sirajgonj Unit-2 225MW | NWPGCL | 1*150+1*75 | | | | | |