

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2021		Day : Tuesday				Date : 23.03.21					
Probable Maximum Demand :		12800 MW		Yesterday = 87.53 ft		Today = 87.41 ft		Probable Maximum Generation : 15203 MW		Rule Curve = 89.48 ft.	
Water Level of Kaptai Lake at 06:00 AM											
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.03.21 (Yesterday)		23.03.21 (Today)		22.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	a) Ghorasal Repowered CAPP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under maint.
	b) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190		
2	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	130	300	0	0		
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	92	100	108	108		
4	Ghorasal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	78	0	0	0	0		Contract Expired on 08/01/2021
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	146	161	200	200		
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	90	300	300	360	Dirt in fuel gas
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	355	340	412	412		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	181	175	180	180		
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100		
14	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	305	305	265	270	265	270		
15	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	100	92	100	100	100		
16	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	100	97	97	100	100		
17	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
18	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	81	74	85	85		
19	Gagnagar 102 MW PP (Digital Pow)	HFO (IPP)	12x8.924	102	102	84	102	100	100		
20	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22		
21	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x167+7x8.73	80	80	47	52	58	58		
22	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33		
23	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
24	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	52	52		
25	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	90	105	105		
26	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	98	150	149	149		
27	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	29	49	50	50		
28	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
29	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	255	287	300	300		
30	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	129	146	149	149		
31	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	248	100	300		
32	Bramhargan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	25	50	100		
33	Aurabahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	97	100	100		
34	Nababganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	55	35	55	55		
35	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
36	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
37	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104		
38	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	120	144	144	144		
	Spectra Solar Plant Ltd.	Solar				29	0	30	0		
Dhaka Zone Total			6171	5972	3064	3829	3838	4063	380	800	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	40	40	190	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	105	105	105		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0		
42	Raazari 25 MW PP	HFO (RPCL)	3x8.9	25	25	22	25	25	25		
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	44	45	50	50		
45	Sikalbaha 105 MW PP (Baraka Sika)	HFO (IPP)	6x18.415	105	105	0	0	50	100		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	204	225	225		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	125	196	300	300		
49	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	50	100	100	100		
50	Juldah 100 MW Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
51	Dohazari Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	102	102		
52	Halihazari 22 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	20	20		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	15	10	15		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	14	91	102	102		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
57	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
58	Chattogram 116 MW PP (Anima Er)	HFO (IPP)	6x21.06	116	116	0	0	116	116		
Chattogram Zone Total			2442	2382	861	1127	1634	1664	190	330	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	135	80	135	135		
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	140	80	140	140		
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	20	20	26	26	25	Gas Shortage
61	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	197	184	225	225		
62	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	325	295	350	350		
63	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	340	325	350	350		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	54	47	55	55		
65	Ashuganj 185MW PP (APSCL United)	Gas (IPP)	20*9.73+1*16	195	195	63	55	63	63	140	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0	150	Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	42	0	50		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	134	152	200	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	10	11	11		
73	Jangala 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jangala 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	52	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	15	20	20		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+4x1.575+1x1.026	200	200	0	50	0	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	114	114	114		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	73	113	113	113		
**	Impoport (Tripura)	India		160	160	146	174	151	168		
	Bhairor 54.5 MW	HFO (IPP)				0	37	0	0		
Cumilla Zone Total			3040	2980	1710	1888	2060	2327	500	163	
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	100	105	160	160	97	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	22	22		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	24	41	81	81		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	109	115	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	183	194	200	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0		
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	24	25	22	22		
Mymensingh Zone Total			717	709	505	497	652	600	97	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.03.21 (Yesterday)		23.03.21 (Today)		22.03.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj	CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	43	44	44				
88	Fenchugonj	CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42				
89	Fenchugonj	51 MW PP (Barakatuli)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
90	Fenchugonj	44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	44	0	0	0	0			Contract Expired on 14/02/2021	
91	Kushiana	163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobiganj	11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar	GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	34	0	0	32		GT-9 Under maint.	
94	Shahjibazar	330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	180	182	180	180				
95	Shahjibazar	86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	79	78	81	81				
96	Sylhet	225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0	231		Under maint.	
97	Sylhet	20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	17	20	20				
98	Sylhet	50MW PP (EPL)	Gas (RPP)	27x2.0	50	50	0	0	0	0			Contract Expired on 04/01/2020	
99	Sylhet	10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	9	10	10				
100	Shahjahanulla	25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
101	Bibiana-II	341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	285	341	341				
102	Bibiyana-III	400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	248	222	250	250				
103	Bibiyana South	383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	370	340	400	400				
	Shahjibazar	100 MW GTTP	Gas (PDB)				0	0	0	0			On Test	
Sylhet Zone Total						2416	2371	1559	1495	1609	1609	0	263	
104	Bheramara	GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
105	Bheramara	410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	275	280	350	350				
106	Faridpur	50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	25				
107	Gopalganj	100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	14	60	60				
108	Khulna	225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna	115 PP MW (KPL-2)	HFO (QRPP)	7x17	115	115	93	66	99	99				
110	Noapara	100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	96	50	100				
111	Noapara	40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	8	33	40	40				
112	Rupsha	105 MW PP (Onion rupsha)	HFO (IPP)	6x18.445	105	105	94	94	90	95				
113	Madhupati	100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000		719	718	725	725				
Khulna Zone Total						2288	2284	1189	1301	1539	1830	0	0	
114	Barsal	110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	64	110	110				
115	Bhola	33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	26	31	25	25				
116	Bhola	225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	66	68	70	70	126		GT-2 Under maint.	
117	Bhola	95 MW PP (Agreko)	Gas (QRPP)	1.1x96	95	95	91	100	95	95				
118	Payra	1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	450	530	620	620				
119	Potukhali	150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
	Bhola Nutan	Biddut BD LTD	Gas/HSD				3	25	90	90				
Barishal Zone Total						1826	1826	636	818	1160	1160	0	126	
120	a)	Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b)	Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
121		Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	17	50	0	50				
122		Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	200	200				
123		Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	32	0	40				
124		Ammura 50 MW PP (Sirha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42				
125		Chapanawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	100	100				
126		Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	50	50				
127		Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	50	50				
128		Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	34				
129		Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
130		Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	162	153	200	200				
131		Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	191	173	200	200				
132		Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	396	400	400				
133		Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
134		Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	10	0	0	0	0			Contract Expired on 12/11/2020	
135		Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
136		Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
137		Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	113	113	113	113				
138		Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	94	95	113				
Rajshahi Zone Total						2193	2183	1069	1347	1535	1677	381	0	
139	a)	Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b)	Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140		Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150				
141		Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	10	10				
142		Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2x3	113	113	113	113	113	113				
143		Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144		Majpara, Tatulia 8 MW Solar PP (Sympa Pt)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total						685	605	269	263	281	273	170	0	
Sub-total: Plants in operation						21778	21312	10862.0	12565	14308	15203	1718	1682	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss								10260	11869	13515	14361			
(B) Contract expired power plants														
Sub-Total: Plants under long term maintenance						0	0	0	0	0	0			
Gross Total						21778	21312	10862	12565	14308	15203	1718	1682	
(C) Actual data of 22.03.21 (Yesterday) Monday :														
01.	Max. Demand (Generation end)			: 12565.00 MW, at = 19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand (Sub-station end)			: 11869.00 MW, at = 19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)			: 12565.00 MW, at = 19:30 hrs	Dhaka	4250	4250	0	Mymensingh	989	989	0		
04.	Minimum Generation (Generation end)			: 9207.00 MW, at = 6:00 hrs	Chattogram	1263	1263	0	Sylhet	455	455	0		
05.	Day-peak Generation (Generation end)			: 10862.00 MW, at = 12:00 hrs	Khulna	1438	1438	0	Barishal	323	323	0		
06.	Evening-peak Generation (Generation end)			: 12565.00 MW, at = 19:30 hrs	Rajshahi	1260	1260	0	Rangpur	778	778	0		
07.	Evening Peak Load-shed (Sub-station end)			: 0.00 MW, at = 19:30 hrs	Cumilla	1113	1113	0						
08.	Actual Minimum Generation Forecast up to 8:00			: 9127.00 MW, at = 5:00 hrs	Total 11869 11869 0									
09.	Generation shortfall at evening peak due to :				13. Fuel cost : (a) Gas = 154273254 Taka (c) Coal = 75998624 Taka (b) Oil = 548765785 Taka Total = 779037663 Taka									
	a) Gas limitation			: 1358 MW	14. Maximum Temperature in Dhaka was : 36.8° C									
	d) Coal supply Limitation			: 170 MW	15. Export through East-West interconnections :									
	b) Low water level in Kaptai lake			: 190 MW	At evening peak-hour : -122 MW, at 19:30 hrs									
	c) Plants under shut down/ maintenance			: 1682 MW	Maximum : -132 MW, at 20:00 hrs									
10.	Total Energy (Generation + India Import)			: 255.71 MCKWh	Energy : 0.9985 MCKWh									
	By Gas = 143.266 MCKWh			By Oil = 73.358 MCKWh										
	By Coal = 16.451 MCKWh			By Hydro = 0.960 MCKWh										
	By Solar = 0.708 MCKWh													
11.	Total Gas Supplied			: 1182.50 MCMCFD										
(D) Forecast of 23.03.21 (Today) Tuesday :														
01.	Maximum Demand			: 12800 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation			: 15203 MW (Generation end)	05. Total Generation : 260.49 MCKWh									
03.	Maximum Shortage			: -2403 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 38.9° C									

* Captive Power ** Imported Power

#Remarks: Highest Generation 12893MW on 29-05-2019 at 21:00

(Fazul Islam Shaker)
Deputy Secretary, Generation