

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month April, 2021			Day : Saturday						Date : 10.04.21		
Probable Maximum Demand : 12800 MW			Probable Maximum Generation : 15072 MW								
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 82.58 ft			Today = 82.10 ft			Rule Curve = 86.20 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.04.21 (Yesterday)		10.04.21 (Today)		09.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	a) Ghorasal Repowered CCGP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering
	b) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.
2	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x254+1x126	365	365	300	300	300	300		
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	103	104	104		
4	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
5	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
6	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	338	345	350	360	15	Gas Shortage
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	320	320	400	400	130	Gas Shortage
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
9	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Dirt in gas
10	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	180	155	180	180	55	Gas Shortage
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	214	223	0	0	112	ST under maint.
12	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	100	100	100		
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	270	270	0	0	35	dirt in gas
14	Meghnaghat 100 MW(TEL)	HFO (QRPP)	12x8.9	100	100	0	75	100	100		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	40	55	55		
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
17	Gagnagar 102 MW PP (Digital Powe)	HFO (IPP)	12x8.924	102	102	0	72	100	100		
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22		
19	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	47	51	58	58		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33		
21	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	52	105	105		
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	133	149	149		
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	195	300	300		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	149	149	149		
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300		
30	Bramhangoan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
31	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
32	Nabaganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	0	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	104	104	104		
36	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	108	162	162		
37	Manikgonj 35MW Solar PP (Inspectr)	Solar (IPP)	1x35	35	35	31	0	30	0		
<b>Dhaka Zone Total</b>				<b>6026</b>	<b>5829</b>	<b>1914</b>	<b>3031</b>	<b>3392</b>	<b>3622</b>	<b>667</b>	<b>872</b>
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	72	72	70	70	158	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50		
44	Sikalbaha 105 MW PP (Baraka Sika)	HFO (IPP)	6x18.415	105	105	0	0	50	100		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	130	130		
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	204	203	225	225		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	16	300	300		
48	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	0	100	100	100		
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	83	82	85		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22		
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			12	20	15	20		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	100	100		
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	35	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100		
57	Chattogram 116 MW PP (Anlima En)	HFO (IPP)	6x21.06	116	116	53	60	60	60		
<b>Chattogram Zone Total</b>				<b>2442</b>	<b>2382</b>	<b>766</b>	<b>1014</b>	<b>1618</b>	<b>1651</b>	<b>158</b>	<b>360</b>
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	100	100	80	80	35	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	206	215	225	225		
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	310	295	300	300		
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	315	270	360	360		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	30	30	50	50		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	STG Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	150	196	200	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	20	17	17		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.056	200	200	0	0	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	113	113	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	36	36		
**	Impoport (Tripura)	India		160	160	110	156	136	168		
<b>Cumilla Zone Total</b>				<b>3094</b>	<b>3034</b>	<b>1332</b>	<b>1547</b>	<b>1883</b>	<b>2065</b>	<b>536</b>	<b>163</b>
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	133	147	160	160	55	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	24	32	49	49		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	105	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	16	183	200	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0		
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0		
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	24	22	22		
<b>Mymensingh Zone Total</b>				<b>717</b>	<b>709</b>	<b>243</b>	<b>508</b>	<b>615</b>	<b>563</b>	<b>55</b>	<b>0</b>

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.04.21 (Yesterday)		10.04.21 (Today)		09.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	35	43	44	44		27	GT-1 Load gear problem		
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	Under maint.		
89	Fenchugonj 51 MW PP (Barakatulla)	Gas (RPP)	19x2.90	51	51	11	50	51	51					
90	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	163	163					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	11	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	33	33	33		33	Under maint.		
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	309	334	330	330					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	78	75	78					
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	120	100	120					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	20	20					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	9	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	235	295	341	341					
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	366	342	400	400					
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	360	340	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0					
<b>Sylhet Zone Total</b>				<b>2422</b>	<b>2377</b>	<b>1603</b>	<b>1842</b>	<b>2037</b>	<b>2060</b>	<b>0</b>	<b>107</b>			
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16					
104	Bheramara 410 MW CAPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	400	295	400	400	115		Gas Shortage		
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20					
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60					
107	Khulna 225 MW CAPP	HSD (NWPGCL)	1 x 150+1x75	230	230	0	0	0	220					
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	49	90	99	99					
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100					
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	33	32	32					
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	92	105	105					
112	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	643	832	654	848					
<b>Khulna Zone Total</b>				<b>2288</b>	<b>2284</b>	<b>1092</b>	<b>1442</b>	<b>1520</b>	<b>2000</b>	<b>115</b>	<b>0</b>			
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	96	110	110					
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	22	33	25	26					
115	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	64	67	70	70		127	GT-2 & STG Under maint.		
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	39	96	95	95					
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	420	570	622	622					
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150					
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				73	0	0	0					
<b>Barishal Zone Total</b>				<b>1826</b>	<b>1826</b>	<b>618</b>	<b>862</b>	<b>1072</b>	<b>1073</b>	<b>0</b>	<b>127</b>			
119	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	65	65	71		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50					
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	40					
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0					
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	99	100	100					
125	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	40					
126	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	34					
128	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	0	0	144	144	210		Gas Shortage		
129	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGCL)	1x150 + 1x75	220	220	175	199	180	200					
130	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	187	163	200	200					
131	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	376	364	400	400					
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22					
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	52	52					
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113					
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	54	94	94	94					
<b>Rajshahi Zone Total</b>				<b>2173</b>	<b>2173</b>	<b>856</b>	<b>1141</b>	<b>1711</b>	<b>1765</b>	<b>381</b>	<b>0</b>			
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage		
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	10	10					
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	50	113	113	113					
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	5	0	0					
142	Majpara, Tatulia 8 MW Solar PP (Sympha Po.)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
<b>Rangpur Zone Total</b>				<b>685</b>	<b>605</b>	<b>205</b>	<b>268</b>	<b>281</b>	<b>273</b>	<b>294</b>	<b>0</b>			
<b>Sub-total: Plants in operation</b>				<b>21673</b>	<b>21219</b>	<b>8629.0</b>	<b>11655</b>	<b>14129</b>	<b>15072</b>	<b>2206</b>	<b>1629</b>			
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>						<b>8180</b>	<b>11048</b>	<b>13393</b>	<b>14287</b>					
<b>(B) Plants under long term maintenance/ contract expired</b>														
143	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021		
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
145	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021		
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020		
147	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
Sub-Total: Plants under long term maintenance/ contract expired				294	0	0	0	0	0					
<b>Gross Total</b>				<b>21967</b>	<b>21219</b>	<b>8629</b>	<b>11655</b>	<b>14129</b>	<b>15072</b>	<b>2206</b>	<b>1629</b>			
<b>(C) Actual data of 09.04.21 (Yesterday) Friday :</b>														
01.	Max. Demand at eve. peak (Generation end)	:	11655.00	MW,	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11048.00	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11655.00	MW,	at =	21:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	7301.00	MW,	at =	7:00 hrs	Dhaka	3717	3717	0	Mymensingh	878	878	0
05.	Day-peak Generation (Generation end)	:	8629.00	MW,	at =	12:00 hrs	Chattogram	1148	1148	0	Sylhet	445	445	0
06.	Evening-peak Generation (Generation end)	:	11655.00	MW,	at =	21:00 hrs	Khulna	1505	1505	0	Barishal	347	347	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Rajshahi	1087	1087	0	Rangpur	716	716	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8974.00	MW,	at =	5:00 hrs	Cumilla	1205	1205	0				
09.	Generation shortfall at evening peak due to :	:									<b>Total</b>	<b>11048</b>	<b>11048</b>	<b>0</b>
	a) Gas limitation	:	1754	MW			13.	Fuel cost :	(a) Gas = 146638207	Taka	(c) Coal = 73045941	Taka		
	d) Coal supply Limitation	:	294	MW					(b) Oil = 296079282	Taka	Total = 515763430	Taka		
	b) Low water level in Kaptai lake	:	158	MW										
	c) Plants under shut down/ maintenance	:	1629	MW										
10.	Total Energy (Generation + India Import)	:	222.28	MKWh			14.	Maximum Temperature in Dhaka was :		34.7° C				
	By Gas = 139.604	MKWh					15.	Export through East-West interconnections :						
	By Coal = 15.775	MKWh						At evening peak-hour		-128	MW,	at	21:00 hrs	
	By Solar= 0.618	MKWh						Maximum		-312	MW,	at	19:00 hrs	
11.	Total Gas Supplied	:	1112.71	MMCFD				Energy		0.8965	MKWh			
<b>(D) Forecast of 10.04.21 (Today) Saturday :</b>														
01.	Maximum Demand	:	12800	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15072	MW	(Generation end)		05.	Total Generation	:	244.12	MKWh			
03.	Maximum Shortage	:	-2272	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :		36.4° C				

\* Captive Power \*\* Imported Power

#Remarks: Highest Generation 13018MW on 03-04-2021 at 21:00

(Faouzul Islam Shaker)  
Deputy Secretary, Generation