

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 12-Apr-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	Hour	MW	
	Ghorasal Repowered CAPP Unit	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CAPP Unit	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
2	Ghorasal 365 MW CAPP Unit-7	PDB	1*243+1*122	365	300	7229836	Machine problem
3	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	343.35	108	104	2330318	
5	Haripur GTRP	SBU_PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	0	0	Under S/D due to dust in the
7	Haripur 360MW CAPP(HPL)	IPP	1*235+1*125	360	240	6450000	Gas shortage
8	Meghnaghat 450 MW CAPP(MP)	IPP	2*150+1*150	450	250	6620850	Gas shortage
9	Meghnaghat 100 MW(EL)	QRPP	12*8.9	100	100	1676160	Gas shortage
10	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	270	2912553	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	1267118	
13	Keraniganj 100 MW PP (Powerpa)	QRPP	8*13.45	100	72	754893	Engine problem
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	368280	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	180	2392000	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	100	1943040	
18	Siddhirganj 335 MW CAPP	EGCB	1*217+1*118	335	217	3978584	ST under maint.
19	Gagnagar 102 MW PP (Digital P)	IPP	12*8.924	102	102	1817856	
20	Katpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
21	Kamatnagar 54 MW PP(Banco E)	IPP	3*18	54	54	1312200	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	1669440	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1233979	
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1152726	
25	Bosila 108MW PP(CLC)	IPP	12*8.75+1*3.5	108	0	0	Engine problem
26	Summit Power SIPP(Asadi-Ashul)	SIPP,REB	3*9.67+4*8.73	90	45	1217400	Engine problem
27	Maona 33 MW PP(Summit)	SIPP,REB	4*8.73	33	33	743500	
28	Ruganaj 33 MW PP(Summit)	SIPP,REB	4*8.73	33	25	624000	Engine problem
29	Gazipur 52 MW PP	IPP	6*8.9	52	51	591360	
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summ)	IPP	18*17.06	300	265	4062217	Engine problem
32	Keraniganj 300 MW PP (AFR)	IPP	25*11.4	300	156	374150	Low demand
33	Bramhangonj 100 MW PP (Agg)	IPP	100	100	100	323254	
34	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	104	485236	
35	Kodda 149 MW PP Unit-1 (Summ)	IPP	149	149	149	3595680	
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	1500000	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*5	104	104	2507520	
38	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	3304080	
	Spectra Solar Plant Ltd.	IPP	35	35	0	202925	
Dhaka area Total				5829	3625	64731195	
39	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage.
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
40	Razzan 25 MW PP	IPP	3*8.9	25	25	548418	
41	Teknaf 20MW PP (SolarTech)Knaif SolarTech Energ	IPP	20	20	0	126630	
42	Patenga 50MW PP (Baraka)	IPP	6*8.98	50	50	1084320	
43	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	35	1597978	Unit-2 under maint
44	Sikalbaha 225MW	PDB	1*150+1*175	225	152	3569124	FGMO
45	Sikalbaha Peaking GT	PDB	1*150	150	130	2943918	
46	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	0	0	Reserve.
47	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	
48	Dohazari-Kalaish 100 MW Peak	PDB	6*17	102	83	801479	Engine problem
49	Juldah 100 MW Unit-1 (Accor)	QRPP	8*13.45	100	100	1950360	Engine problem
50	Juldah 100 MW PP Unit-3 (Accor)	SIPP, PDB	0	100	100	2407680	
51	Barakunda 22 MW PP (Regent + Malancha, Ctg. E22 (United)	SIPP, PDB	8*2.90	22	20	466896	
52	Chattogram 108 MW PP (ECPV)	IPP	6*17	108	94	889920	Engine problem
53	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	31920	
54	Anwara 300 MW PP (United)	IPP	300 MW	300	160	1876800	Transformer OIL
55	Jodiac Power	IPP	3*18.55+1*3.6	54	54	1257439	
56	Karnaphuli Power Ltd.	IPP	110	110	0	48509	Reserve.
57	Juldah unit-2 (Accor)	IPP	8*13.6	100	100	2389440	
	Anlima Energy Ltd.	IPP	6*21.2	116	58	1377491	Engine problem
Chattogram area Total				2382	1185	23811362	
58	Ashuganj TPP Unit- 3	APSCL	1*150	135	135	3193178	
	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Gas shortage
59	Ashuganj 225 MW CAPP	APSCL	1*144+2*75	221	212	4876000	
60	Ashuganj 450 MW CAPP(North)	APSCL	1*360	360	310	7535500	FGMO
61	Ashuganj 450 MW CAPP(South)	APSCL	1*360	360	295	7117000	FGMO
62	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	582480	Engine problem
63	Ashuganj 55 MW PP (Precision)	RPP	154	55	47	1154880	
64	Ashuganj 155MW PP (APCL-U)	IPP	20*9.34+11.6	155	0	217454	Gas shortage
65	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	0	Line fault
66	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	0	Line fault
67	Titas 50 MW Peaking PP	PDB	6*8.92	52	50	247096	
68	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	0	476420	
69	Chandpur 200MW (Desh energy)	IPP	0	200	172	4149600	Engine problem
70	Feni 22MW PP (Doreen)	SIPP, PDB	8*12.60	22	22	491544	
71	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	5	172260	
**	Impoort (Tripura)	Imported power	0	160	172	3546240	
72	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	774100	
73	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	886157	
74	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*8.67+2*6.97	25	20	492420	
75	Daudkandi 200 MW PP (B.Trac)	IPP	15*11.4	200	200	824256	
76	Feni Lanka Power	IPP	7*18.15+1*9.78	114	114	1003200	
77	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	113	2838360	
	Bhairab 54.5 MW	IPP	3*18.2	54	37	323280	Engine problem
Cumilla Area Total				3034	2023	4098245	
78	RPCL 210MW CAPP	IPP	4*35+1*70	202	158	3251240	Gas shortage
79	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	17	262583	Engine problem
80	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	57	791040	Engine problem
81	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	13550	
82	Mymensingh 200 MW PP (Unite)	IPP	200	200	193	4329600	
83	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2403600	
84	Sutakhal 50 MW Solar PP	IPP	50	50	0	3054200	
85	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	24	268800	
Mymensingh Area Total				709	544	11626833	
86	Fenchuganj CAPP Phase-1	PDB	2*32+1*33	70	43	1002000	Machine problem
87	Fenchuganj CAPP Phase-2	PDB	2*35+1*35	90	43	1015200	Machine problem
88	Kushihara 163 MW CAPP (KP)	IPP	1*108+1*54	163	163	3402327	
89	Shahjibazar 330 MW CAPP	PDB	3*110	330	328	7374000	
90	Fenchuganj 51 MW PP (Barakat)	RPP	19*2.90	51	52	884400	
91	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	208500	
93	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	32	764544	GT-8 Under maint.
94	Shahjibazar 80MW PP (Shahjiba)	RPP	32*2.90	66	78	1774800	
95	Shahjibazar 100 MW GTTP	IPP	1*100	100	0	0	Under Shut down
96	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	163	4301900	ST under maint.
97	Sylhet 20 MW GTTP	PDB	1*20	20	18	409000	
98	Sylhet 50MW PP (EPL)	RPP	2*72	0	0	0	Contract Expired
99	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	370248	Engine problem
100	Bibiyana-II 341 MW CAPP (Summ)	IPP	1*122+1*119	341	305	7305000	FGMO
101	Bibiyana-III 400 MW CAPP	PDB	400 MW	400	316	8048000	FGMO
102	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	189000	
	Bibiyana South 400 MW	PDB	400 MW	383	320	7951500	Gas shortage
Sylhet Area Total				2377	1897	45039699	
102	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (RPCL-2)	Imported power	2*500	1000	722	1980272	
103	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	99	1832540	Engine problem
104	Fariapur 50 MW Peaking PP	PDB	6*8.99	54	19	159360	Engine problem
105	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
106	Gopalganj 100 MW Peaking PP	PDB	16*8.98	109	0	9344	Reserve.
107	Bheramara 410 MW CAPP	NWPGCL	1*276+1*132	410	300	7785216	Gas shortage.
108	Noapara 40 MW PP (Kharajaban)	QRPP	5*8.5	40	32	468500	Engine problem
109	Noapara 100 MW PP (Bangla Tr)	IPP	70*1.4	100	100	1084800	
110	Rupsha 105 MW PP (Orion rupsa)	IPP	6*18.445	105	93	1966560	Engine problem
111	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1365	33127692	
112	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	1122144	
113	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	34	843593	
114	Bhola 225 MW CAPP	PDB	2*63+1*68	194	68	1587000	Machine problem
115	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	96	2177632	
116	Payra 1320 MW	BCPCL	2*622	1244	600	13088300	
	Bhola Nutan Biddut BD LTD	IPP	220	0	0	0	On Test
	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	35	350400	Low demand
Barisal Area Total				1826	943	78690669	
117	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
118	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	597088	
119	Bera 70 MW Peaking PP	PDB	9*8.29	71	44	872279	Engine problem
120	Amn						