

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2021		Day : Tuesday				Date : 13.04.21					
Probable Maximum Demand :		13300 MW		Yesterday = 81.24 ft		Today = 80.92 ft.		Rule Curve = 85.80 ft.			
Water Level of Kaptai Lake at 06:00 AM											
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	12.04.21 (Yesterday)		13.04.21 (Today)		12.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	a) Ghorasal Repowered CCGP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering
	b) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.
2	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	300	300		
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	100	104	103	103		
4	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
5	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
6	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	213	240	250	260	120	Gas Shortage
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	250	300	300	200	Gas Shortage
8	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
9	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Dirty in gas
10	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	150	180	200	200	30	Gas Shortage
11	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	209	217	220	220	118	ST under maint.
12	Siddhirganj 100 PP/Dutch Bangla	HFO (QRPP)	12x8.9	100	100	92	100	100	100		
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	120	270	305	305	35	dirty in gas
14	Meghnaghat 100 MW(LEL)	HFO (QRPP)	12x8.9	100	100	96	100	100	100		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	10	72	100	100		
17	Gagragar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	102	102	100	100		
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22		
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x17+1x17.3	80	80	53	45	58	58		
20	Masna 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.17	33	33	10	33	33	33		
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.17	33	33	25	25	25	25		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	20	51	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	41	105	105	105		
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	48	150	149	149		
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	132	265	300	300		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149		
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	156	100	300		
30	Bramangan 100 MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	50	100		
31	Aurahi 100MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	104	100	100		
32	Nabaganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	35	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
37	Manikganj 35MW Solar PP (Inspect)	Solar (IPP)	1x35	35	35	27	0	30	0		
Dhaka Zone Total				6026	5829	2681	3625	3736	3966	817	878
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	73	35	70	70	195	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0	0		
41	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	45	50	50	50		
44	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	0	0	50	100		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	130	130		
46	Shikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	151	152	151	151	73	ST under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	57	160	300	300		
48	Judha 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	92	100	100	100		
49	Judha 100 MW Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
50	Dohazari - Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	83	82	85		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22		
*	Malancha Ctg.EPZ (United)	Gas	5x8.73+3x3.34			2	24	10	20		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	94	100	100		
54	Sikalbaha 54 MW Power Plant(Jodiak Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	18	0	110	110		
56	Judha unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
57	Chattogram 116 MW PP (Anilima En	HFO (IPP)	6x21.06	116	116	58	58	60	60		
Chattogram Zone Total				2442	2382	952	1185	1539	1577	195	433
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	135	135	135	135	0	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+17x5	221	221	188	212	225	225		
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	285	295	300	300		
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	280	310	360	360		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	48	47	50	50		
64	Ashuganj 199MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	0	0	0	0	51	Gas Shortage
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50		
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	172	172	170	170		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	5	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.44+159x1.54+106	200	200	0	200	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	2	114	114	114		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	113	113	113	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	37	36	36		
**	Impoprt (Tripura)	India		160	160	144	172	150	168		
Cumilla Zone Total				3094	3034	1535	2023	1925	2093	501	163
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	114	138	135	135	64	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	17	17	17		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	16	57	56	56		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	179	193	200	200		
84	Saishatabdi 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	31	0	50	0		
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	6	24	22	22		
Mymensingh Zone Total				717	709	463	544	597	545	64	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.04.21 (Yesterday)		13.04.21 (Today)		12.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	43	42	42		27	GT-1 Load gear problem	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	Under maint.	
89	Fenchugonj 51 MW PP (Barakatulle)	Gas (RPP)	19x20	51	51	22	52	51	51				
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	140	163	110	110				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	32	33	33		34	Under maint.	
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	310	328	330	330				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	73	78	75	78				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x69	231	231	164	163	200	220				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	9	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	305	341	341				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	315	316	400	400	84		Gas Shortage	
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	330	320	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1798	1897	2080	2103	84	108	
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	300	300	400	400	110		Gas Shortage	
105	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	19	20	20				
106	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	99	83	99				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	8	32	32	33				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	74	93	92	92				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	837	722	856	856				
Khulna Zone Total					2288	2284	1306	1365	1693	1996	110	0	
113	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110				
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	34	33	33				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	68	70	70		126	GT-2 & STG Under maint.	
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1x196	95	95	90	96	95	95				
117	Payra 1320 MW TPP	Coal (BCFCL)	2x622	1244	1244	470	600	622	622				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	150	150				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0				
Barishal Zone Total					1826	1826	646	943	1080	1080	0	126	
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	200	0	200	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	44	35	35				
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0				
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	100	100				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	31				
126	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
127	Santihar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	33				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	92	144	100	100	66		Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	166	202	180	200				
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	166	208	200	200				
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	378	390	400	400				
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	19	21	22				
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	2	11	11	11				
134	Natore 52 MW PP (Rajlanika)	HFO (IPP)	6x8.92	52	52	43	43	43	43				
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	90	113	113	113				
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	113	113				
Rajshahi Zone Total					2173	2173	1250	1502	1597	1651	237	0	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	76	70	70	9		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	10	10				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	113	67	113	113				
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Majpara, Tatala 8 MW Solar PP (Sympa Po)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total					685	605	269	293	351	343	218	0	
Sub-total: Plants in operation					21673	21219	10900.0	13377	14598	15354	2226	1708	
Available Power at Sub-station end excluding PS auxiliary use and Transmission loss							10372	12729	13890	14610			
(B) Plants under long term maintenance/ contract expired													
143	Ghorashal 78.5 MW PP (MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
144	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
147	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired					294	0	0	0	0	0	0	0	
Gross Total					21967	21219	10900	13377	14598	15354	2226	1708	
(C) Actual data of 12.04.21 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	: 13377.00 MW, at = 21:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 12729.00 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 13377.00 MW, at = 21:00 hrs		Dhaka	4398	4398	0	Mymensingh	1040	1040	0		
04.	Minimum Generation (Generation end)	: 9921.00 MW, at = 6:00 hrs		Chattogram	1406	1406	0	Sylhet	466	466	0		
05.	Day-peak Generation (Generation end)	: 10900.00 MW, at = 12:00 hrs		Khulna	1624	1624	0	Barishal	373	373	0		
06.	Evening-peak Generation (Generation end)	: 13377.00 MW, at = 21:00 hrs		Rajshahi	1365	1365	0	Rangpur	763	763	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs		Cumilla	1294	1294	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10030.00 MW, at = 5:00 hrs						Total	12729	12729	0		
09.	Generation shortfall at evening peak due to :	:		13.	Fuel cost :	(a) Gas = 160666360 Taka	(c) Coal = 81398948 Taka						
	a) Gas limitation	: 1813 MW			(b) Oil = 674559967 Taka		Total = 916625275 Taka						
	d) Coal supply Limitation	: 218 MW		14.	Maximum Temperature in Dhaka was :	37.0° C							
	b) Low water level in Kaplai lake	: 195 MW		15.	Export through East-West interconnections :								
	c) Plants under shut down/ maintenance	: 1708 MW			At evening peak-hour	: -296 MW, at 21:00 hrs							
10.	Total Energy (Generation + India Import)	: 276.85 MKWh			Maximum	: -296 MW, at 21:00 hrs							
	By Gas = 149.209 MKWh	By Oil = 84.513 MKWh			Energy	: 0.534 MKWh							
	By Coal = 17.430 MKWh	By Hydro = 1.598 MKWh											
	By Solar = 0.726 MKWh												
11.	Total Gas Supplied	: 1197.33 MMCFD											
(D) Forecast of 13.04.21 (Today) Tuesday :													
01.	Maximum Demand	: 13300 MW (Generation end)		04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 15354 MW (Generation end)		05.	Total Generation	: 275.25 MKWh							
03.	Maximum Shortage	: -2054 MW (Generation end)		06.	Probable Max. Temperature in Dhaka	: 39.8° C							

* Captive Power ** Imported Power

#Remarks: Highest Generation 13377 MW on 12-04-2021 at 21:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation