

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 13-Apr-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour Generation	Generated	
			Unit No. X Capacity	MW	HR	MW	
	Ghorasal Repowered CAPP Unit-	PDB	1*210	170	0	0	Under maint.
	Ghorasal Repowered CAPP Unit-	PDB	1*210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
2	Ghorasal 365 MW CAPP Unit-7	PDB	1*243+1*122	365	300	7149391	Machine problem
3	Ghorashah 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
4	Ghorashah 108MW PP (Regent)	IPP	343.35	108	103	2416045	
5	Haripur GTRP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	0	0	Under S/D due to dust in the gas line.
7	Haripur 360MW CAPP(HPL)	IPP	1*235+1*125	360	160	4976000	Gas shortage
8	Meghnaghat 450 MW CAPP(MP)	IPP	2*150+1*150	450	260	5979300	Gas shortage
9	Meghnaghat 100 MW(EL)	QRPP	12*8.9	100	100	2105280	Gas shortage
10	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	240	5900044	Gas shortage
11	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+1*11.3	55	55	1315132	
13	Keraniganj 100 MW PP (Powerpa)	QRPP	8*13.45	100	82	984747	Engine problem
14	Narsihngi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	344340	
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirganj 2*120 MW GTTP	EGCB	2*105	210	180	3986000	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla	QRPP	12*8.9	100	96	2172480	
18	Siddhirganj 335 MW CAPP	EGCB	1*217+1*18	335	221	519382	ST under maint.
19	Gagnagar 102 MW PP (Digital Pa	IPP	12*8.924	102	102	2132352	
20	Katpott 52 MW PP (Siraha)	IPP	7*7.9	51	0	0	Fuel shortage
21	Kamatnagar 54 MW PP(Banco E	IPP	3*18	54	54	1283040	
22	Kodda 150MW PP	BPDB-RCCL	9*17.06	149	133	2284640	
23	Maniganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1125164	
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	1268047	
25	Bosila 108MW PP(CLC)	IPP	12*8.75+1*3.5	108	0	0	Engine problem
26	Summit Power Plant (Siddhirganj)	SIPP, REB	3*3.67+4*8.73	90	52	1212640	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	743900	
28	Ruganaj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	692400	Engine problem
29	Gazipur 52 MW PP	IPP	6*8.9	52	50	654720	
30	Tongi 80 MW GTTP	PDB	1* 105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	268	5045779	Engine problem
32	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	256	4943927	Low demand
33	Bramhanaganj 100 MW PP (Agg	IPP	100	100	50	288662	Low demand
34	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	101	473305	
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3482928	
36	Gazipur 100 MW PP	RCL	100 MW	105	105	1749600	
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*5	104	104	261690	
38	Maniganj 162MW PP(MPGCL)	IPP	9*18	162	162	3690640	
	Spectra Solar Plant Ltd.	IPP	35	35	0	213419	
Dhaka area Total				5829	3581	65470294	
39	Chattogram TPP-1	PDB	1*210	180	0	0	Gas shortage.
40	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
41	Razzan 25 MW PP	IPP	3*8.9	25	25	366682	
42	Teknaf 20MW PP (SolarTech)	SolarTech Energ	20	20	0	1224440	
43	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	1053600	
44	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	1676000	Unit-2 under maint
45	Sikalbaha 225MW	PDB	1*150+1*175	225	230	2929083	
46	Sikalbaha Peaking GT	PDB	1*150	150	130	3067034	
47	Sikalbaha 105 MW PP (Baraka S	IPP	105 MW	105	0	0	Reserve.
48	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	
49	Dohazari-Kalaish 100 MW Peak	PDB	6*17	102	83	1031555	Engine problem
50	Juddah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	98	1205520	
51	Juddah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2318400	
52	Barakunda 22 MW PP (Regent	SIPP, PDB	8*2.90	22	20	442272	
53	Malancha, Cig (United)	IPP	5*8.73+3*9.34	0	31	596400	
54	Chattogram 108 MW PP (ECPV)	IPP	6*17	108	84	1225920	Engine problem
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	31318	
56	Anwara 300 MW PP (United)	IPP	300 MW	300	125	3138873	Transformer OIL
57	Jodiha Power	IPP	3*18.55+1*3.6	54	54	1299734	
58	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
59	Juddah unit-2 (Acorn)	IPP	8*13.6	100	100	2426160	
60	Anlima Energy Ltd.	IPP	6*21.2	116	57	1377491	Engine problem
Chattogram area Total				2382	1257	24212487	
61	Ashuganj TPP Unit- 3	APSCL	1*150	135	100	2313324	
62	Ashuganj TPP Unit- 4	APSCL	1*150	129	0	0	Gas shortage
63	Ashuganj TPP Unit- 5	APSCL	1*150	134	0	0	Gas shortage
64	Ashuganj 225 MW CAPP	APSCL	1*144+2*75	221	208	4755000	
65	Ashuganj 450 MW CAPP(North)	APSCL	1*360	360	300	7674700	FGMO
66	Ashuganj 450 MW CAPP(South)	APSCL	1*360	360	300	7233000	FGMO
67	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	594288	Engine problem
68	Ashuganj 55 MW PP (Precision)	RPP	154	55	50	1131840	
69	Ashuganj 158MW PP (APCL-U)	IPP	20*9.34+1*16	195	8	200727	
70	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	0	Gas shortage
71	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	0	0	Line fault
72	Titias 50 MW Peaking PP	PDB	6*8.92	52	50	516912	
73	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	51	487260	Machine problem
74	Chandpur 200MW (Desh energy)	IPP	0	200	154	388948	Engine problem
75	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	491272	
76	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	159660	
77	Impport (Tripura)	Imported power	0	160	170	3557760	
78	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	817400	
79	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	1035701	
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	514160	
81	Daudkandi 200 MW PP (B. Trac)	IPP	15*11.4	200	150	7441892	
82	Feni Lanka Power	IPP	7*18.15+1*9.78	114	114	1476300	
83	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	113	2730840	
84	Bhairab 54.5 MW	IPP	3*18.2	54	37	737280	Engine problem
Cumilla Area Total				3034	1969	37566964	
85	RPCL 210MW CAPP	IPP	4*35+1*70	202	100	2701520	Gas shortage
86	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	17	360000	Engine problem
87	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	57	1147200	Engine problem
88	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	14750	
89	Mymensingh 200 MW PP (Unite)	IPP	200	200	180	3976800	Engine problem
90	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2516400	
91	Sutakhali 50 MW Solar PP	IPP	50	50	0	3336110	
92	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	24	566160	
Mymensingh Area Total				709	493	11619640	
93	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	42	997000	Machine problem
94	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	43	1031880	Machine problem
95	Kushihara 163 MW CAPP (KP)	IPP	1*108+1*54	163	110	2977036	Gas shortage
96	Shahjibazar 330 MW CAPP	PDB	3*110	330	326	743208	
97	Fenchugonj 51 MW PP (Barakat	RPP	19*2.90	51	50	1130000	
98	Fenchugonj 44MW (Energyprima	RPP	12*3.3+5*2	0	0	0	Contract Expired
99	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	165100	
100	Shahjibazar GTRP Unit- 8 & 9	PDB	2*32	66	32	774912	GT-8 Under maint.
101	Shahjibazar 80MW PP (Shahjiba	RPP	32*2.90	66	78	1765000	
102	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under Shut down
103	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	163	3918390	Gas shortage
104	Sylhet 20 MW GTTP	PDB	1*20	20	18	410000	
105	Sylhet 50MW PP (EPL)	RPP	2*72	0	0	0	Contract Expired
106	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	273936	Engine problem
107	Bibiana-II 341 MW CAPP (Summit)	IPP	1*122+1*119	341	300	7303500	FGMO
108	Bibiyana-III 400 MW CAPP	PDB	400 MW	400	368	8679000	FGMO
109	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	8	170280	
110	Bibiyana South 400 MW	PDB	400 MW	383	331	8063600	
Sylhet Area Total				2377	1896	45122234	
111	Bheramara GTRP Unit-3	PDB	1*20	16	0	0	Reserve.
112	Bheramara (RPCL-2)	Imported power	2*500	1000	843	19353818	
113	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	115	99	2108240	Engine problem
114	Faridpur 50 MW Peaking PP	PDB	6*6.89	54	19	198720	Engine problem
115	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	230	0	0	Reserve.
116	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	16256	Reserve.
117	Bheramara 410 MW CAPP	NWPGCL	1*276+1*132	410	250	6920928	Gas shortage.
118	Noapara 40 MW PP (Kharajabari)	QRPP	5*8.5	40	33	526875	Engine problem
119	Noapara 100 MW PP (Bangla Tr	IPP	70*1.4	100	100	792960	
120	Rupsha 105 MW PP (Orion rupsa	IPP	6*18.445	105	92	2129280	Engine problem
121	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1436	32025077	
122	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	110	102296	
123	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	34	632574	
124	Bhola 225 MW CAPP	PDB	2*63+1*68	194	67	1579000	Machine problem
125	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	96	1936835	
126	Payra 1320 MW	BCPCL	2*622	1244	610	14355400	
127	Bhola Nutan Biddu Ltd LTD	IPP	220	0	4	124827	On Test
128	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	54	222000	Low demand
Barisal Area Total				1826	975	78652684	
129	Baghbari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
130	Baghbari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage.
131	Baghbari 50 MW Peaking PP	PDB	6*8.9	52	43	612000	
132	Bera 70 MW Peaking PP	PDB	9*8.29	71	42	422426	Engine problem
133	Annura 50 MW PP(Siraha)	QRPP	7*7.9	50	0	0	Fuel shortage
134	Katakahi 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Fuel shortage
135	Katakahi 50 MW Peaking PP	PDB	6*8.7	50	31	329200	Engine problem
136	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	80	1599000	Gas shortage
137	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	174	4826382	FGMO
138	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	176	4521764	FGMO
139	Sirajgonj 400 MW CAPP Unit-4	SWPGCL	1*282+1*132	414	394	9070781	FGMO
140	Sarlahar 50 MW Peaking PP	PDB	6*8.7	50	26	229588	Engine problem
141	Bogra 22 MW PP (GBB)	RPP	6*4	22	21	475200	
142	Bogra 20 MW PP (Energyprima	RPP	5*3+5*2	0	0	0	Contract Expired
143	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	167598	
144	Natore 52 MW PP (Banjanka)	IPP	6*8.92	52	43	993298	
145	Chapanawabganj 100 MW Peak	IPP	12*8.924	104	96	1067768	
146	Baghbari 200 MW PP (Paramou	IPP	200 MW	200	0	25655	Reserve.
147	Bagura 113 MW PP (Confidence	IPP	113 MW	113	113	2604864	
148	Confidence Power Bogura Unit-1	IPP	6*18.55	113	113	2614560	
Rajshahi Area Total				2173	1383	29575206	