

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2021		Day : Saturday				Date : 17.04.21					
Probable Maximum Demand :		13000 MW		Yesterday = 79.88 ft		Today = 79.76 ft		Probable Maximum Generation : 15995 MW		Rule Curve = 84.80 ft.	
Water Level of Kaptai Lake at 06:00 AM											
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.04.21 (Yesterday)		17.04.21 (Today)		16.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	a) Ghorasal Repowered CCGP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170	Under Repowering
	b) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	170	170	170	20	Gas Shortage
2	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	104	104	104		
4	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
5	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
6	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	340	346	360	360	14	Gas Shortage
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	290	290	300	300	160	Gas Shortage
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
9	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	230	300	300	182	Dirty in gas
10	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	155	200	200	55	Gas Shortage
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	220	200	220	115	ST under maint.
12	Siddhirgonj 100 PP/Dutch Bangla	HFO (QRPP)	12x8.9	100	100	7	91	91	91		
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	305	305	280	270	280	280	35	dirty in gas
14	Meghnaghat 100 MW(LEL)	HFO (QRPP)	12x8.9	100	100	0	100	100	100		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
17	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	8	102	100	100		
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.50	22	22	22	22	22	22		
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	42	52	58	58		
20	Masna 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.71	33	33	33	33	33	33		
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.71	33	33	25	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	25	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	105	105		
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	150	149	149		
25	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	300	300	300		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	133	149	149		
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300		
30	Bramhangon 100 MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
31	Aurahi 100MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
32	Nabaganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	35	54	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
37	Manikganj 35MW Solar PP (Inspect	Solar (IPP)	1x35	35	35	30	0	30	0		
Dhaka Zone Total				6026	5829	1829	3415	3971	4211	466	1070
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	35	35	35	35	195	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	3	0	5	0	0		
41	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	42	50	50	50		
44	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	0	0	50	100		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	130	130		
46	Shikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	228	203	230	230		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	52	34	300	300		
48	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	0	80	80	80		
49	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	62	100	100	100		
50	Dohazari - Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	83	82	85		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.50	22	22	22	22	22	22		
*	Malancha, Ctg,EPZ (Unite)	Gas	5x8.73+3x9.34			18	42	25	40		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	77	85	85		
54	Sikalbaha 54 MW Power Plant(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
56	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
57	Chattogram 116 MW PP (Anilima En	HFO (IPP)	6x21.06	116	116	72	95	108	109		
Chattogram Zone Total				2442	2382	858	1122	1603	1647	195	360
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	80	80	80	80	55	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+17x5	221	221	195	206	225	225		
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	290	265	300	300		
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	345	260	360	360		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	53	50	55		
64	Ashuganj 199MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	0	0	0	0	51	Gas Shortage
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0	50	
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	91	91	90	90	72	ST Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	156	195	195	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.50	22	22	20	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x4.44+159x1.54+0.06	200	200	0	0	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	26	113	113	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	37	36	37		
**	Impoport (Tripura)	India		160	160	140	166	157	188		
Cumilla Zone Total				3094	3034	1501	1638	1992	2184	556	72
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	190	207	200	200		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.50	22	22	19	19	20	20		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	33	74	74	74		
82	Jamalpur 115 MW PP (Unite)	HFO (IPP)	12x9.87	115	115	0	115	115	115		
83	Mymensingh 200 MW PP (Unite)	HFO (IPP)	21x9.780	200	200	154	198	200	200		
84	Saishatabdi 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	1.6	0	0		
85	Sutarkhali 50 MW Solar PP	Solar (IPP)	1x50	50	49	0	50	0	0		
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22		
Mymensingh Zone Total				717	709	471	637	683	631	0	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.04.21 (Yesterday)		17.04.21 (Today)		16.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	43	43	43		27	GT-1 Load gear problem
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	Under maint.
89	Fenchugonj 51 MW PP (Barakatulle)	Gas (RPP)	19x20	51	51	53	53	51	51			
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	32	33	33		34	Under maint.
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	331	333	330	330			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	73	78	75	78			
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x69	231	231	169	203	200	220			
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	18	18			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	9	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16			
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	300	341	341			
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	336	368	400	400			
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	335	400	400			
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			
Sylhet Zone Total				2422	2377	1944	2005	2134	2157	0	108	
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16			
104	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	265	340	400	400	70		Gas Shortage
105	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	19	20	20			
106	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60			
107	Khulna 225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	0	0	0	220			
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	99	99	99			
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100			
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	33	32	33			
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	92	91	92			
112	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	100	100			
**	Bheramara (HVDC)	India		1000	1000	842	723	857	857			
Khulna Zone Total				2288	2284	1207	1406	1709	1997	70	0	
113	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110			
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	25	34	33	33			
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	64	68	70	70		126	GT-2 & STG Under maint.
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1x196	95	95	52	97	95	95			
117	Payra 1320 MW TPP	Coal (BCFCL)	2x622	1244	1244	500	560	622	622			
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150			
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				24	51	50	50			
Barishal Zone Total				1826	1826	665	920	1130	1130	0	126	
119	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50			
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	35	35			
123	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	82	100	100			
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	31			
126	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0			
127	Santihar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32			
128	Siraggonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	110	70	0	140	140		Gas Shortage
129	Siraggonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150+1x75	220	220	192	175	180	200			
130	Siraggonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	200	169	200	200			
131	Siraggonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	353	410	400	400			
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	22	22			
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	10	11	11			
134	Natore 52 MW PP (Rajlanaka)	HFO (IPP)	6x8.92	52	52	1	43	43	43			
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113			
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113			
Rajshahi Zone Total				2173	2173	1114	1238	1497	1690	311	0	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	76	74	75	75	11		Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	10	10			
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	58	100	113	113			
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
142	Majpara, Tatala 8 MW Solar PP (Synpa Po)	Solar (IPP)	1 x 8	8	8	0	0	8	0			
Rangpur Zone Total				685	605	284	324	356	348	220	0	
Sub-total: Plants in operation				21673	21219	9873.0	12705	15075	15995	1818	1736	
Available Power at Sub-station end excluding PS auxiliary use and Transmission loss						9551	12290	14582	15473			
(B) Plants under long term maintenance/ contract expired												
143	Ghorashal 78.5 MW PP (MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021
144	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
145	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020
147	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
Sub-Total: Plants under long term maintenance/ contract expired				294	0	0	0	0	0			
Gross Total				21967	21219	9873	12705	15075	15995	1818	1736	
(C) Actual data of 16.04.21 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)	: 12705.00 MW, at = 21:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 12290.00 MW, at = 21:00 hrs										
03.	Highest Generation (Generation end)	: 12712.00 MW, at = 22:00 hrs										
04.	Minimum Generation (Generation end)	: 9126.00 MW, at = 9:00 hrs										
05.	Day-peak Generation (Generation end)	: 9873.00 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 12705.00 MW, at = 21:00 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 4853.00 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
	a) Gas limitation	: 1403 MW										
	d) Coal supply Limitation	: 220 MW										
	b) Low water level in Kaplai lake	: 195 MW										
	c) Plants under shut down/ maintenance	: 1736 MW										
10.	Total Energy (Generation + India Import)	: 261.99 MKWh										
	By Gas =	145.270 MKWh	By Oil =	73.339 MKWh								
	By Coal =	19.179 MKWh	By Hydro =	0.840 MKWh								
	By Solar =	0.655 MKWh										
11.	Total Gas Supplied	: 1123.28 MMCFD										
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
	Dhaka	3979	3979	0	Mymensingh	1111	1111	0				
	Chattogram	1290	1290	0	Sylhet	484	484	0				
	Khulna	1569	1569	0	Barishal	383	383	0				
	Rajshahi	1413	1413	0	Rangpur	798	798	0				
	Cumilla	1263	1263	0								
					Total	12290	12290	0				
13.	Fuel cost :	(a) Gas = 156170827 Taka	(c) Coal = 90844805 Taka									
		(b) Oil = 520820227 Taka	Total = 767835859 Taka									
14.	Maximum Temperature in Dhaka was : 36.1° C											
15.	Export through East-West interconnections :											
	At evening peak-hour	: -352 MW, at 21:00 hrs										
	Maximum	: -352 MW, at 21:00 hrs										
	Energy	: 2.0465 MKWh										
(D) Forecast of 17.04.21 (Today) Saturday :												
01.	Maximum Demand	: 13000 MW (Generation end)										
02.	Maximum Generation	: 15995 MW (Generation end)										
03.	Maximum Shortage	: -2995 MW (Generation end)										
04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)										
05.	Total Generation	: 267.92 MKWh										
06.	Probable Max. Temperature in Dhaka	: 38.1° C										

* Captive Power ** Imported Power

#Remarks: Highest Generation 13380 MW on 15-04-2021 at 21:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation