

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2021		Day: Sunday					Date: 18.04.21					
Probable Maximum Demand : 12000 MW		Probable Maximum Generation : 15834 MW					Rule Curve = 84.60 ft.					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 79.76 ft	Today = 79.64 ft.									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	17.04.21 (Yesterday)		18.04.21 (Today)		17.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for:		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening			Gas/water/Coal limitation MW	
(A) Plants in operation:												
1	a) Ghorasal Repowered CCGP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0	170		Under Repowering
	b) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under Repowering
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190			
2	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		Under maint.
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	97	101	104	104			
4	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		CB Problem
5	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage
6	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	341	283	360	360	77		Gas Shortage
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	290	290	300	300	160		Gas Shortage
8	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling
9	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	189	191	0	0	221		Dirty in gas
10	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	115	175	180	190	35		Gas Shortage
11	Siddhirganj 335 MW CCGP	Gas (EGCB)	1x 217+1x118	335	335	180	220	150	220	115		ST under maint.
12	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	3	100	100	100			
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	250	275	300	300	30		dirty in gas
14	Meghnaghat 100 MW(LEL)	HFO (QRPP)	12x8.9	100	100	0	65	100	100			
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.09+1x11.3	55	55	0	55	55	55			
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	85	85			
17	Gagnagar 102 MW PP (Digital Powe	HFO (IPP)	12x8.924	102	102	16	32	100	100			
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x3.73	80	80	47	55	58	58			
20	Masna 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.71	33	33	33	33	33	33			
21	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.71	33	33	8	33	33	33			
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	52	52			
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	105	105			
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	16	149	149			
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	135	300	300			
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	125	132	149	149			
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300			
30	Bramhangon 100 MW PP (Aggrak)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
31	Aurahi 100MW PP (Aggrak)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
32	Nabaganj 55 MW PP (Southern po	HFO (IPP)	3x19.3	55	55	20	35	55	55			
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
34	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	16	104	104	104			
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	108	162	162			
37	Manikganj 35MW Solar PP (Inspect)	Solar (IPP)	1x35	35	35	32	0	30	0			
Dhaka Zone Total			6026	5829	2080	2872	3635	3935	543	1050		
38	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	55	70	61	61	160		Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	6	0	5	0	0			
41	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	17	17			
42	Teknaf 20MW PP (Solar)tech	Solar (IPP)	1x20	20	20	5	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	25	50	50			
44	Sikalbaha 105 MW PP (Baraka Sika	HFO (IPP)	6x18.415	105	105	0	0	50	100			
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	130	130	130	130			
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	204	202	230	230			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300			
48	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	100	100	100			
49	Juldah 100 MW Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	90	100	100			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	83	83	83			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	22	22	22			
*	Malancha Ctg.EPZ (United)	Gas	5x8.73+3x3.34			5	38	10	20			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	95	95			
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	54	54			
55	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	70	100	100	100			
57	Chattogram 116 MW PP (Arifima En	HFO (IPP)	6x21.06	116	116	0	116	108	109			
Chattogram Zone Total			2442	2382	539	1047	1645	1681	160	360		
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	135	135	135	135	0		Gas Shortage
	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage
	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+17x5	221	221	182	179	225	225			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	0	0	360	360			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	245	320	360	360			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	49	55	50	55			
64	Ashuganj 199MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	83	26	8	8	169		Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	0	0	0	0	51		Gas Shortage
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	0	0			
67	Titass 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0	50		
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	86	90	90	90	73		ST Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	28	136	150	150			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	0	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	25	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	20	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.46+115x+13x1.066	200	200	0	0	100	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	18	113	113	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	36	37	37			
**	Impoport (Tripura)	India		160	160	114	166	157	188			
Cumilla Zone Total			3094	3034	1010	1371	2063	2249	483	73		
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	210	170	200	200			
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	19	20	20			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	34	65	74	74			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	72	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	184	200	200			
84	Saishaban 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	26	0	50	0			
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	5	24	22	22			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.04.21 (Yesterday)		18.04.21 (Today)		17.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening					Day	Evening		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Load gear problem					
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	44	43	43	43		47	Under maint.					
89	Fenchugonj 51 MW PP (Barakakulsi)	Gas (RPP)	19x2.90	51	51	46	53	51	51								
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163								
91	Hobiganj 11MW PP Confidence-E	Gas (SIIP, REB)	4x2.90	11	11	2	11	11	11								
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	32	33	33	33		33	Under maint.					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	334	329	330	330								
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	78	75	78								
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x69	231	231	174	200	200	220								
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18								
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10								
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16								
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	130	300	341	341								
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	240	365	400	400								
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	360	400	400								
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0								
Sylhet Zone Total						2422	2377	1679	2021	2134	2157	0	107				
103	Bheramara GTTP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	16								
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	355	355	400	400		55	Gas Shortage					
105	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	4	20	20								
106	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60								
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220								
108	Khulna 115 PP MW (KPLC-2)	HFO (QRPP)	7x17	115	115	83	99	99	99								
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100								
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	33	32	33								
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	5	92	93	93								
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100								
**	Bheramara (HVDC)	India		1000	1000	723	727	742	742								
Khulna Zone Total						2288	2284	1166	1410	1596	1883	55	0				
113	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	96	110	110								
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	12	31	33	33								
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	69	70	70		125	GT-2 & STG Under maint.					
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1x196	95	95	31	95	95	95								
117	Payra 1320 MW TPP	Coal (BCFCL)	2x622	1244	1244	370	580	622	622								
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150								
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	50	50								
Barishal Zone Total						1826	1826	413	871	1130	1130	0	125				
119	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	70	40	40		1	Gas Shortage					
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	70	40	40		30	Gas Shortage					
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50								
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200								
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	35	35								
123	Ammura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0								
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	100	100	100								
125	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	31								
126	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50								
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	32								
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	134	140	140		76	Gas Shortage					
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	117	180	180	200								
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	193	181	200	200								
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	384	419	400	400								
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	22	22								
133	Lillapara 11 MW PP (Summit)	Gas (SIIP, REB)	4x2.90	11	11	11	8	11	11								
134	Natore 52 MW PP (Rajlanca)	HFO (IPP)	6x8.92	52	52	0	52	43	43								
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	70	95	113	113								
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	18	113	113	113								
Rajshahi Zone Total						2173	2173	811	1476	1767	1820	107	0				
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	76	75	75		9	Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85				Coal Shortage				
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	149	150	150		125	Coal Shortage					
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	10	10								
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	20	113	113	113								
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
142	Majpara, Tatala 8 MW Solar PP (Sympa Po)	Solar (IPP)	1 x 8	8	8	0	0	8	0								
Rangpur Zone Total						685	605	245	338	356	348	219	0				
Sub-total: Plants in operation						21673	21219	8237.0	11940	15009	15834	1567	1715				
Available Power at Sub-station end excluding PS auxiliary use and Transmission loss									7902	11455	14399	15191					
(B) Plants under long term maintenance/ contract expired																	
143	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021				
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0								
145	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021				
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020				
147	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020				
Sub-Total: Plants under long term maintenance/ contract expired						294	0	0	0	0	0	0	0				
Gross Total						21967	21219	8237	11940	15009	15834	1567	1715				
(C) Actual data of 17.04.21 (Yesterday) Saturday :																	
01.	Max. Demand at eve. peak (Generation end) :				11940.00	MW,	at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end) :				11455.00	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end) :				11940.00	MW,	at =	21:00 hrs	Dhaka	3844	3844	0	Mymensingh	959	959	0	
04.	Minimum Generation (Generation end) :				4853.00	MW,	at =	7:00 hrs	Chattogram	1309	1309	0	Sylhet	418	418	0	
05.	Day-peak Generation (Generation end) :				8237.00	MW,	at =	12:00 hrs	Khulna	1514	1514	0	Barishal	335	335	0	
06.	Evening-peak Generation (Generation end) :				11940.00	MW,	at =	21:00 hrs	Rajshahi	1375	1375	0	Rangpur	574	574	0	
07.	Evening Peak Load-shed (Sub-station end) :				0.00	MW,	at =	21:00 hrs	Cumilla	1127	1127	0					
08.	Minimum Generation Forecast up to 8:00 hrs. :				7957.00	MW,	at =	5:00 hrs					Total	11455	11455	0	
09.	Generation shortfall at evening peak due to :								13.	Fuel cost :	(a) Gas = 148330279 Taka	(c) Coal = 76655706 Taka					
	a) Gas limitation :				1188	MW				(b) Oil = 281698950 Taka		Total = 507664935 Taka					
	d) Coal supply Limitation :				219	MW											
	b) Low water level in Kaplai lake :				160	MW											
	c) Plants under shut down/ maintenance :				1715	MW											
10.	Total Energy (Generation + India Import) :				213.48	MKWh			14.	Maximum Temperature in Dhaka was :		33.0° C					
	By Gas = 136.497 MKWh									15. Export through East-West interconnections :							
	By Coal = 15.925 MKWh									At evening peak-hour :		122	MW,	at	21:00 hrs		
	By Solar = 0.667 MKWh									Maximum :		-446	MW,	at	4:00 hrs		
	By Oil = 40.557 MKWh									Energy :		0.729	MKWh				
11.	Total Gas Supplied :				1227.52	MKWh											
(D) Forecast of 18.04.21 (Today) Sunday :																	
01.	Maximum Demand :				12000	MW	(Generation end)		04.	Maximum Load-shed :				0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation :				15834	MW	(Generation end)		05.	Total Generation :				214.55	MKWh		
03.	Maximum Shortage :				-3834	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :				38.5° C			

* Captive Power ** Imported Power

Remarks: Highest Generation 13380 MW on 15-04-2021 at 21:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation