

Date : 21-Apr-21		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	MW	
1	Ghorasal Repowered CCPP Unit-3	PDB	1'210	180	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1'210	190	190	4485600	
4	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	103	2309409	
7	Haripur GTPP	SBU_PDB	2'32	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	0	0	Dirty in Gas
9	Haripur 360MW CCPP(HPL)	IPP	1'235+1'125	360	282	7082000	Gas shortage
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	280	6644500	Gas shortage
11	Meghnaghat 100 MW(IEI)	QRPP	12'8.9	100	91	1522960	
12	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	305	240	6116160	Gas shortage
13	Madanganj 102 PP(Summit)	QRPP	6'17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3'17.06+1'11.3	55	55	1289531	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	100	100	489797	
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	449964	
17	210 MW Sidhigonj TPP	PDB	1'210	115	0	0	Under maint.
18	Sidhigonj 2'120 MW GTTP	EGCB	2'105	210	140	3529000	
19	Sidhigonj 100 PP(Dutch Bangla)	QRPP	12'8.9	100	100	2112000	
20	Sidhigonj 335 MW CCPP	EGCB	1'217+1'18	335	192	463178	ST under maint.
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	102	1550304	
22	Kalpoti 52 MW PP (Sinha)	IPP	7'7.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	1237680	
24	Kodda 150MW PP	BRPB-RPCL	9'17.06	149	147	3520640	
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	500290	Engine problem
26	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	54	1214132	
27	Bosila 108MW PP(IEI)	IPP	12'8.775+1'3.5	108	0	0	Fuel shortage
28	Summit Power, (Madhadi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	49	1032580	Engine problem
29	Madhadi 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	734800	
30	Rugganji 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	742600	
31	Gazipur 52 MW PP	IPP	6'8.9	52	41	557280	Engine problem
32	Tongi 80 MW GTTP	PDB	1'105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	267	2569608	Load increasing time.
34	Keraniganj 300 MW PP (APR)	IPP	258'1.4	300	0	0	Reserve.
35	Bramanganj 100 MW PP (Agreko)	IPP	100	100	39	36929	Low demand
36	Aurahati 100MW PP (Agreko)	IPP	0.85'23+0.95'91	100	95	125705	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3323204	
38	Gazipur 100 MW PP	RPCL	100 MW	105	103	2158800	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	104	2266960	
40	Manikganj 162MW PP(MPGL)	IPP	9'18	162	162	3064320	
41	Spectro Solar Plant Ltd.	IPP	35	35	0	228552	
Dhaka area Total				5829	3253	59368383	
39	Chattoagram TPP-1	PDB	1'210	180	0	0	Gas shortage.
40	Chattoagram TPP-2	PDB	1'210	180	0	0	Gas shortage
41	Raozan 25 MW PP	IPP	3'8.9	25	17	415326	Engine problem
42	Teknaf 20MW PP (Solartech)	IPP	20	20	0	91665	
43	Teknaf 20MW PP (Baraka)	IPP	8'6.98	50	45	554720	
44	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	35	848000	Unit-2 under maint
45	Sikalbaha 225MW	PDB	1'150+1'175	225	204	4910668	FGMO
46	Sikalbaha Peaking GT	PDB	1'150	150	130	3116710	
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	1'150	105	105	2340145	
48	Hathazari 100 MW peaking PP	PDB	1'18.9	98	0	0	
49	Dohazari-Kalaish 100 MW Peaking	PDB	6'17	102	66	854134	Engine problem
50	Juddah 100 MW Unit-1 (Acorn)	QRPP	8'13.45	100	100	1575220	
51	Juddah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	2136960	Engine problem
52	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	21	481056	
53	Malancha, Ctg. EPZ, United	IPP	5'8.73+3'9.34	0	28	51360	
54	Chattoagram 108 MW PP (ECFV)	IPP	8'29	108	84	847680	Engine problem
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	37920	
56	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0	Transformer O/L.
57	Jodioc Power	IPP	3'18.55+1'3.6	54	54	1285410	
58	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
59	Juddah unit-2 (Acorn)	IPP	8'13.6	100	100	2247360	
60	Antima Energy Ltd.	IPP	6'21.2	115	35	966073	Engine problem
Chattoagram area Total				2382	1714	23044947	
58	Ashuganj TPP Unit-3	APSCL	1'150	135	100	2975686	Gas shortage
59	Ashuganj TPP Unit-4	APSCL	1'150	129	0	0	Gas shortage
60	Ashuganj TPP Unit-5	APSCL	1'150	134	0	0	Gas shortage
61	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	0	3721000	tripped at 17.04.
62	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	310	7455400	FGMO
63	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	295	7191000	FGMO
64	Ashuganj 50 MW PP	APSCL	14'3.968	45	26	542304	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	46	990720	
66	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'116	195	8	200727	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6'8.34	51	0	0	Line fault
68	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	0	0	Line fault
69	Titas 50 MW Peaking PP	PDB	6'8.92	52	50	244216	
70	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	88	2115450	
71	Chandpur 200MW (Desh energy)	IPP	0	200	197	4656000	
72	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	21	448056	
73	Feni 11 MW PP (Doreen)	SIPP, PDB	4'2.90	11	11	222360	
74	Import (Tripura)	Imported power	0	160	154	3486720	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	616900	
76	Jangalia 52 MW PP (Lakdanavi)	IPP	6'8.92	52	52	1238472	
77	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	20	514230	
78	Daokandi 200 MW PP (B.Trac)	IPP	154'1.4	200	30	46000	Low demand
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	64	351390	Engine problem
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	113	2397360	
81	Bhalol 54.5 MW	IPP	3'18.2	54	37	879120	Engine problem
Cumilla Area Total				3034	1655	40506641	
78	RPCL 210MW CCPP	IPP	4'36+1'70	202	160	4106640	Gas shortage
79	Tangal 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	346572	Engine problem
80	Rangpur 95 MW PP(Powerpac)	IPP	12'8.24	95	73	1605120	Engine problem
81	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	13100	
82	Mymensingh 200 MW PP (United)	IPP	200	200	178	1965600	Engine problem
83	Jamalpur 115 MW PP (United)	IPP	115 MW	115	115	2514000	
84	Sulakhali 50 MW Solar PP	IPP	50	50	0	355490	
85	Tangal Pali Power Gen 22 MW	IPP	4'6.7	22	24	4116960	
Mymensingh Area Total				709	570	11318122	
86	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	40	952000	Machine problem
87	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	42	1016760	Machine problem
88	Kushiarra 163 MW CCPP (KP)	IPP	1'109+1'54	163	163	3443727	
89	Shahjibazar 330 MW CCPP	PDB	3'110	330	332	7501000	
90	Fenchugonj 51 MW PP (Barakattallah)	RPP	19'2.35	51	53	1097400	
91	Fenchugonj 44MW (Energyprima)	RPP	12'3.3+5'2	0	0	0	Contract Expired
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	160500	
93	Shahjibazar GTPP Unit- 8 & 9	PDB	2'35	66	32	591648	GT-8 Under maint.
94	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	75	1667520	
95	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under Shut down
96	Sylhet 225 MW CCPP	PDB	1'142+1'189	114	106	3506410	Gas shortage
97	Sylhet 20 MW GTTP	PDB	1'20	20	18	386000	
98	Sylhet 50MW PP (EPL)	RPP	2'72	0	0	0	Contract Expired
99	Shahjahanuli 25 MW PP	SIPP, REB	9'3.34	25	8	272712	Engine problem
100	Bibiyana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	290	7403500	FGMO
101	Bibiyana-III 400 MW CCPP	PDB	400 MW	400	366	9083000	FGMO
102	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	8	188460	
103	Bibiyana South 400 MW	PDB	400 MW	383	370	9342900	FGMO
Sylhet Area Total				2377	1944	46620537	
102	Bheramara GTPP Unit-3	PDB	1'20	16	0	0	Reserve.
103	Bheramara (HVDC)	Imported power	2'500	1000	604	17737454	Baharampur Ckt-1 tripped at
104	Khulna 115 PP MW (KPCL-2)	QRPP	7'17	115	99	2316640	Engine problem
105	Faridpur 50 MW Peaking PP	PDB	8'6.89	54	20	127200	Engine problem
106	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	0	0	Reserve.
107	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	9472	Reserve.
108	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	405	9256320	FGMO
109	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5'8.5	40	32	403500	Engine problem
110	Noapara 100 MW CCPP (Bangla Trac)	IPP	70'1.4	100	98	841920	
111	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	92	1716000	Engine problem
112	Madhumati 100 MW PP	SWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1350	32308506	
112	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	96	616608	
113	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	33	629780	
114	Bhola 225 MW CCPP	PDB	2'63+1'168	194	65	1551000	Machine problem
115	Bhola 95 MW PP (Agreko)	QRPP	96'1.10	95	96	1396861	Gas shortage
116	Payra 1320 MW	BCPCL	2'622	1244	520	12729900	
117	Bhola Nutan Biddut BD LTD	IPP	220	0	107	2734282	On Test
118	United Payra Power Ltd.	IPP	8'18.5+1'9.5	150	0	0	Reserve.
Barisal Area Total				1828	917	19688431	
117	Baghabari 71 MW GTTP	PDB	1'171	71	0	0	Gas shortage
118	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage.
119	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	50	730556	
120	Bera 70 MW Peaking PP	PDB	9'8.29	71	40	196508	
121	Amnura 50 MW PP(Sinha)	QRPP	7'7.79	50	0	0	Fuel shortage
122	Katakhal 50 MW PP (Northern)	QRPP	6'8.9	50	43	107036	Engine problem
123	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'175	210	100	1972700	ST under S/D.
124	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'175	220	141	4246818	FGMO
125	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	170	4592173	FGMO
126	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1'282+1'132	414	412	9012236	FGMO
127	Santalara 50 MW Peaking PP	PDB	6'8.7	50	22	177144	Engine problem
128	Bogra 22 MW PP (GBB)	RPP	6'4	22	20	440400	
129	Bogra 20 MW PP (Energyprima)	RPP	5'3.3+5'2	0	0	0	Contract Expired
130	Ullapara 11 MW PP (Summit)	SIPP, REB	4'2.90	11	11	215262	
131	Natore 52 MW PP (Rajjanka)	IPP	6'8.92	52	49	1151040	
132	Chapanawabaganj 100 MW Peaking PP	PDB	12'8.924	104	80	861496	
133	Baghabari 200 MW PP (Paramount)	IPP	200 MW	200	0	0	Reserve.
134	Bagura 113 MW PP (Confidence)-2	IPP	113 MW	113	113	1670016	
135	Confidence Power Bogura Unit-1 113 MW	IPP	6'18.55	113	113	1498368	
Rajshahi Area Total				2173	1395	27177549	
136	Barapukuria TPP Unit-1	PDB	1'125	85	73	1789509	
137	Barapukuria TPP Unit-2	PDB</					