

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 29-Apr-21		Page - 2						
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks	
			Unit No. X Capacity	MW	MW	KWH		
1	Ghorasal Repowered CAPP Unit	PDB	1720	170	0	0	Under maint.	
2	Ghorasal Repowered CAPP Unit-5	PDB	1720	180	0	0	Under maint.	
3	Ghorasal 365 MW CAPP Unit-7	PDB	1'243+1'122	190	180	4348000		
4	Ghorasal 78.5 MW PPMAX	QRPP	2'40	365	0	0	Under maint.	
5	Ghorasal 108MW PP (Regen)	IPP	343.35	0	0	0	Contract Expired	
6	Haripur GTTP	SBU, PDB	2'32	108	102	2016681		
7	Haripur 412 MW CAPP	EGCB	1'273+1'139	20	0	0	Under maint.	
8	Haripur 360MW CAPP(HPL)	IPP	1'235+1'125	412	150	3936250	ST under maint & Gas short	
9	Meghnaghat 450 MW CAPP(MP)	IPP	2'150+1'150	360	146	4454000	Gas Shortage	
10	Meghnaghat 100 MW (EL)	QRPP	12'8.9	450	300	7135800	Gas shortage	
11	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	100	98	1434240		
12	Madanganj 102 PP(Summit)	QRPP	6'17	305	230	5732102	Gas shortage	
13	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	0	0	0	Contract Expired	
14	Keraniganj 100 MW PP (Powerpa)	QRPP	8'13.45	55	55	1260518		
15	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	100	100	921795		
16	210 MW Siddhirganj TPP	PDB	1210	22	22	459864		
17	Siddhirganj 2'120 MW GTTP	EGCB	2'105	115	0	0	Under maint.	
18	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12'8.9	210	180	3657000	Gas shortage	
19	Siddhirganj 335 MW CAPP	EGCB	1'217+1'118	100	100	1777219		
20	Gagnagar 102 MW PP (Digital Pa)	IPP	12'8.924	335	217	5024457	ST under maint.	
21	Katpott 52 MW PP (Sinha)	IPP	77.9	102	102	1475568		
22	Kamatnagar 54 MW PP(Banco E)	IPP	3'18	51	45	171504	Engine problem	
23	Kodda 150MW PP	BFDB-RPCL	9'17.06	54	35	718200	Engine problem	
24	Manikganj 55 MW PP (Northern)	IPP	3'19.3	149	150	1493760		
25	Nabaganj 55 MW PP (Southern)	IPP	3'19.3	55	55	795204		
26	Bosila 108MW PP(CLG)	IPP	12'8.775+1'3.5	55	55	1017115	Fuel shortage	
27	Summit Power, (Madhabadi+Ashul)	SIPP, REB	3'3.67+8'7.3	108	0	0	Engine problem	
28	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	80	53	1145220		
29	Ruganaj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	78520		
30	Gazipur 52 MW PP	IPP	6'8.9	33	33	680400		
31	Tongi 80 MW GTTP	PDB	1'105	52	49	708960		
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	1'105	0	0	Under maint.	
33	Keraniganj 300 MW PP (APR)	IPP	258'1.4	300	233	2910544	Engine problem	
34	Bramhanganj 100 MW PP (Agg)	IPP	100	300	225	475418	Low demand	
35	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	98	223155		
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	100	100	445502		
37	Gazipur 100 MW PP	RPCL	100 MW	149	149	3406320		
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'5	105	87	1877928	Engine problem	
39	Manikganj 162MW PP(MPCL)	IPP	9'18	104	90	1623360	Engine problem	
	Spectra Solar Plant Ltd.	IPP	35	162	144	2625100	Engine problem	
			35	35	0	225930		
	Dhaka area Total			5829	3616	64962654		
39	Chattogram TPP-1	PDB	1'210	180	100	2400000	Gas shortage.	
40	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage	
41	Raazan 25 MW PP	IPP	3'8.9	25	17	384557	Engine problem	
42	Teknaf 20MW PP (Solar) (Khatun Solartech Energy)	IPP	20	20	0	121500		
43	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	22	421920	Engine problem	
44	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	35	848000	Unit-2 under maint	
45	Sikalbaha 225MW	PDB	1'150+1'175	225	202	4798327	FGMO	
46	Sikalbaha Peaking GT	PDB	1'150	150	125	2777952	Gas shortage	
47	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	257163		
48	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	0		
49	Dohazari -Kalaish 100 MW Peak	PDB	6'17	102	85	1039189	Engine problem	
50	Juldah 100 MW Unit-1 (Acorn)	QRPP	8'13.45	100	10	256920	Fuel shortage	
51	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2314560		
52	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	21	498048		
53	Manircha, Ctg. EZZ	IPP	5'8.73+9.34	0	34	501690		
54	Chattogram 108 MW PP (ECPV)	IPP	6'7	108	60	786240	Engine problem	
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	34680		
56	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	0	0	Transformer O/L.	
57	Jodiak Power	IPP	3'18.55+1'3.6	54	54	1245102		
58	Karnaphuli Power Ltd.	IPP	110	110	34	412327	Transformer O/L.	
59	Juldah unit-2 (Acorn)	IPP	8'13.6	100	100	2427840		
60	Anlima Energy Ltd.	IPP	6'21.2	116	114	2064982		
	Chattogram area Total			2382	1218	25908907		
61	Ashuganj TPP Unit- 3	APSCL	1'150	135	0	0	Gas Shortage	
62	Ashuganj TPP Unit- 4	APSCL	1'150	129	0	0	Gas shortage	
63	Ashuganj TPP Unit- 5	APSCL	1'150	134	90	1993582	Gas shortage	
64	Ashuganj 225 MW CAPP	APSCL	1'144+1'75	221	196	4313000	Gas shortage	
65	Ashuganj 450 MW CAPP(North)	APSCL	1'360	360	275	7478500	FGMO	
66	Ashuganj 450 MW CAPP(South)	APSCL	1'360	330	330	6823000	FGMO	
67	Ashuganj 50 MW PP	APSCL	14'3.968	45	26	561672	Engine problem	
68	Ashuganj 55 MW PP (Precision)	RPP	154	55	25	1124160	Gas shortage	
69	Ashuganj 150MW PP (APCL-U)	IPP	20'37+1'16	195	8	234181	Gas shortage	
70	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1009119		
71	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	150	2087563		
72	Tilas 50 MW Peaking PP	PDB	6'8.92	52	48	147520		
73	Chandpur 150 MW CAPP	PDB	1'106+1'57	163	95	2225100	Gas shortage	
74	Chandpur 200MW (Desh energy)	IPP	0	200	140	3360480	Engine problem	
75	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	498836		
76	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	242100		
77	Impoort (Tripura)	Imported power	0	160	158	3474240		
78	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	818000		
79	Jangalia 52 MW PP (Lakdanavi)	IPP	6'8.92	52	52	1427208		
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	20	480100	Engine problem	
81	Cumilla 200 MW PP (B.Trac)	IPP	154'1.4	200	200	4739616		
82	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	1510500		
83	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	113	2516640		
84	Bhairab 54.5 MW	IPP	3'18.2	54	36	874440	Engine problem	
	Cumilla Area Total			3034	2192	43605557		
85	RPCL 210MW CAPP	IPP	4'35+1'70	202	147	3445400	Gas shortage	
86	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	17	353712		
87	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	81	1752960	Engine problem	
88	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	14950		
89	Mymensingh 200 MW PP (Unite)	IPP	200	200	194	2716800	Engine problem	
90	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	115	2402400		
91	Sutakhirali 50 MW Solar	IPP	50	50	0	358380		
92	Tangail Palli Power Gen 22 MW	IPP	4'6.7	22	24	429840		
	Mymensingh Area Total			709	578	11478502		
93	Fenchugonj CAPP Phase-1	PDB	2'32+1'33	70	43	745000	Machine problem	
94	Fenchugonj CAPP Phase-2	PDB	2'35+1'35	90	43	979920	Machine problem	
95	Kushkhara 163 MW CAPP (KP)	IPP	1'109+1'54	163	163	3607445		
96	Shahjibazar 330 MW CAPP	PDB	3'11.0	330	271	4933000	Machine problem	
97	Fenchugonj 51 MW PP (Barakat)	RPP	19'2.90	51	53	1137000		
98	Fenchugonj 44MW (Energyprim)	RPP	12'3.3+5'2	0	0	0	Contract Expired	
99	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	144000		
100	Shahjibazar GTTP Unit- 8 & 9	PDB	2'35	66	68	1450176		
101	Shahjibazar 80MW PP (Shahjiba)	RPP	32'2.90	86	75	1662720	Engine problem	
102	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under Shut down	
103	Sylhet 225 MW CAPP	PDB	1'142+1'89	231	218	5089250		
104	Sylhet 20 MW GTTP	PDB	1'20	20	17	402000		
105	Sylhet 50MW PP (EPL)	RPP	2'72	0	0	0	Contract Expired	
106	Shahjibazar 25 MW PP	SIPP, REB	3'9.34	25	16	333600	Engine problem	
107	Bibiana-II 341 MW CAPP (Summit)	IPP	1'122+1'119	341	270	7332600	FGMO	
108	Bibiyana-III 400 MW CAPP	PDB	400 MW	400	403	9077000	FGMO	
109	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	8	188100	Engine problem	
110	Bibiyana South 400 MW	PDB	400 MW	383	390	8828000	FGMO	
	Sylhet Area Total			2377	2049	45934711		
111	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Reserve.	
112	Bheramara (NWDCL)	Imported power	2'500	1000	918	2085090		
113	Khulna 115 PP MW (KPCL-2)	QRPP	7'17	115	83	1853760	Engine problem	
114	Fariapur 50 MW Peaking PP	PDB	8'6.89	54	19	138240	Engine problem	
115	Khulna 225 MW CAPP	NWPGCL	1'150+1'75	230	0	0	Reserve.	
116	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Reserve.	
117	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	180	5269536	Gas shortage	
118	Noapara 40 MW PP (Khanjahan)	QRPP	5'18.5	40	32	651375	Engine problem	
119	Noapara 100 MW PP (Bangla Tr)	IPP	70'1.4	100	100	534720		
120	Rupsha 105 MW PP (Orion rupa)	IPP	6'18.445	105	90	1623840	Engine problem	
121	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.	
	Khulna Area Total			2284	1422	30822380		
122	Bansail 110 MW PP (Summit)	IPP	7'17.076	110	110	1359456		
123	Bhola 33 MW PP (Doreen)	RPP	1'34.50	33	35	669226		
124	Bhola 225 MW CAPP	PDB	2'63+1'68	194	52	1567000	Machine problem	
125	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	95	96	2310999		
126	Payra 1320 MW	BCPCL	2'622	1244	600	13866400		
127	Bhola Nutan Biddut BD LTD	IPP	220	0	0	0	On Test	
128	Uniled Payra Power Ltd.	IPP	8'18.5+1'9.5	150	98	556800	Line O/L	
	Barisal Area Total			1826	982	20229881		
129	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage	
130	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage.	
131	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	50	580208		
132	Bera 70 MW Peaking PP	PDB	9'8.29	71	42	134625	Engine problem	
133	Amnara 50 MW PP(Sinha)	QRPP	7'7.79	50	0	102450	Low demand	
134	Katakhal 50 MW PP (Northern)	QRPP	6'8.9	50	43	137341	Engine problem	
135	Katakhal 50 MW Peaking PP	PDB	6'8.7	50	23	245705	Engine problem	
136	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'75	210	77	2280400	Gas shortage	
137	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'75	220	138	3973436	Gas shortage	
138	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	149	4022009	Gas shortage	
139	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1'282+1'132	414	414	9293636	FGMO	
140	Sanlahar 50 MW Peaking PP	PDB	6'8.7	50	33	201919	Engine problem	
141	Bogra 22 MW PP (GGB)	RPP	6'4	22	21	472800		
142	Bogra 20 MW PP (Energyprima)	RPP	5'3.3+5'2	0	0	0	Contract Expired	
143	Uliapara 11 MW PP (Summit)	SIPP, REB	4'2.90	11	11	164520		
144	Natore 52 MW PP (Rajshahi)	IPP	6'8.92	52	52	995040		
145	Chapainawabganj 100 MW Peak	PDB	12'8.924	104	96	836148		
146	Baghabari 200 MW PP (Paramo)	IPP	200 MW	200	20	39560	Low demand	
147	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	1498944		
148	Confidence Power Bogura Unit-1	IPP	6'18.55	113	113	1403328		
	R							