

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 30-Apr-21		Page - 2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
	Ghorasal Repowered CAPP Unit	PDB	1'210	170	0	0	Under maint.
	Ghorasal Repowered CAPP Unit	PDB	1'210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1'210	190	180	4284000	
2	Ghorasal 365 MW CAPP Unit-7	QRPB	1'243+1'122	365	0	0	Under maint.
3	Ghorasal 78.5 MW PPMAX	QRPB	2'40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regen)	IPP	343.35	108	102	2320909	
5	Haripur GTTP	SBU_PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	164	3909640	ST under maint & Gas short
7	Haripur 360MW CAPP(HPL)	IPP	1'235+1'125	360	171	4294000	Gas Shortage
8	Meghnaghat 450 MW CAPP(MP)	IPP	2'150+1'150	450	320	7418500	Gas shortage
9	Meghnaghat 100 MW (EEL)	QRPB	12'8.9	100	96	1601280	Gas shortage
10	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	305	230	5449745	
11	Madanganj 102 PP(Summit)	QRPB	6'17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	55	1326330	
13	Keraniganj 100 MW PP (Powerpa)	QRPB	8'13.45	100	50	435412	Low demand
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	409356	
15	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	180	3322000	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	QRPB	12'8.9	100	100	1866528	
18	Siddhirgonj 335 MW CAPP	EGCB	1'217+1'118	335	215	4929529	ST under maint.
19	Gagnagar 102 MW PP (Digital P)	IPP	12'8.924	102	93	1337040	Engine problem
20	Katpott 52 MW PP (Sinha)	IPP	7'7.9	51	0	0	Engine problem
21	Kamatnagar 54 MW PP(Banco E)	IPP	3'19	54	35	661200	Engine problem
22	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	82	941760	Engine problem
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	477938	
24	Nabaganj 55 MW PP (Southern)	IPP	3'19.3	55	55	1188125	
25	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	108	0	0	Fuel shortage
26	Summit Power, (Madhabdi+Ashul)	SIPP, REB	3'3.67+8'7.3	80	51	1053420	Engine problem
27	Machra 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	802800	
28	Ruganaj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	813200	
29	Gazipur 52 MW PP	IPP	6'8.9	52	41	382080	Engine problem
30	Tongi 80 MW GTTP	PDB	1'105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Sumr)	IPP	18'17.076	300	240	2536689	Engine problem
32	Keraniganj 300 MW PP (AFR)	IPP	25'11.4	300	70	180655	Low demand
33	Bramhanganj 100 MW PP (Agg)	IPP	100	100	0	0	Reserve.
34	Auraha 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Sumr)	IPP	149	149	149	3372770	
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	1938084	Engine problem
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'5	104	91	1783680	Engine problem
38	Manikganj 162MW PP(MPCL)	IPP	9'18	162	144	2486880	Engine problem
	Spectra Solar Plant Ltd.	IPP	35	35	0	223589	
Dhaka area Total			5829	3162	61749059		
39	Chattogram TPP-1	PDB	1'210	180	100	2400000	Gas shortage.
	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
	Raozan 25 MW PP	IPP	3'8.9	25	17	349993	Engine problem
41	Teknaf 20MW PP (SolarTech)Khat SolarTech Energy	IPP	20	20	0	134460	
42	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	50	371520	
43	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	35	824000	Unit-2 under maint
44	Sikalbaha 225MW	PDB	1'150+1'175	225	220	4974054	FGMO
45	Sikalbaha Peaking GT	PDB	1'150	150	125	2899628	Gas shortage
46	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	2170208	
47	Hathazari 100 MW peaking PP	PDB	1'18.9	98	0	0	
48	Dohazari -Kalaish 100 MW Peak	PDB	6'17	102	85	712209	Engine problem
49	Juldah 100 MW Unit-1 (Acorn)	QRPB	8'13.45	100	10	257400	Fuel shortage
50	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1895040	
51	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	21	501984	
	Malancha, Ctg. EZZ	IPP	5'8.73+9.34	0	40	667680	
52	Chattogram 108 MW PP (ECPV)	IPP	6'7	108	90	818880	Engine problem
53	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	29160	
54	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	0	0	Transformer O/L.
55	Jodiak Power	IPP	3'18.55+1'3.6	54	54	1295883	
56	Karnaphuli Power Ltd.	IPP	110	110	17	196217	Transformer O/L.
57	Juldah unit-2 (Acorn)	IPP	8'13.6	100	100	1849920	
	Anlima Energy Ltd.	IPP	6'21.2	116	116	1767655	
Chattogram area Total			2382	1285	24123861		
58	Ashuganj TPP Unit- 3	APSCL	1'150	135	0	0	Gas Shortage
	Ashuganj TPP Unit- 4	APSCL	1'150	129	0	0	Gas shortage
	Ashuganj TPP Unit- 5	APSCL	1'150	134	90	2133634	Gas shortage
59	Ashuganj 225 MW CAPP	APSCL	1'144+2'175	221	158	4675000	Gas shortage
60	Ashuganj 450 MW CAPP(North)	APSCL	1'360	360	350	7154500	FGMO
61	Ashuganj 450 MW CAPP(South)	APSCL	1'360	360	305	6751000	FGMO
62	Ashuganj 50 MW PP	APSCL	14'3.968	45	26	590256	Engine problem
63	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	25	571200	Gas shortage
64	Ashuganj 150MW PP (APCL-U)	IPP	20'37+1'116	195	8	217454	Gas shortage
65	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1169392	
66	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	150	2530836	
67	Tilas 50 MW Peaking PP	PDB	6'8.92	52	0	169760	Reserve.
68	Chandpur 150 MW CAPP	PDB	1'106+1'57	163	95	2207740	Gas shortage
69	Chandpur 200MW (Desh energy)	IPP	0	200	158	3774240	Engine problem
70	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	477972	
71	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	208800	
	Impopr (Tripura)	Imported power	0	160	164	3185280	
72	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	817700	
73	Jangalia 52 MW PP (Lakdanavi)	IPP	6'8.92	52	38	1206307	Engine problem
74	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	20	496610	Engine problem
75	Katakhal 200 MW PP (B.Trac)	IPP	15'41.4	200	0	0	Reserve.
76	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	769500	
77	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	113	2508240	
	Bhairab 54.5 MW	IPP	3'18.2	54	36	820080	33 kV Feeder fault
Cumilla Area Total			3034	1964	42435901		
78	RPCL 210MW CAPP	IPP	4'35+1'170	202	152	3530520	Gas shortage
79	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	17	393948	
80	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	82	1735680	Engine problem
81	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	13650	
82	Mymensingh 200 MW PP (Unite)	IPP	200	193	2433600	Engine problem	
83	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	115	2410800	
84	Sutakhir 50 MW Solar PP	IPP	50	50	0	284020	
85	Tangail Palli Power Gen 22 MW	IPP	4'6.7	22	24	570960	
Mymensingh Area Total			709	583	11373778		
86	Fenchugonj CAPP Phase-1	PDB	2'32+1'33	70	44	1025000	Machine problem
87	Fenchugonj CAPP Phase-2	PDB	2'35+1'35	90	41	964920	Machine problem
88	Kushkhara 163 MW CAPP (KP)	IPP	1'109+1'54	163	163	3353400	
89	Shahjibazar 330 MW CAPP	PDB	3'110	330	271	6215000	
90	Fenchugonj 51 MW PP (Barakat)	RPP	19'2.90	51	53	1208400	
91	Fenchugonj 44MW (Energyprim)	RPP	12'3.3+5'2	0	0	0	Contract Expired
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	130000	
93	Shahjibazar GTTP Unit- 8 & 9	PDB	2'35	66	63	1570944	
94	Shahjibazar 80MW PP (Shahjiba)	RPP	32'2.90	86	78	1819200	Engine problem
95	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under Shut down
96	Sylhet 225 MW CAPP	PDB	1'142+1'89	231	224	4924800	
97	Sylhet 20 MW GTTP	PDB	1'20	20	17	406000	
98	Sylhet 50MW PP (EPL)	RPP	2'72	0	0	0	Contract Expired
99	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	332280	Engine problem
100	Bibiana-II 341 MW CAPP (Summ)	IPP	1'122+1'119	341	320	7151500	FGMO
101	Bibiyana-III 400 MW CAPP	PDB	400 MW	400	403	9475000	FGMO
102	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	8	197460	Engine problem
	Bibiyana South 400 MW	PDB	400 MW	383	393	8784800	FGMO
Sylhet Area Total			2377	2105	47588704		
102	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Reserve.
	Bheramara (NWDCL)	Imported power	2'500	1000	917	22147636	
103	Khulna 115 PP MW (KPCL-2)	QRPB	7'17	115	99	1800240	Engine problem
104	Fariapur 50 MW Peaking PP	PDB	8'6.89	54	18	184800	Engine problem
105	Khulna 225 MW CAPP	NWPGCL	1'150+1'75	230	0	0	Reserve.
106	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Reserve.
107	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	190	4894848	Gas shortage
108	Noapara 40 MW CAPP (Khanjahan)	QRPB	5'18.5	40	32	235815	Engine problem
109	Noapara 100 MW PP (Bangla Tr)	IPP	70'1.4	100	100	465600	
110	Rupsha 105 MW PP (Orion rups)	IPP	6'18.445	105	91	1440960	Engine problem
111	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total			2284	1447	31259959		
112	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	110	1516896	
113	Bhola 33 MW PP (Doreen)	RPP	1'34.50	33	35	647150	
114	Bhola 225 MW CAPP	PDB	2'63+1'68	194	60	1471000	Machine problem
115	Bhola 95 MW PP (Aggreko)	QRPB	96'1.10	95	96	2319888	
116	Payra 1320 MW	BCPCL	2'622	1244	590	13714700	
	Bhola Nutan Biddut BD LTD	IPP	220	0	0	0	On Test
	Uniled Payra Power Ltd.	IPP	8'18.5+1'9.5	150	88	738000	Line O/L
Barisal Area Total			1826	980	20407684		
117	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage.
118	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	50	814593	
	Bera 70 MW Peaking PP	PDB	9'8.29				