

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month May, 2021		Day : Saturday							Date : 01.05.21			
Probable Maximum Demand :		11800 MW		Probable Maximum Generation :							15732 MW	
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 76.93 ft		Today = 76.67 ft.				Rule Curve = 82.20 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.04.21 (Yesterday)		01.05.21 (Today)		30.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	a) Ghorasal Repowered CCGP Unit-3	Gas (PDB)	1 x 210	210	170	0	0	0	0		170	Under Repowering
	b) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering
	c) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
2	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.
3	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	102	100	102			
4	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem
5	Hariपुर GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		20	Under Maint.
6	Hariपुर 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	185	171	360	360		189	Gas Shortage
7	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	320	320	320	320		130	Gas Shortage
8	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
9	Hariपुर 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	156	164	165	255		248	Dirt in gas
10	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	115	180	180	180		30	Gas Shortage
11	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	180	215	200	200		120	ST under maint.
12	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100			
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	235	230	250	250		75	dirt in gas
14	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	100	60	96	100	100			
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	50	100	100			
17	Gagnagar 102 MW PP (Digital Powe)	HFO (IPP)	12x8.924	102	102	32	93	102	102			
18	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22			
19	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	51	50	50			
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
21	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	41	52	52			
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	86	105	105	105			
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	82	150	150			
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
26	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	35	35			
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	240	250	250			
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	145	149	149	149			
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	70	100	300			
30	Bramhangaoan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
31	Aurahati 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100			
32	Nabaganj 55 MW PP (Southern po)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55			
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	91	90	90			
36	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	144	162	162			
37	Manikgonj 35MW Solar PP (Inspectr)	Solar (IPP)	1x35	35	35	31	0	30	0			
Dhaka Zone Total				6026	5829	2378	3162	3683	4045	672	1075	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	35	35	25	25		195	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	43	43			
44	Sikalbaha 105 MW PP (Baraka Sika)	HFO (IPP)	6x18.415	105	105	90	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	115	125	125	125			
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	205	220	230	230			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300			
48	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	10	10	10	10			
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	100	100	100			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	85	85			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22			
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	40	40	40			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	90	90	90			
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	17	110	110			
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
57	Chattogram 116 MW PP (Anlima En)	HFO (IPP)	6x21.06	116	116	35	116	116	116			
Chattogram Zone Total				2442	2382	885	1285	1697	1672	195	180	
58	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0		135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0		129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	90	90	90	90		44	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	193	158	225	225			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	275	305	330	330			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	280	350	330	340			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	25	25	25	25			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8		187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	70	150	100	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
68	Chandpur 150 MW CCGP	Gas (PDB)	1x106+1x57	163	163	94	95	0	0		68	Gas Shortage
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	158	158	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	20	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	10	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	38	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+40x1.515+15x1.056	200	200	0	0	100	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	114	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	110	113	113	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	36	36	36			
**	Impopri (Tripura)	India		160	160	124	164	157	179			
Cumilla Zone Total				3094	3034	1638	1964	2043	2275	563	0	
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	142	152	200	200		50	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	17	20	20			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	73	82	81	81			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	193	200	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	38	0	50	0			
86	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22			

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.04.21 (Yesterday)		01.05.21 (Today)		30.04.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	43	43		26	Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	41	0	0		49	Under maint.	
89	Fenchugonj 51 MW PP (Barakatulla)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	63	66	66				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	267	271	162	162				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	78	76	76				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	218	224	225	225				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	320	341	341				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	403	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	360	393	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total				2422	2377	1995	2105	1982	1982	0	75		
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	16				
104	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	200	190	320	320	220		Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	3	18	20	20				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	0	0	0	220				
108	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	99	99	99				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	32	32	33				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	91	90	91				
112	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	917	917	933	933				
Khulna Zone Total				2288	2284	1256	1447	1704	1992	220	0		
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110				
114	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	35	33	33				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	60	66	67		134	GT-2 & STG Under maint.	
116	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	96	96	95	95				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	490	590	622	622				
118	Potuahali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	89	80	90				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0				
Barishal Zone Total				1826	1826	671	980	1006	1017	0	134		
119	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
120	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	20	50	50	50				
121	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
122	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	45				
123	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	42	42	42				
124	Chapainawabganj 100 MW Peaking	HFO (PDB)	12x8.924	104	104	0	97	100	100				
125	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	30				
126	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	43	43				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	42	0	32				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	85	84	100	100	66		Gas Shortage	
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150 + 1x75	220	220	157	153	200	200	67		Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	169	171	200	200				
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	340	414	400	400				
132	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	22	22				
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
135	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	113	113	113				
136	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	113	113	113				
Rajshahi Zone Total				2173	2173	888	1427	1716	1753	304	0		
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	73	73	75	75	12		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	101	113	113	113				
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Majpara, Tatulia 8 MW Solar PP (Sympha Po.)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total				685	605	330	336	346	358	221	0		
Sub-total: Plants in operation				21673	21219	10454.0	13289	14867	15732	2225	1464		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						9877	12555	14045	14863				
(B) Plants under long term maintenance/ contract expired													
143	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
146	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
147	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired				294	0	0	0	0	0				
Gross Total				21967	21219	10454	13289	14867	15732	2225	1464		
(C) Actual data of 30.04.21 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	13289.00	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12555.00	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13289.00	MW, at =	21:00 hrs	Dhaka	4154	4154	0	Mymensingh	1073	1073	0
04.	Minimum Generation (Generation end)	:	9396.00	MW, at =	9:00 hrs	Chattogram	1337	1337	0	Sylhet	504	504	0
05.	Day-peak Generation (Generation end)	:	10454.00	MW, at =	12:00 hrs	Khulna	1622	1622	0	Barishal	404	404	0
06.	Evening-peak Generation (Generation end)	:	13289.00	MW, at =	21:00 hrs	Rajshahi	1373	1373	0	Rangpur	789	789	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Cumilla	1299	1299	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8081.00	MW, at =	5:00 hrs	Total				12555	12555	0	
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 169837094 Taka	(c) Coal = 90716179 Taka				
	a) Gas limitation	:	1809	MW			(b) Oil = 536271958 Taka	Total = 796825232 Taka					
	d) Coal supply Limitation	:	221	MW									
	b) Low water level in Kaptai lake	:	195	MW									
	c) Plants under shut down/ maintenance	:	1464	MW		14.	Maximum Temperature in Dhaka was :	37.2° C					
10.	Total Energy (Generation + India Import)	:	273.42	MKWh		15.	Export through East-West interconnections :						
	By Gas = 153.458 MKWh			By Oil = 73.931 MKWh			At evening peak-hour	:-268 MW, at		21:00 hrs			
	By Coal = 19.145 MKWh			By Hydro = 0.824 MKWh			Maximum	:-300 MW, at		22:00 hrs			
	By Solar = 0.732 MKWh						Energy	: 0.3635		MKWh			
11.	Total Gas Supplied	:	1285.02	MMCFD									
(D) Forecast of 01.05.21 (Today) Saturday :													
01.	Maximum Demand	:	11800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15732	MW	(Generation end)	05.	Total Generation	:	242.79	MKWh			
03.	Maximum Shortage	:	-3932	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	38.6° C				

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation