

**EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : 15-May-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
			Unit No. X Capacity	MW	MW	KWH	
	Ghorasal Repowered CAPP Unit	PDB	170	170	0	0	Under maint.
	Ghorasal Repowered CAPP Unit	PDB	1210	180	0	0	Under maint.
	Ghorasal TPP Unit-5	PDB	1210	190	180	3433500	
2	Ghorasal 365 MW CAPP Unit-7	PDB	1243+1122	365	0	0	Under maint.
	Ghorasal 78.5 MW PPMAX	QRPP	240	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regen)	IPP	343.35	108	104	1644500	
5	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
6	Haripur 412 MW CAPP	EGCB	1273+1139	412	333	8221350	FGMO
7	Haripur 360MW CAPP(HPL)	IPP	1235+1125	360	353	7348000	
8	Meghnaghat 450 MW CAPP(MP)	IPP	2150+1150	450	280	6639250	Gas shortage
9	Meghnaghat 100 MW (EL)	QRPP	128.9	100	0	0	Contract Expired
10	Meghnaghat CAPP(Summit)	IPP	2110+1110	305	240	5828451	FGMO
11	Madanganj 102 PP(Summit)	QRPP	617	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	(IPP)	317.08+111.3	55	15	256644	Low demand
13	Keraniganj 100 MW PP (Powerpa)	QRPP	813.45	100	0	0	Reserve.
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	82.90	22	0	266616	Engine problem
15	210 MW Siddhirganj TPP	PDB	1210	115	0	0	Under maint.
16	Siddhirganj 2120 MW GTPP	EGCB	2105	210	185	2973000	FGMO
17	Siddhirganj 100 PP(Dutch Bangla)	QRPP	128.9	100	0	88080	Reserve.
18	Siddhirganj 335 MW CAPP	EGCB	1217+118	335	170	4280929	Bad weather
19	Gagnagar 102 MW PP (Digital P)	IPP	128.924	102	0	47376	Reserve.
20	Katpott 52 MW PP (Sinha)	IPP	77.9	51	0	0	Fuel shortage
21	Kamatnagar 54 MW PP(Banco E	IPP	319	54	0	62280	Reserve.
22	Kodda 150MW PP	BFDB-RPCL	917.06	149	0	0	Reserve.
23	Manikganj 55 MW PP (Northern)	IPP	319.3	55	0	0	Reserve.
24	Nababganj 55 MW PP (Southern)	IPP	319.3	55	0	182944	Reserve.
25	Bosila 108MW PP(CLG)	IPP	128.75+13.5	108	0	0	Fuel shortage
26	Summit Power(Madhab+Ashul)	SIPP,REB	33.67+48.73	80	30	664260	Engine problem
27	Machra 33 MW PP(Summit)	SIPP,REB	48.73	33	20	587500	Engine problem
28	Ruganaj 33 MW PP(Summit)	SIPP,REB	48.73	33	25	523300	Engine problem
29	Gazipur 52 MW PP	IPP	68.9	52	0	0	Reserve.
30	Tongi 80 MW GTPP	PDB	1105	105	0	0	Under maint.
31	Kodda 300 MW PP Unit-2 (Sumr	IPP	1817.076	300	0	0	Reserve.
32	Keraniganj 300 MW PP (AFR)	IPP	2581.4	300	0	0	Reserve.
33	Bramhangganj 100 MW PP (Agg	IPP	100	100	0	0	Reserve.
34	Aurahati 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	0	0	Reserve.
35	Kodda 149 MW PP Unit-1 (Sumr	IPP	149	149	16	242784	Low demand
36	Gazipur 100 MW PP	RPCL	100 MW	105	0	0	Reserve.
37	Meghnaghat 104 MW PP (OPCL	IPP	18.53	104	0	144000	Reserve.
38	Manikganj 162MW PP(MPCL)	IPP	918	162	0	122400	Reserve.
	Spectra Solar Plant Ltd.	IPP	35	35	0	238246	
<b>Dhaka area Total</b>				<b>5829</b>	<b>1951</b>	<b>43795410</b>	
39	Chattogram TPP-1	PDB	1210	180	0	0	Under maint.
40	Chattogram TPP-2	PDB	1210	180	0	0	Gas shortage
41	Raozan 25 MW PP	IPP	38.9	25	17	408969	Engine problem
42	Tokrai 20MW PP (SolarTech)Khaif	SolarTech Energy	20	20	0	124200	
43	Patenga 50MW PP (Baraka)	IPP	86.98	50	0	0	Reserve.
44	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	240+350	230	23	472080	Unit-2 under maint
45	Sikalbaha 225MW	PDB	1150+1175	225	205	4891484	FGMO
46	Sikalbaha Peaking GT	PDB	1150	150	130	2777586	
47	Sikalbaha 105 MW PP (Baraka S	IPP	105 MW	105	34	518545	Low demand
48	Hathazari 100 MW peaking PP	PDB	118.9	98	0	0	
49	Dohazari-Kalaish 100 MW Peak	PDB	617	102	68	410678	Engine problem
50	Juldah 100 MW Unit-1 (Acorn)	QRPP	813.45	100	100	1413840	
51	Juldah 100 MW PP Unit-3 (Acorn	IPP	0	100	10	641280	Low demand
52	Barabkunda 22 MW PP (Regent	SIPP, PDB	82.90	22	19	500160	
	Malancha, Cg. E2	IPP	58.72+19.34	0	42	1118400	
53	Chattogram 108 MW PP (ECPV)	IPP	67	108	0	0	Reserve.
54	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	35160	
55	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	0	0	Reserve.
56	Jodiak Power	IPP	318.55+13.6	54	54	981639	
57	Karnaphuli Power Ltd.	IPP	110	110	0	0	Reserve.
58	Juldah unit-2 (Acorn)	IPP	813.6	100	10	398520	Low demand
59	Anlima Energy Ltd.	IPP	621.2	116	0	0	Reserve.
<b>Chattogram area Total</b>				<b>2382</b>	<b>712</b>	<b>14689541</b>	
60	Ashuganj TPP Unit- 3	APSCL	1150	135	0	0	Gas Shortage
61	Ashuganj TPP Unit- 4	APSCL	1150	129	0	0	Gas shortage
62	Ashuganj TPP Unit- 5	APSCL	1150	134	80	1923456	Gas shortage
63	Ashuganj 225 MW CAPP	APSCL	1142+175	221	191	4891484	FGMO
64	Ashuganj 450 MW CAPP(North)	APSCL	1360	360	280	7049000	FGMO
65	Ashuganj 450 MW CAPP(South)	APSCL	1360	360	285	6793000	FGMO
66	Ashuganj 50 MW PP	APSCL	143.968	45	26	539928	Engine problem
67	Ashuganj 55 MW PP (Precision)	RPP	154	55	5	536160	Gas shortage
68	Ashuganj 195MW PP (APSCL-U)	IPP	2037+1116	195	6	963272	Gas shortage
69	Ashuganj 51 MW PP (Midland)	IPP	69.34	51	51	485088	Gas shortage
70	Ashuganj 150MW PP (Midland)	IPP	237.015	150	0	95345	Reserve.
71	Tilas 50 MW Peaking PP	PDB	68.92	52	0	0	Reserve.
72	Chandpur 150 MW CAPP	PDB	1106+157	163	88	2113070	Machine problem
73	Chandpur 200MW (Desh energy)	IPP	0	200	51	2011180	Low demand
74	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	22	498960	
75	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	0	147420	
76	Impopr (Tripura)	Imported power	0	160	74	2689920	Bad weather
77	Jangalia 33MW PP (Summit)	SIPP, PDB	48.73	33	15	752600	
78	Jangalia 52 MW PP (Lakdanavi)	IPP	68.92	52	6	475094	Low demand
79	Cumilla 25 MW PP (Summit)	SIPP, PDB	33.67+26.97	25	16	435820	Engine problem
80	Baidyandi 200 MW PP (B. Trac)	IPP	1541.4	200	0	0	Reserve.
81	Feni Lanka Power	IPP	718.415+19.78	114	0	0	Reserve.
82	Chowmuhani 113 MW	IPP	129.78+23.1	113	36	671160	Low demand
83	Bhairab 54.5 MW	IPP	318.2	54	17	437760	Low demand
<b>Cumilla Area Total</b>				<b>3034</b>	<b>1283</b>	<b>3297073</b>	
84	RPCL 210MW CAPP	IPP	435+1170	202	207	4671960	
85	Tangail 22 MW PP (Doreen)	SIPP, PDB	82.90	22	19	279576	Engine problem
86	Jamalpur 95 MW PP(Powerpac)	IPP	128.924	95	65	1008960	Engine problem
87	Sarishabari 3 MW Solar Plant	IPP	13	3	0	12650	
88	Mymensingh 200 MW PP (Unite	IPP	200	200	0	16800	Reserve.
89	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	75	1000800	Low demand
90	Sutakhir 50 MW Solar PP	IPP	50	50	0	328560	
91	Tangail Pali Power Gen 22 MW	IPP	46.7	22	5	92880	Low demand
<b>Mymensingh Area Total</b>				<b>709</b>	<b>371</b>	<b>7404476</b>	
92	Fenchugonj CAPP Phase-1	PDB	232+133	70	0	358000	Machine problem
93	Fenchugonj CAPP Phase-2	PDB	235+135	90	42	978720	Machine problem
94	Kushkhara 163 MW CAPP (KP)	IPP	1109+154	163	163	3492655	
95	Shahjibazar 330 MW CAPP	PDB	3110	330	332	7331085	
96	Fenchugonj 51 MW PP (Barakat	RPP	192.90	51	52	816000	
97	Fenchugonj 44MW (Energyprim	RPP	123.3+52	0	0	0	Contract Expired
98	Hobiganj 11MW PP Confidence-E	SIPP, REB	42.90	11	11	247000	
99	Shahjibazar GTPP Unit- 8 & 9	PDB	235	66	51	1130880	
100	Shahjibazar 80MW PP (Shahjiba	RPP	322.90	86	78	1123200	Engine problem
101	Shahjibazar 100 MW GTPP	PDB	1100	100	0	0	Under Shut down
102	Sylhet 225 MW CAPP	PDB	1142+1189	231	223	4679000	
103	Sylhet 20 MW GTPP	PDB	120	20	18	415000	
104	Sylhet 50MW PP (EPL)	RPP	272	0	0	0	Contract Expired
105	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	16	366528	Engine problem
106	Bibiana-II 341 MW CAPP (Summ	IPP	1222+1119	341	0	116500	Under shut down due to gas
107	Bibiyana-III 400 MW CAPP	PDB	400 MW	400	388	4194000	FGMO
108	Sylhet 10MW PP (Desh)	RPP	61.95	10	7	122940	Engine problem
109	Bibiyana South 400 MW	PDB	400 MW	383	96	1572500	ST Synchronization process
<b>Sylhet Area Total</b>				<b>2377</b>	<b>1477</b>	<b>26943923</b>	
110	Bheramara GTPP Unit-3	PDB	120	16	0	0	
111	Bheramara (NWDCL)	Imported power	21500	1000	727	15752727	
112	Khulna 115 PP MW (KPCL-2)	QRPP	717	115	99	1217280	Engine problem
113	Fariapur 50 MW Peaking PP	PDB	86.89	54	0	0	Reserve.
114	Khulna 225 MW CAPP	NWPGCL	1150+1175	230	0	0	Reserve.
115	Gopalganj 100 MW Peaking PP	PDB	166.98	109	0	0	Reserve.
116	Bheramara 410 MW CAPP	NWPGCL	1278+1132	410	350	8637408	Gas shortage
117	Noapara 40 MW PP (Kharjahan	IPP	518.5	40	33	168875	Engine problem
118	Noapara 100 MW PP (Bangla Tr	IPP	701.14	100	0	0	Reserve.
119	Rupsha 105 MW PP (Orion rupa	IPP	618.445	105	17	252000	Low demand
120	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
<b>Khulna Area Total</b>				<b>2284</b>	<b>1226</b>	<b>26026290</b>	
121	Barisal 110 MW PP (Summit )	IPP	717.076	110	48	499300	Low demand
122	Bhola 33 MW PP (Doreen)	RPP	134.50	33	34	630963	
123	Bhola 225 MW CAPP	PDB	263+1168	194	88	2068707	Machine problem
124	Bhola 95 MW PP (Aggreko)	QRPP	961.10	95	94	1794218	
125	Payra 1320 MW	BCPCL	2622	1244	380	9900400	Bad weather
126	Bhola Nutan Biddut BD LTD	IPP	220	0	0	0	On Test
127	Uniled Payra Power Ltd.	IPP	818.5+19.5	150	0	0	Reserve.
<b>Barisal Area Total</b>				<b>1826</b>	<b>644</b>	<b>14893618</b>	
128	Baghabari 71 MW GTPP	PDB	171	71	0	0	Gas shortage
129	Baghabari 100 MW GTPP	PDB	1100	100	0	0	Gas shortage.
130	Baghabari 50 MW Peaking PP	PDB	68.9	52	0	0	Reserve.
131	Bera 70 MW Peaking PP	PDB	98.29	71	0	0	Reserve.
132	Annara 50 MW PP(Sinha)	QRPP	77.79	50	0	0	Reserve.
133	Katakhal 50 MW PP (Northern)	QRPP	68.9</				