

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 956467, 9551095

Month May, 2021		Day : Tuesday		Date : 18.05.21							
Probable Maximum Demand : 13000 MW		Yesterday = 75.18 ft		Today = 75.07 ft		Probable Maximum Generation : 15278 MW		Rule Curve = 78.77 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.05.21 (Yesterday)		18.05.21 (Today)		17.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Water/Coal limitation (MW)	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	100	100		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	102	100	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	304	347	360	360		
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	290	290	290	290	160	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	336	332	350	360	80	Dirty in gas
11	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	95	175	150	175	35	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	180	217	220	220	118	ST Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	40	40	100	100		
14	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	275	260	260	260	45	dirty in gas
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	0	0		
16	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55		
17	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
18	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	102	102		
19	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	0	15	15		
20	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	28	33	42	42		
21	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	25	25	25		
22	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25		
23	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	25	42	42		
24	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	50	105	105		
25	Kodda 150MW PP	HFO (B/PDB-RPCL)	9x17.06	149	149	0	32	150	150		
26	Katpott 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
27	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	25	35	35		
28	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	250	250		
29	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	100	128	132	132		
30	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300		
31	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
32	Aurshahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	100		
33	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	4	55	55		
34	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55		
35	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
36	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	35	91	90	90		
37	Manikgonj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	17	54	162	162		
38	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	32	0	30	0		
Dhaka Zone Total			6076	5919	2143	2490	3600	3905	320	1163	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	23	21	22	22	209	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
43	Taknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	20	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	12	12	43	43		
45	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	41	105	105	105		
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	110	110	110	110		
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	206	204	225	225		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300		
49	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	92	100	100	100		
50	Juddah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	85	85		
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	22	22		
**	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	37	10	30		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	90	90		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	35	54	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	110	110		
57	Juddah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100		
58	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	95	116	116		
Chattogram Zone Total			2442	2382	774	1072	1634	1629	209	360	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	125	120	100	120	14	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	26	26	26		
61	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+175	221	221	136	142	140	140		
62	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	285	275	330	330		
63	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	290	290	330	330		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	51	55	55	55		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	45	8	45	45	187	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	43	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	30	150	150		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	91	87	90	92	76	Gas Shortage
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	102	120	120	120		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11		
73	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	42	43	43	43		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	20	20	20		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x14+8x1.515+15x1.058	200	200	0	0	100	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	35	114	114		
78	Chowmahani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	26	113	113	113		
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	36	35	35		
**	Impport (Tripura)	India		160	160	130	156	145	179		
Cumilla Zone Total			3094	3034	1480	1670	2073	2279	541	0	
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	199	208	200	200		
81	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19		
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	64	64	65	65		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	45	64	115	115		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	22	200	200		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
86	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	38	0	50	0		
87	Tangali 22 MW PP(RPGL)	HFO (IPP)	4x6.7	22	22	13	10	22	22		
Mymensingh Zone Total			717	709	379	438	673	621	0	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.05.21 (Yesterday)		18.05.21 (Today)		17.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation (MW)	Machines shut down (MW)			
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	16	0	30		54	Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	41	0	42		49	Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	49	53	51	51				
91	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	45	51	51				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	320	328	330	330				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	71	78	75	75				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	217	217	225	225				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	7	7				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
100	Bihiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Under maint.	
101	Bityana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	348	365	400	400				
102	Bityana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	394	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1687	1758	1747	1819	0	444	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	370	340	350	350		70	Gas Shortage	
106	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	66	99	99	99				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	4	50	100				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	32	32	32				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	105	90	90				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	15	100	100				
**	Bheramara (HVDC)	India		1000	1000	821	821	859	859				
Khulna Zone Total					2288	2284	1257	1416	1660	1930	70	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	110	110				
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	23	34	33	33				
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	84	86	88	88		108	GT-2 & STG Under maint.	
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	93	95	95	95				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	400	560	622	622				
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	58	0	80				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0				
Barishal Zone Total					1826	1826	616	943	948	1028	0	108	
120	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	40				
124	Ammura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42				
125	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	98	100	100				
126	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	30				
127	Katakhalai 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
128	Santihar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	32				
129	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	120	113	140	140		37	Gas Shortage	
130	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	160	153	200	200		67	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	185	174	200	200				
132	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	401	377	400	400				
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	18	18	18				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
135	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	25	43	52	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	0	35	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	70	113	113				
138	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	0	0	0	0				
Rajshahi Zone Total					2179	2179	916	1142	1752	1784	275	0	
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150		124	Coal Shortage	
141	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	34	113	113	113				
143	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
144	Majpara, Tutula 8 MW Solar PP (Sypsa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total					685	605	190	263	271	283	294	0	
Sub-total: Plants in operation					21729	21315	9442.0	11192	14358	15278	1709	2075	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							9045	10721	13753	14635			
(B) Plants under long term maintenance/ contract expired													
145	Ghorashal 78.5 MW PP (MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
146	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
147	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
148	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired													
Gross Total					22023	21315	9442	11192	14358	15278	1709	2075	

(C) Actual data of 17.05.21 (Yesterday) Monday :					Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
Sl. No.	Parameter	Value	Unit	Time	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
01.	Max. Demand at eve. peak (Generation end)	11192.00	MW	at = 21:00 hrs	12.	Dhaka	3310	3510	0	Mymensingh	753	753	0
02.	Max. Demand at eve. peak (Sub-station end)	10721.00	MW	at = 21:00 hrs		Chattogram	1256	1256	0	Sylhet	427	427	0
03.	Highest Generation (Generation end)	11491.00	MW	at = 23:00 hrs		Khulna	1398	1398	0	Barishal	401	401	0
04.	Minimum Generation (Generation end)	8256.00	MW	at = 8:00 hrs		Rajshahi	1145	1145	0	Rangpur	752	752	0
05.	Day-peak Generation (Generation end)	9442.00	MW	at = 12:00 hrs		Cumilla	1279	1279	0				
06.	Evening-peak Generation (Generation end)	11192.00	MW	at = 21:00 hrs									
07.	Evening Peak Load-shed (Sub-station end)	0.00	MW	at = 21:00 hrs									
08.	Minimum Generation Forecast up to 8:00 hrs.	8788.00	MW	at = 5:00 hrs									
09.	Generation shortfall at evening peak due to :												
	a) Gas limitation	1206	MW		13.	Fuel cost :	(a) Gas = 167044053	Taka	(c) Coal = 71884821	Taka			
	d) Coal supply Limitation	294	MW				(b) Oil = 326176580	Taka	Total = 565105454	Taka			
	b) Low water level in Kaptai lake	209	MW										
	c) Plants under shut down/ maintenance	2075	MW		14.	Maximum Temperature in Dhaka was :			36.7° C				
10.	Total Energy (Generation + India Import)	239.39	MKWh		15.	Export through East-West interconnections :							
	By Gas = 153.290	MKWh	By Oil = 45.395	MKWh		At evening peak-hour	-48	MW	at 21:00 hrs				
	By Coal = 15.513	MKWh	By Hydro = 0.492	MKWh		Maximum	-168	MW	at 1:00 hrs				
	By Solar= 0.710	MKWh				Energy	0.939	MKWh					
11.	Total Gas Supplied	1265.78	MMCFD										

(D) Forecast of 18.05.21 (Today) Tuesday :									
01.	Maximum Demand	13000	MW	(Generation end)	04.	Maximum Load-shed	0	MW	At evening peak (Sub-station end)
02.	Maximum Generation	15278	MW	(Generation end)	05.	Total Generation	270.82	MKWh	
03.	Maximum Shortage	-2278	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	40.5° C		

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazool Islam Shaker)
Deputy Secretary, Generation