

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 956467, 9551095

Month May, 2021			Day : Wednesday				Date : 19.05.21					
Probable Maximum Demand :			12500 MW		Yesterday = 75.07 ft		Today = 74.95 ft		Probable Maximum Generation : 15161 MW		Rule Curve = 78.58 ft.	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.05.21 (Yesterday)		19.05.21 (Today)		18.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :	Machines shut down				
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering	
2	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	100	100	100	100			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	93	100	100	100			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.	
7	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	270	350	360	360			
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	290	290	290	290	160	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	347	46	350	360	366	Dirty in gas	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	146	175	150	175	35	Gas Shortage	
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	208	221	220	220	114	ST Under maint.	
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	80	100	100			
14	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	270	275	260	260	30	dirty in gas	
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	0	0			
16	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	45	55	55			
17	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	50	100	100			
18	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	0	102	102			
19	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	0	15	15			
20	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	32	30	42	42			
21	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
22	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	17	25	25			
23	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	42	42			
24	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	78	52	105	105			
25	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	0	150	150			
26	Katpott 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
27	Karnaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	17	35	35			
28	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	1	0	250	250			
29	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	114	132	132	132			
30	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300			
31	Bramhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
32	Aurshahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
33	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
34	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	0	55	55			
35	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
36	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	66	94	90	90			
37	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	69	162	162	162			
38	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	18	0	30	0			
Dhaka Zone Total			6076	5919	2424	2324	3608	3913	591	1159		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	23	20	22	22	210	Low Water Level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
43	Taknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	18	0	20	0			
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	43	43			
45	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	110	110	110	110			
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	205	208	150	150			
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300			
49	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	92	100	100	100			
50	Juldah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100			
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	85	85			
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	35	10	30			
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	1	0	90	90			
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	1	17	110	110			
57	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
58	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	97	74	116	116			
Chattogram Zone Total			2442	2382	958	1064	1559	1554	210	360		
59	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
59	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
59	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	120	120	100	120	14	Gas Shortage	
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26			
61	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1175	221	221	183	189	190	200			
62	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	295	310	330	330			
63	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	325	305	330	330			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	49	55	55	55			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	16	16	45	45	179	Gas shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	33	150	150	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	90	90	90	90	73	Gas Shortage	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	119	120	120	120			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
73	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	43	43	43			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	0	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+86x1.515+15x1.056	200	200	0	0	100	200			
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114			
78	Chowmahani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	117	119	113	113			
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	33	0	35	35			
**	Impoort (Tripura)	India		160	160	142	162	157	191			
Cumilla Zone Total			3094	3034	1712	1819	2135	2349	530	0		
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	202	203	200	200			
81	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	63	55	65	65			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	70	200	200			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	11	0	50	0			
87	Tangali 22 MW PP(RPGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22			
Mymensingh Zone Total			717	709	436	486	673	621	0	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.05.21 (Yesterday)		19.05.21 (Today)		18.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation (MW)	Machines shut down (MW)			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	22	22	22		68	Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	51	51				
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	40	51	51				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	324	330	330	330				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	68	76	75	75				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	60	140	150	150				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	7	7				
99	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Under maint.	
101	Bityana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	367	375	400	400				
102	Bityana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	397	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1515	1642	1694	1694	0	479	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	240	305	350	350		105	Gas Shortage	
106	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna 225 MW CCPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	99	99	99	99				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
111	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	0	32	32				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	105	90	90				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	844	844	864	864				
Khulna Zone Total					2288	2284	1236	1353	1665	1935	105	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	110	110				
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	25	34	33	33				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	85	87	88	88				
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	92	83	95	95				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	510	490	622	622				
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	80				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0				
Barishal Zone Total					1826	1826	728	742	948	1028	0	107	
120	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	40	40				
124	Ammura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	42	42				
125	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	98	100	100				
126	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	30				
127	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
128	Santihar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0	32				
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	86	115	140	140		35	Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	123	136	200	200		84	Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	127	145	200	200		75	Gas Shortage	
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	353	406	400	400				
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	18	18	18				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
135	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	60	113	113	113				
138	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	0	0				
Rajshahi Zone Total					2179	2179	853	1285	1752	1784	365	0	
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150		124	Coal Shortage	
141	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	95	113	113	113				
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
144	Majpara, Tutula 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total					685	605	251	263	271	283	294	0	
Sub-total: Plants in operation					21729	21315	10113	10978	14305	15161	2095	2105	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							9705	10535	13727	14549			
(B) Plants under long term maintenance/ contract expired													
145	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
147	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
148	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired							294	0	0	0	0	0	
Gross Total					22023	21315	10113	10978	14305	15161	2095	2105	

(C) Actual data of 18.05.21 (Yesterday)				Tuesday :				Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
Sl. No.	Description	Value	Unit	Sl. No.	Description	Value	Unit	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
01.	Max. Demand at eve. peak (Generation end)	10978.00	MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :			Dhaka	3073	3073	0	Mymensingh	892	892	0
02.	Max. Demand at eve. peak (Sub-station end)	10535.00	MW, at = 21:00 hrs					Chattogram	1313	1313	0	Sylhet	398	398	0
03.	Highest Generation (Generation end)	11234.00	MW, at = 22:00 hrs					Khulna	1198	1198	0	Barishal	371	371	0
04.	Minimum Generation (Generation end)	8788.00	MW, at = 7:00 hrs					Rajshahi	1286	1286	0	Rangpur	787	787	0
05.	Day-peak Generation (Generation end)	10113.00	MW, at = 12:00 hrs					Cumilla	1217	1217	0				
06.	Evening-peak Generation (Generation end)	10978.00	MW, at = 21:00 hrs												
07.	Evening Peak Load-shed (Sub-station end)	0.00	MW, at = 21:00 hrs												
08.	Minimum Generation Forecast up to 8:00 hrs.	8781.00	MW, at = 5:00 hrs												
09.	Generation shortfall at evening peak due to :			13.	Fuel cost :										
	a) Gas limitation	1591	MW		(a) Gas =	157716793	Taka					(c) Coal =	77999002	Taka	
	d) Coal supply Limitation	294	MW		(b) Oil =	386549797	Taka					Total =	622265592	Taka	
	b) Low water level in Kaptai lake	210	MW												
	c) Plants under shut down/ maintenance	2105	MW	14.	Maximum Temperature in Dhaka was :										
	10. Total Energy (Generation + India Import)	243.67	MWKh		Export through East-West interconnections :										
	By Gas =	146.656	MWKh		At evening peak-hour										
	By Coal =	16.905	MWKh		Maximum										
	By Solar =	0.539	MWKh		Energy										
11.	Total Gas Supplied	1213.60	MMCFD	15.	Probable Max. Temperature in Dhaka :										

(D) Forecast of 19.05.21 (Today)				Wednesday :			
01.	Maximum Demand	12500	MW (Generation end)	04.	Maximum Load-shed	0	MW At evening peak (Sub-station end)
02.	Maximum Generation	15161	MW (Generation end)	05.	Total Generation	271.13	MWKh
03.	Maximum Shortage	-2661	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	38.8° C	

* Captive Power ** Imported Power
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00
(Faouz Islam Shaker)
Deputy Secretary, Generation