

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 954667, 9551095

Month May 2021		Day : Friday			Date : 21.05.21						
Probable Maximum Demand : 12300 MW		Yesterday = 74.81 ft			Today = 74.57 ft			Rule Curve = 78.20 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.05.21 (Yesterday)		21.05.21 (Today)		20.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	190	190	190	190		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	93	101	100	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	335	325	360	360		
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	357	344	350	360	68	Dirty in gas
11	Siddhirgonj 2'120 MW GTPP	Gas (EGCB)	2 x 105	210	210	185	185	185	200	25	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	207	218	220	220	117	ST Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	65	100	100		
14	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	285	280	285	290		
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	0	0		
16	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
17	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
18	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	48	102	102		
19	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	16	15	15		
20	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	41	41	42	42		
21	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	16	25	25		
23	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	16	42	42		
24	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	50	105	105		
25	Kodda 150MW PP	HFO (BPPB-RPCL)	9x17.06	149	149	32	48	150	150		
26	Katpott 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
27	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35		
28	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	195	245	245		
29	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	125	130	132	132		
30	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300		
31	Bramhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
32	Aurshahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
33	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
34	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	17	55	55		
35	Bosila 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
36	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	76	56	90	90		
37	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	162	54	162	162		
38	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	25	0	30	0		
Dhaka Zone Total				6076	5919	2966	2873	3763	4063	243	1162
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0		
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	11	17	17	17		
43	Taknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	17	0	20	0		
44	Palenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	25	43	43		
45	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	74	89	70	90		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150-1 x 75	225	225	133	131	0	0	94	ST Under maint.
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150-1 x 75	225	225	133	131	0	0		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300		
49	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	80	100	100	100		
50	Juddah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68		
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	25	22	30		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	18	97	97		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	45	54	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	110	110		
57	Juddah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	90	100	100	100		
58	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	100	111	116	116		
Chattogram Zone Total				2442	2382	855	1010	1379	1382	205	454
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	80	80	80	80	54	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	26	26	26		
61	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1175	221	221	210	218	215	215		
62	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	310	285	330	330		
63	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	325	285	330	330		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	47	20	55	55		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	43	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	51	148	150	150		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	80	86	90	90	77	Gas Shortage
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	120	120	120	120		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11		
73	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86+14+80+155+15x1.058	200	200	0	0	100	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	52	114	114		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	117	120	113	113		
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	21	17	35	35		
**	Impoort (Tijura)	India		160	160	144	164	157	191		
Cumilla Zone Total				3094	3034	1707	1862	2112	2296	582	0
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	166	153	190	190		
81	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	0	19	19		
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	54	64	64	64		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	45	115	115		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	40	8	200	200		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0		
87	Tangal 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22		
Mymensingh Zone Total				717	709	459	294	662	610	0	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.05.21 (Yesterday)		21.05.21 (Today)		20.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation (MW)	Machines shut down (MW)			
88	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43			27	Under maint.
89	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	22	22	22	22			68	Under maint.
90	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
91	Kushiana 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	0	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	20	20	20				
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	320	192	154	330				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	74	78	78	78				
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	140	140	140	140				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	7	7				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
100	Bitiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	7	300	300	341				
101	Bitiana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	376	380	400	400				
102	Bitiana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	0	350	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1263	1782	1823	2040	0	95	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	375	370	350	350				
106	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	5	0	20	20				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna 225 MW CCGP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	83	99	99	99				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	98	50	100				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	32	32	32				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	70	105	105	105				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	105	100	100				
**	Bheramara (HVDC)	India		1000	1000	912	916	932	932				
Khulna Zone Total					2288	2284	1445	1725	1748	2018	0	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110				
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	25	34	33	33				
116	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	85	88	88	88			106	GT-2 & STG Under maint.
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	85	92	95	95				
118	Payra 320 MW TPP	Coal (BCPCL)	2x622	1244	1244	490	500	622	622				
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	0	80				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0				
Barishal Zone Total					1826	1826	685	859	948	1028	0	106	
120	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71	Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Gas Shortage
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	30	50	50	50				
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	43	40	40				
124	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	24	42	42				
125	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	100	100	100				
126	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	30	30				
127	Katakhalai 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	43	43				
128	Santlahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	32				
129	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	135	125	140	140			25	Gas Shortage
130	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	159	160	200	200			60	Gas Shortage
131	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	179	186	200	200				
132	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	388	420	400	400				
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	18	18	18				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
135	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	43	43	52	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	0	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	40	66	113	113				
138	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	0	0				
Rajshahi Zone Total					2179	2179	1039	1312	1752	1784	256	0	
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Coal Shortage
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	225	150	150	150			124	Coal Shortage
141	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	113	113	113				
143	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
144	Majpara, Tutula 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
Rangpur Zone Total					685	605	341	263	271	283	294	0	
Sub-total: Plants in operation					21729	21315	10760.0	11980	14458	15504	1580	1817	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							10270	11434	13799	14797			
(B) Plants under long term maintenance/ contract expired													
145	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
147	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021
148	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
Sub-Total: Plants under long term maintenance/ contract expired							294	0	0	0	0		
Gross Total					22023	21315	10760	11980	14458	15504	1580	1817	

(C) Actual data of 20.05.21 (Yesterday)			Thursday :		Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
01.	Max. Demand at eve. peak (Generation end)	: 11980.00 MW, at = 21:00 hrs	12.	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
02.	Max. Demand at eve. peak (Sub-station end)	: 11434.00 MW, at = 21:00 hrs		Dhaka	3820	3620	0	Mymensingh	773	773	0
03.	Highest Generation (Generation end)	: 12395.00 MW, at = 1:00 hrs		Chattogram	1307	1307	0	Sylhet	362	362	0
04.	Minimum Generation (Generation end)	: 9667.00 MW, at = 8:00 hrs		Khulna	1626	1626	0	Barishal	400	400	0
05.	Day-peak Generation (Generation end)	: 10760.00 MW, at = 12:00 hrs		Rajshahi	1146	1146	0	Rangpur	701	701	0
06.	Evening-peak Generation (Generation end)	: 11980.00 MW, at = 21:00 hrs		Cumilla	1299	1299	0				
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs									
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8870.00 MW, at = 5:00 hrs									
09.	Generation shortfall at evening peak due to :	:						Total	11434	11434	0
a)	Gas limitation	: 1081 MW		13.	Fuel cost :	(a) Gas = 166167088 Taka	(c) Coal = 81036565 Taka				
d)	Coal supply Limitation	: 294 MW				(b) Oil = 511977922 Taka	Total = 759181575 Taka				
b)	Low water level in Kaptai lake	: 205 MW									
c)	Plants under shut down/ maintenance	: 1817 MW		14.	Maximum Temperature in Dhaka was :	35.9° C					
10.	Total Energy (Generation + India Import)	: 267.46 MKWh		15.	Export through East-West interconnections :						
	By Gas = 152.541 MKWh	By Oil = 71.018 MKWh			At evening peak-hour	: 82 MW, at 21:00 hrs					
	By Coal = 17.450 MKWh	By Hydro = 0.612 MKWh			Maximum	: -230 MW, at 3:00 hrs					
	By Solar = 0.752 MKWh				Energy	: 0.581 MKWh					
11.	Total Gas Supplied	: 1290.67 MMCFD									

(D) Forecast of 21.05.21 (Today)			Friday :		
01.	Maximum Demand	: 12300 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)
02.	Maximum Generation	: 15504 MW (Generation end)	05.	Total Generation	: 265.41 MKWh
03.	Maximum Shortage	: -3204 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	37.7° C

* Captive Power ** Imported Power

#Remarks: