

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 954667, 9551095

Month May, 2021		Day : Wednesday						Date : 26.05.21			
Probable Maximum Demand : 11500 MW		Yesterday = 73.75 ft				Today = 73.51 ft				Rule Curve = 77.20 ft	
Water Level of Kaptai Lake at 06:00 AM		Probable Maximum Generation : 15623 MW									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.05.21 (Yesterday)		26.05.21 (Today)		25.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	93	102	102	102		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	212	161	170	170		
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	338	326	350	350		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	130	153	130	180	57	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	214	219	220	220	116	ST Under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	82	100	100	100		
14	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	275	264	270	270		
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	0	0		
16	Madaniganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
17	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	40	85	85		
18	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	66	92	102	102		
19	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	0	20	20		
20	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	40	38	45	45		
21	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
23	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	42	41	41		
24	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105		
25	Kodda 150MW PP	HFO (B/PDB-RPCL)	9x17.06	149	149	150	150	150	150		
26	Katpott 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
27	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35		
28	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	112	268	245	245		
29	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	148	149	149	149		
30	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300		
31	Bramhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
32	Aurshahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
33	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
34	Maniganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
35	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
36	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	90	94	72	72		
37	Maniganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	133	144	162	162		
38	Maniganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	34	0	30	0		
Dhaka Zone Total			6076	5919	2999	3183	3534	3804	207	1161	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0		
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	13	17	17	17		
43	Taknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0		
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	41	43	50	50		
45	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	53	53	70	90		
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	110	125	125		
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	204	204	220	220		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300		
49	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	80	85	100	100		
50	Juddah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	40	100	100		
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68		
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
**	Malanचा, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	11	10	20		
54	Chatogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	64	100	100		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	51	110	110		
57	Juddah unit-2, (Acorn)	HFO (IPP)	8x13.6	100	100	50	20	100	100		
58	Chatogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	53	17	116	116		
Chattogram Zone Total			2442	2382	711	884	1612	1617	385	180	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	70	80	80	59	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	80	100	134	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	26	26	26		
61	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+17x5	221	221	185	172	215	215		
62	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	300	270	330	330		
63	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	315	310	360	360		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	52	20	55	55		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	45	8	45	187		Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	128	108	150	150		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	90	87	90	90	76	Gas Shortage
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	69	58	125	125		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	21	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11		
73	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	0	33	33		
74	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	52	52	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	8	15	20	20		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x14+8x1.515+15x1.058	200	200	0	0	100	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	114	114	114	114		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	110	119	113	113		
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	36		
**	Impopt (Tipura)	India		160	160	146	162	145	181		
Cumilla Zone Total			3094	3034	1771	1756	2215	2459	591	0	
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	150	151	160	160	51	Gas Shortage
81	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	19	19	19		
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	63	24	64	64		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	107	115	115	115		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	32	88	200	200		
85	Sarisbaha 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0		
87	Tangal 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22		
Mymensing Zone Total			717	709	430	402	632	580	51	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.05.21 (Yesterday)		26.05.21 (Today)		25.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			Description/ Remarks
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	43	43	43		27	Under maint.		
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	42	42	42		48	Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	49	53	51	51					
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163					
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	2	11	11					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	52	57	57					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	158	160	163	160					
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	78	76	76					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	120	135	140	140					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	18	18					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	7	7					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
100	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	341	341					
101	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	368	366	400	400					
102	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	380	399	400	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total						2422	2377	1726	1823	1928	1925	0	75	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	310	350	410	410	60		Gas Shortage		
106	Faizpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	5	8	20	20					
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60					
108	Khulna 225 MW CCPP	HSD (NWPGCL)	1 x 150+1x75	230	230	0	0	0	220					
109	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	115	32	99	99	99					
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	20	50	100					
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	32	32	32					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	53	105	105					
113	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	892	892	523	812					
Khulna Zone Total						2288	2284	1239	1454	1399	1958	60	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	96	110	110					
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	14	33	33					
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x88	194	194	88	88	88	88			106	GT-2 & STG Under	
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	14	82	95	95					
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	460	622	622					
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110					
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				108	0	110	165					
Barishal Zone Total						1826	1826	546	740	1058	1223	0	106	
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50					
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	47	40	40					
124	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	42	40	42					
125	Chapainawabganj 100 MW Peaking Pi	HFO (PDB)	12x8.924	104	104	0	96	100	100					
126	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	30					
127	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43					
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35					
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	100	127	125	125					
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150+1x75	220	220	148	163	200	200	57		Gas Shortage		
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	130	181	200	200					
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	380	387	400	400					
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	20	20	20					
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	0	11	11					
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	52	52					
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6x18.55	113	113	0	109	113	113					
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	113	113	113					
138	Sirajgonj 6.55 MW Solar	Solar (NWPGCL)	1x6	6	6	4	0	6	0					
Rajshahi Zone Total						2179	2179	790	1402	1743	1774	228	0	
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage		
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x2'3	113	113	0	113	113	113					
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
144	Maipara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0					
Rangpur Zone Total						685	665	153	263	271	283	294	0	
Sub-total: Plants in operation						21729	21315	10365.0	11907	14392	15623	1816	1522	
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss								9847	11312	13672	14842			
(B) Plants under long term maintenance/ contract expired														
145	Ghorashal 78.5 MW PP (MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021	
146	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
147	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021	
148	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020	
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020	
	Sub-Total: Plants under long term maintenance/ contract expired			294	0	0	0	0	0					
Gross Total						22023	21315	10365	11907	14392	15623	1816	1522	
(C) Actual data of 25.05.21 (Yesterday) Tuesday :														
01.	Max. Demand at eve. peak (Generation end)		11907.00 MW, at = 19:30 hrs			12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)		11312.00 MW, at = 19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)		11907.00 MW, at = 19:30 hrs		MW	MW	MW		MW	MW	MW			
04.	Minimum Generation (Generation end)		7904.00 MW, at = 7:00 hrs	Dhaka	4275	4275	0	Mymensingh	595	595	0			
05.	Day-peak Generation (Generation end)		10365.00 MW, at = 12:00 hrs	Chattogram	1305	1305	0	Sylhet	446	446	0			
06.	Evening-peak Generation (Generation end)		11907.00 MW, at = 19:30 hrs	Khulna	1407	1407	0	Barishal	202	202	0			
07.	Evening Peak Load-shed (Sub-station end)		0.00 MW, at = 19:30 hrs	Rajshahi	1116	1116	0	Rangpur	805	805	0			
08.	Minimum Generation Forecast up to 8:00 hrs.		8403.00 MW, at = 5:00 hrs	Cumilla	1161	1161	0							
09.	Generation shortfall at evening peak due to :							Total	11312			11312	0	
	a) Gas limitation		1317 MW	13.	Fuel cost :	a) Gas = 153881280 Taka		(c) Coal = 63767643 Taka				63767643	Taka	
	b) Low water level in Kaptai lake		294 MW			b) Oil = 389280028 Taka		Total = 606928950 Taka				606928950	Taka	
	c) Plants under shut down/ maintenance		1522 MW											
10.	Total Energy (Generation + India Import)		242.14 MKWh	14.	Maximum Temperature in Dhaka was :			34.6° C						
	By Gas = 147.411 MKWh			15.	Export through East-West interconnections :									
	By Coal = 13.667 MKWh				At evening peak-hour :	80 MW, at 19:30 hrs								
	By Solar = 0.582 MKWh				Maximum :	-10 MW, at 4:00 hrs								
					Energy :	1.3205 MKWh								
11.	Total Gas Supplied		1244.54 MMCFD											
(D) Forecast of 26.05.21 (Today) Wednesday :														
01.	Maximum Demand		11500 MW (Generation end)	04.	Maximum Load-shed		0 MW	At evening peak (Sub-station end)						
02.	Maximum Generation		15623 MW (Generation end)	05.	Total Generation		233.87 MKWh							
03.	Maximum Shortage		-4123 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :		35.4° C							

* Captive Power ** Imported Power
#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation