

**Bangladesh Power Development Board  
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month May, 2021		Day: Saturday				Date: 29.05.21					
Probable Maximum Demand :		13000 MW		Yesterday = 73.03 ft		Today = 72.87 ft		Probable Maximum Generation : 15133 MW		Rule Curve = 76.60 ft.	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.05.21 (Yesterday)		29.05.21 (Today)		28.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)	
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	170	185	185		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	92	96	104	104		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	128	180	250	250	180	Gas Shortage
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	300	300	170	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	353	359	350	350		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	150	185	180	200	25	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	212	217	220	220		118 ST under maint.
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	68	100	100	100		
14	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	150	145	150	150	160	GT-2 Under maint.
15	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	100	0	0	0	0		
16	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55		
17	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	100	100		
18	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	58	102	102		
19	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	20	20		
20	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	38	41	45	45		
21	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Ruganaj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
23	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	42	42	42		
24	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	85	67	85	85		
25	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	0	115	150	150		
26	Katpott 52 MW PP (Sirha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
27	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35		
28	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	97	245	245		
29	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	68	149	149		
30	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x61.4	300	300	0	0	100	300		
31	Bramhangon 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
32	Aurshahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100		
33	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	55	55		
34	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
35	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
36	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	90	90		
37	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	114	144	144		
38	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	17	0	30	0		
<b>Dhaka Zone Total</b>			<b>6076</b>	<b>5919</b>	<b>1894</b>	<b>2599</b>	<b>3557</b>	<b>3797</b>	<b>375</b>	<b>1323</b>	
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low Water Level
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	90	100	100	100	80	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
43	Taknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	19	0	20	0		
44	Palenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	42	50	50		
45	Sikalbaha 105 MW PP (Baraka Sikab)	HFO (IPP)	6x18.415	105	105	53	53	53	100		
46	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	0	0	0	150	Under maint.
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	204	208	220	220		
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	0	0	300	300		
49	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	80	100	100	100		
50	Juddah 100 MW Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
51	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68		
52	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
53	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
**	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			15	42	30	30		
54	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	6	6	6		
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	54	54	54		
56	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	68	108	110	110		
57	Juddah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	10	68	100	100		
58	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	0	17	116	116		
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>798</b>	<b>1030</b>	<b>1496</b>	<b>1518</b>	<b>285</b>	<b>330</b>	
59	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	80	80	80	80	49	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
60	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	20	20	26	26		
61	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+175	221	221	186	167	215	215		
62	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	300	320	300	300		
63	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	300	335	300	330		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	25	49	49	49	6	Gas shortage
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	16	8	8	8	187	Gas shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	10	80	150	150		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	91	90	90	90	73	Gas Shortage
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	19	85	100	100		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	16	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		
73	Jargalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jargalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	20	20	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x14+86x1.515+15x1.058	200	200	0	0	100	200		
77	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	100	114	114		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	89	119	113	113		
79	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
**	Impoort (Tirupura)	India		160	160	90	150	145	181		
<b>Cumilla Zone Total</b>			<b>3094</b>	<b>3034</b>	<b>1474</b>	<b>1821</b>	<b>2014</b>	<b>2231</b>	<b>584</b>	<b>0</b>	
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	149	157	160	160	45	Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	19	19		
82	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	16	16	24	24		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	84	200	200		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
86	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	29	0	50	0		
87	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22		
<b>Mymensingh Zone Total</b>			<b>717</b>	<b>709</b>	<b>352</b>	<b>414</b>	<b>592</b>	<b>540</b>	<b>45</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.05.21 (Yesterday)		29.05.21 (Today)		28.05.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	42	42		27	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
91	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
93	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	57	56	56				
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	160	161	163	163				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	79	81	80	80				
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	137	218	218	218				
97	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	7	7	7				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
100	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	245	280	341	341				
101	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	241	382	400	400				
102	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	400	400	400				
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
<b>Sylhet Zone Total</b>					<b>2422</b>	<b>2377</b>	<b>1583</b>	<b>1931</b>	<b>2008</b>	<b>2008</b>	<b>0</b>	<b>75</b>	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	395	380	400	400	30		Gas Shortage	
106	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
109	Khulna 115 PP MW (KPCL-2)	HFO (QRPP)	7x17	115	115	94	115	115	115				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
111	Noapara 40 MW PP (Kharjahan Ali)	HFO (QRPP)	5x8.5	40	40	0	32	0	0				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	105	90	105				
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	896	887	919	919				
<b>Khulna Zone Total</b>					<b>2288</b>	<b>2284</b>	<b>1385</b>	<b>1519</b>	<b>1754</b>	<b>2039</b>	<b>30</b>	<b>0</b>	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	64	110	110				
115	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	34	33	33				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	85	83	88	88			111	GT-2 & STG Under
117	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	73	95	95	95				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	470	570	622	622				
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	110				
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				0	0	0	0				
<b>Barishal Zone Total</b>					<b>1826</b>	<b>1826</b>	<b>644</b>	<b>863</b>	<b>948</b>	<b>1058</b>	<b>0</b>	<b>111</b>	
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	43	50	50				
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	40	40				
124	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	42	40	42				
125	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	85	100	100				
126	Katakhalai 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	40	40				
127	Katakhalai 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	0	35				
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	150		Gas Shortage, STG S/D	
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	150	214	200	200				
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	178	193	200	200				
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	375	420	400	400				
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	20	20				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	0	113	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	109	113	113				
138	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
<b>Rajshahi Zone Total</b>					<b>2179</b>	<b>2179</b>	<b>782</b>	<b>1340</b>	<b>1628</b>	<b>1659</b>	<b>321</b>	<b>0</b>	
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	113	113	113				
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
144	Maipara, Tatula 6 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
<b>Rangpur Zone Total</b>					<b>685</b>	<b>665</b>	<b>152</b>	<b>263</b>	<b>271</b>	<b>283</b>	<b>294</b>	<b>0</b>	
<b>Sub-total: Plants in operation</b>					<b>21729</b>	<b>21315</b>	<b>9064.0</b>	<b>11780</b>	<b>14268</b>	<b>15133</b>	<b>1934</b>	<b>1839</b>	
<b>Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss</b>					<b>8616</b>	<b>11198</b>	<b>13563</b>	<b>14385</b>					
<b>(B) Plants under long term maintenance/ contract expired</b>													
145	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
146	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
147	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
148	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
149	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
Sub-Total: Plants under long term maintenance/ contract expired					294	0	0	0	0	0	0	0	
<b>Gross Total</b>					<b>22023</b>	<b>21315</b>	<b>9064</b>	<b>11780</b>	<b>14268</b>	<b>15133</b>	<b>1934</b>	<b>1839</b>	
<b>(C) Actual data of 28.05.21 (Yesterday) Friday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 11780.00 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	: 11198.00 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 12044.00 MW, at = 23:00 hrs	Dhaka	3748	3748	0	Mymensingh	919	919	0			
04.	Minimum Generation (Generation end)	: 8754.00 MW, at = 9:00 hrs	Chattogram	1304	1304	0	Sylhet	514	514	0			
05.	Day-peak Generation (Generation end)	: 9064.00 MW, at = 12:00 hrs	Khulna	1512	1512	0	Barishal	344	344	0			
06.	Evening-peak Generation (Generation end)	: 11780.00 MW, at = 21:00 hrs	Rajshahi	1015	1015	0	Rangpur	645	645	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs	Cumilla	1197	1197	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9215.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :		13. Fuel cost : (a) Gas = 166501076 Taka (c) Coal = 79702354 Taka Total = 617829278 Taka										
	a) Gas limitation	: 1435 MW	14. Maximum Temperature in Dhaka was : 33.7° C										
	d) Coal supply Limitation	: 294 MW	15. Export through East-West interconnections :										
	b) Low water level in Kaptai lake	: 205 MW	At evening peak-hour : 220 MW, at 21:00 hrs										
	c) Plants under shut down/ maintenance	: 1839 MW	Maximum : 92 MW, at 19:30 hrs										
10.	Total Energy (Generation + India Import)	: 243.49 MKWh	Energy : 0 MKWh										
	By Gas = 152.109 MKWh	By Oil = 48.315 MKWh											
	By Coal = 17.294 MKWh	By Hydro = 0.604 MKWh											
	By Solar = 0.640 MKWh												
11.	Total Gas Supplied	: 1217.40 MMCFD											
<b>(D) Forecast of 29.05.21 (Today) Saturday :</b>													
01.	Maximum Demand	: 13000 MW (Generation end)	04.	Maximum Load-shed	: 0 MW (Sub-station end)								
02.	Maximum Generation	: 15133 MW (Generation end)	05.	Total Generation	: 262.81 MKWh								
03.	Maximum Shortage	: -2133 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	36.4° C								

\* Captive Power \*\* Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazool Islam Shaker)  
Deputy Secretary, Generation