

Evening Peak Generation and Day Long Energy Data of Power Stations

Date : 12-Jun-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks	
			Unit No. X Capacity	MW	MW	KWH		
1	Ghorasal Repowered CCPP-Unit-2	PDB	1260	260	0	0	Under maint.	
2	Ghorasal Repowered CCPP-Unit-3	PDB	1210	180	0	0	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	PDB	1243+1122	365	0	0	Under maint.	
4	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired	
5	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	101	2295818	Engine problem	
6	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.	
7	Haripur 412 MW CCPP	EGCB	1273+1138	412	0	0	Under maint.	
8	Haripur 360MW CCPP(HPL)	IPP	1235+1125	360	127	5462000	Gas shortage	
9	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	300	7126250	Gas shortage	
10	Meghnaghat 100 MW(EL)	ORPP	12*8.9	100	0	0	Contract Expired	
11	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	305	260	6750458	FGMO	
12	Madangan 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired	
13	Madangan-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	55	601609		
14	Karanganj 100 MW PP (Poweres)	ORPP	8*13.45	100	62	348847	Low demand	
15	Narsingh 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	21	471240		
16	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.	
17	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	90	2863000	FGMO	
18	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	100	96	1412160	Engine problem	
19	Siddhirgonj 335 MW CCPP	EGCB	1217+118	335	332	7474794		
20	Sagaraj 102 MW PP (Digital Po	IPP	12*8.924	102	102	1065568		
21	Katpali 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage	
22	Kamalaghat 54 MW PP(Banco En	IPP	3*18	54	54	1031400		
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	2034720		
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	704021		
25	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	922682		
26	Basia 108MW PP(EL)	IPP	12*8.75+1*13.5	108	0	0	Fuel shortage	
27	Summit Power (Madhabdi-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	54	1279320	Engine problem	
28	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	739100		
29	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	816100		
30	Gazipur 52 MW PP	IPP	6*8.9	52	42	572640	Engine problem	
31	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.	
32	Kodda 300 MW PP Unit-2 (Summ	IPP	18*17.076	300	225	2752472	Engine problem	
33	Karanganj 300 MW PP (APR)	IPP	256*1.4	300	130	237673	Low demand	
34	Bramhangonj 100 MW PP (Aggr	IPP	100	100	50	138215	Low demand	
35	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	100	239781		
36	Kodda 149 MW PP Unit-1 (Summ	IPP	149	149	129	2088000	Engine problem	
37	Gazipur 100 MW PP	RPCL	100 MW	105	88	1808400	Engine problem	
38	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.6	104	104	1141440		
39	Manikganj 162MW PP(MPL)	IPP	9*18	162	128	1539360		
40	Spectra Solar Plant Ltd	IPP	35	35	0	114985	Engine problem	
Dhaka area Total				5919	3159	58462303		
41	Chattogram TPP-1	PDB	1*210	180	100	2400000	Gas shortage	
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage	
43	Razzan 25 MW PP	IPP	3*8.9	25	17	370035	Engine problem	
44	Tainal 20MW PP (Sataech)Kakal	Solartech Ener				63045	Gas shortage	
45	Palanga 50MW PP (Baraka)	IPP	8*6.98	50	50	242980		
46	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	25	604000	Low water level & Unit-2 und	
47	Sikalbaha 225MW	PDB	1*150+1*175	225	203	4839828	FGMO	
48	Sikalbaha Peaking GT	PDB	1*150	150	100	2351387	Machine problem	
49	Sikalbaha 105 MW PP (Baraka S	IPP	105 MW	105	105	2599406		
50	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D	
51	Dohazari-Kalesh 100 MW Peaker	PDB	6*11.7	102	85	639233	Engine problem	
52	Jaldah 100 MW Unit-1 (Acom)	ORPP	8*13.45	100	100	2220000		
53	Jaldah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	2019840		
54	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	0	0	Engine problem	
55	Malancha, Ctg. EPZ (United)		5*8.73+3*9.34	0	28	439200		
56	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Fuel shortage	
57	Kaptai 7 MW Solar PP	PDB	7*4 MW	7	0	38400		
58	Arwara 300 MW PP (Unite)	IPP	300 MW	300	0	0	Reserve.	
59	Jodac Power	IPP	3*18.55+1*3.6	54	54	1145771		
60	Karnaphuli Power Ltd.	IPP	110	110	110	2724024		
61	Jaldah unit-2 (Acom)	IPP	8*13.6	100	100	1054080		
62	Anilma Energy Ltd.	IPP	6*21.2	116	0	0	Transformer O/L	
Chattogram area Total				2382	1177	23751129		
63	Ashuganj TPP Unit-3	APSCL	1*150	135	80	2105718	Gas Shortage	
64	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage	
65	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Under maint.	
66	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	206	4832000	FGMO	
67	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	260	6916200	FGMO	
68	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	270	6724000	FGMO	
69	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	559416	Engine problem	
70	Ashuganj 55 MW PP (Precision)	IPP	15*4	55	10	416640	Gas shortage	
71	Ashuganj 195MW PP (APSCL-Uh	IPP	20*9.73+1*16	195	8	284363	Gas shortage	
72	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1248825		
73	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	147	2149454		
74	Titas 50 MW Peaking PP	PDB	6*8.92	50	50	232328		
75	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	133	3152710	Machine problem	
76	Chandpur 200MW (Desh energy)	IPP	0	200	180	3126720	Engine problem	
77	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	18	425952	Engine problem	
78	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	255780		
79	Imporrt (Tripura)	Imported power	0	160	152	2577600		
80	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	816900		
81	Jangalia 52 MW PP (Lakshana)	IPP	6*8.92	52	41	493776	Engine problem	
82	Dumaila 25 MW PP (Precision)	SIPP, PDB	3*3.67+2*6.97	25	21	535560	Engine problem	
83	Dauidkandi 200 MW PP (B.Trac)	IPP	15*11.4	200	80	155712	Low demand	
84	Feni Lanka Power	IPP	7*18.415+1*9.78	114	100	882360	Engine problem	
85	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	117	2452800		
86	Bhairab 54.5 MW	IPP	3*18.2	54	35	537480	33 KV feeder fault.	
Cumilla Area Total				3034	2029	40849294		
87	RPCL 210MW CCPP	IPP	4*35+1*70	202	118	3589520	Gas shortage	
88	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	0	402192	Engine problem
89	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	8	188180	Engine problem	
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12700		
91	Mymensingh 200 MW PP (Unite)	IPP	200	200	156	1936800	Engine problem	
92	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	115	2617200		
93	Sulakhal 50 MW Solar PP	IPP	50	50	0	289080		
94	Tangal Palli Power Gen 22 MW	IPP	4*8.7	22	5	223940	Engine problem	
Mymensingh Area Total				709	402	923992		
95	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	0	0	Machine problem	
96	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	42	990000	Machine problem	
97	Kushara 163 MW CCPP (KP)	IPP	1*109+1*54	163	163	3449372		
98	Shajibazar 330 MW CCPP	PDB	3*110	330	164	3613000	GT-1 under maint	
99	Fenchugonj 51 MW PP (Barakata)	RPP	19*2.90	51	47	1102800		
100	Fenchugonj 44MW PP (Energyprima)	RPP	12*3.34+3*2	0	0	0	Contract Expired	
101	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	177408		
102	Shajibazar GTTP Unit- 8 & 9	PDB	2*35	66	56	1401120		
103	Shajibazar 86MW PP (Shajibaz	RPP	32*2.90	86	81	1884480		
104	Shajibazar 100 MW GTTP	PDB	1*100	100	0	0	Under Shut down	
105	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	219	5038160		
106	Sylhet 20 MW GTTP	PDB	1*20	20	16	389200		
107	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired	
108	Shahajhalla 25 MW PP	SIPP, REB	3*9.34	25	16	367248	Engine problem	
109	Biliana-II 341 MW CCPP (Summ	IPP	1*222+1*119	341	290	7302003	FGMO	
110	Biliana-III 400 MW CCPP	PDB	400 MW	400	404	9424000	FGMO	
111	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	210060		
112	Biliana South 400 MW	PDB	400 MW	382	398	8974500		
Sylhet Area Total				2377	1919	44326151		
113	Bheramara GTTP Unit-3	PDB	1*20	16	0	0		
114	Bheramara (HVDC)	Imported power	2*500	1000	899	17525090		
115	Khulna 115 MW (KPCL-2)	ORPP	7*17	115	0	0	Contract Expired	
116	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	2	5760	Low demand	
117	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	225	80	143963	Low demand	
118	Opaganj 100 MW Peaking PP	RPP	16*6.89	108	0	0	Reserve.	
119	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	295	8575776	FGMO	
120	Nopara 40 MW PP (Khanjahan A	ORPP	5*8.5	40	0	0	Contract Expired	
121	Nopara 100 MW PP (Bangla Tr	IPP	70*1.4	100	100	777600		
122	Rupsha 105 MW PP (Orion rupsh	IPP	6*18.445	105	91	968640	Engine problem	
123	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.	
Khulna Area Total				2284	1467	28002229		
124	Bansal 110 MW PP (Summit)	IPP	7*17.076	110	16	289172	Line O/L	
125	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	33	502266		
126	Bhola 225 MW CCPP	PDB	2*63+1*68	194	84	2057072	Machine problem	
127	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	12	294107	Gas shortage	
128	Payra 1320 MW	BCPCL	2*622	1244	530	10730600		
129	Bhola Nulan Biddut BD LTD	IPP	220	0	221	4729000	On Test	
130	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Reserve.	
Barisal Area Total				1226	898	18391957		
131	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage	
132	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage	
133	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	336112		
134	Bera 70 MW Peaking PP	PDB	9*8.29	71	10	119653	Low demand	
135	Amnara 50 MW PP(Sinha)	ORPP	7*7.79	50	35	389030	Engine problem	
136	Katakhal 50 MW PP (Northern)	ORPP	6*8.9	50	34	108165	Engine problem	
137	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	30	137832	Engine problem	
138	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage	
139	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	187	4576382	Gas shortage	
140	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	190	4676045	FGMO and Gas shortage	
141	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	397	9039900	FGMO	
142	Santihar 50 MW Peaking PP	PDB	6*8.7	50	35	178910	Engine problem	
143	Bogra 22 MW PP (BBB)	RPP	6*4	22	22	504720		
144	Bogra 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	Contract Expired	
145	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	0	120942	Engine problem	
146	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	922560		
147	Chapainawabganj 100 MW Peaki	PDB	12*8.924	104	88	1204384	Engine problem	
148	Baghabari 200 MW PP (Paramou	IPP	200 MW	200	0	0	Reserve.	
149	Bogra 113 MW PP (Confidence)	IPP	113	113	113	1321856		
150	Confidence Power Bogura Unit-1	IPP	6*18.55	113	113	1327584		
151	Sirajgonj 6.55 MW Solar	NWPGCL	1*6	6	0	24840		
Rajshahi Area Total				2179	1356	24983315		