			POWER GRID NATIONA	COMPANY O	SPATCH (QF-LDC-08 Page -1
		40700 0		5,421 1121	•						ng Date :	20-Jun-21	ruge r
Till now the maximum generation is The Summary of Yesterday's	: - 19-Jun-21	13792.0 Generation 8	Demand				20:0	0 Hrs Today's Actu		27-Apr-21	ahle Gen 8	. Demand	
Day Peak Generation :		.0 MW	Comana	Hour :	12:00			Min. Gen. at		7:0		79	29 MW
Evening Peak Generation :		.0 MW		Hour:	21:00			Available Max	x Generati			151	90 MW
E.P. Demand (at gen end) :		.0 MW		Hour:	21:00			Max Demand					00 MW
Maximum Generation :		.0 MW		Hour :	21:00			Reserve(Gen	neration en	d)		33	90 MW
Total Gen. (MKWH) :	218		System Loa		: 83.93%	_		Load Shed		:			0 MW
Export from East grid to West grid :- Max Import from West grid to East grid :- Max	dmum	I/IMPORT IN	ROUGH EAST-WE		0 MW MW	at at		20:00			Energy Energy		MKWHR. - MKWHR.
Water Level of Kaptai Lake at 6:00 A		20-Jun-21		Rule curve		81.03		Ft.(MSL)					
		10 MH0FD		Rule curve				FI.(IVISL)					
Gas Consumed :	Total = 1197.	12 MMCFD.			Oil Cons	sumed (PDB)	:			HSD :			Liter
									F	FO :			Liter
Cost of the Consumed Fuel (PDB+Pvt) :	Gas Coal	:	Tk159,369,040 Tk51,378,757				Oil	: Tk218,665,58	83		Total : T	k429,413,380	
	Load Shedding & Ot	ner Information										,,	
Area Yesterda	·							Todav					
MW	7	Est	imated Demand (S/	/S end)				Estimated Sh		/S end) vIW		Rates of Sheddin	
Dhaka 0	0:00		4152							0	(0	On Estimated Der 0%	ııaılu)
Chittagong Area 0	0:00		1414							0		0%	
Khulna Area 0	0:00		1267							0		0%	
Rajshahi Area 0	0:00		1145							0		0%	
Cumilla Area 0	0:00		1034							0		0%	
Mymensingh Area 0	0:00		835							0		0%	
Sylhet Area 0 Barisal Area 0	0:00		465							0		0%	
Barisal Area 0 Rangpur Area 0	0:00 0:00		215 644							0		0% 0%	
Total 0	0.00		11170							0		0%	
	of the Generating Units unde	r shut down.											
Planned Shut- D	lown				Forced	Shut- Down							
					1) Barap 2) Ghora 3) Ashu 4) Kapta 5) Raoz 6) Bhola	oukuria ST: Ur asal-3,4,7 ganj-4 ii-2	nit-1,2 -2						
	mation of Machines, lines, l	nterruption / For	ced Load shed etc	.									
a) Ishwardi 230/132 kV T02 transformer ib) Ishwardi 230/132 kV T03 transformer is switched on at 15:56. c) Jaldhaka-Saidpur 132 kV Ckt-2 was u d) Matuali-Sddhirganj 132 kV Ckt was u e) Naogaon-Shantahar P.P. 132 kV Ckt v	ripped at 10:33 due to probler nder shut down from 08:20 to nder shut down from 08:50 to vas under shut down from 11:	20:20 for C/M. 14:01 for C/M. 10 to 18:02 due t	to CB problem at										
g) Madaripur 132/33 kV T-2 transformer h) Maniknagar-Matuail 132 kV Ckt was c i) Netrokona 132/33 kV T-1 transformer v j) Dohazari-Cox's Bazar 132 kV Ckt-1 sw k) Satmosjid 132/33 kV T-2 transformer t switched on at 23/36. l) Payra-Gopalganj 400 kV Ckt was unde m) Sikalbaha 150 MW tripped at 05:01(2 n) Kallyanpur-Laibag 132 kV Ckt-1 & 2 w o) Hasnabad 230/132 kV T01 transforme	was under shut down from 11: harge at 14:06 from Matuali e vas under shut down from 14: itched on at 15:36. ripped at 19:00 showing K86, r shut down from 13:58 to 15: 0-06-2021). ere shut down at 07:32(20-06	54 to 13:30 for C nd. 17 to 14:56 for C PRD relays at 33 11 for paralleling -2021) for C/M.	c/M. /M. 8 kV end and was T2 transformer.										
Sub Divisional Engineer Network Operation Division		Executive Network Oper									intendent Ei Despatch C		