

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 21-Jun-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation		Energy Generated	Remarks
					MW	KWH		
1	Ghorasal Repowered CCPP Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.	
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	Under maint.	
3	Ghorasal TPP Unit-5	PDB	1'210	190	185	4441500		
4	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	30	4200	Under maint.	
5	Ghorasal 78.5 MW PP (MAX)	QRPP	2'40	0	0	0	Contract Expired	
6	Ghorasal 108MW PP (Regent)	IPP	34'3.55	108	99	1893318		
7	Hariapur GTPP	SBU, PDB	2'32	20	0	0	Under maint.	
8	Hariapur 412 MW CCPP	EGCB	1'273+1'139	412	338	7744682	FGMO	
9	Hariapur 360MW CCPP(HPL)	IPP	1'235+1'125	360	252	6702000	Gas shortage	
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	300	7127000	Gas shortage	
11	Meghnaghat 100 MW (IEL)	QRPP	12'8.9	100	0	0	Contract Expired	
12	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	305	250	6492858	Gas shortage	
13	Madanganj 102 PP(Summit)	QRPP	6'17	0	0	0	Contract Expired	
14	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	55	485561		
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	100	30	151589	Low demand	
16	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	341928		
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.	
18	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	0	Gas shortage	
19	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12'8.9	100	100	1531843		
20	Siddhirgonj 335 MW CCPP	EGCB	1'217+1'118	335	223	4952529	Gas shortage	
21	Gaganagar 102 MW PP (Digital Power)	IPP	12'8.924	102	102	1115136		
22	Katpotti 52 MW PP (Sinha)	IPP	7'7.9	51	0	0	Fuel shortage	
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	1019520		
24	Kodda 150MW PP	BPD&RPCL	8'17.06	149	150	1802869		
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	17	687568		
26	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	684978		
27	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	108	0	0	Fuel shortage	
28	Summit Power,(Madhabd+Ashulia)	SIPP,REB	3'3.67+4'8.73	80	55	1262580	Engine problem	
29	Maona 33 MW PP(Summit)	SIPP,REB	4'8.73	33	33	793600		
30	Rugganj 33 MW PP(Summit)	SIPP,REB	4'8.73	33	33	831400		
31	Gazipur 52 MW PP	IPP	6'8.9	52	51	764540		
32	Tongi 80 MW GTPP	PDB	1'105	105	0	0	Under maint.	
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	265	2539199	Low demand	
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	0	Reserve.	
35	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	0	0	Reserve.	
36	Aurahali 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Reserve.	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	115	1279296	Engine problem	
38	Gazipur 100 MW PP	RPCL	100 MW	105	105	2067600		
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	91	369600	Engine problem	
40	Manikganj 162MW PP(MPGL)	IPP	9'18	162	126	1238400	Engine problem	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	154914		
Dhaka area Total				5919	3136	58483719		
41	Chattogram TPP-1	PDB	1'210	180	100	2200000	Gas shortage	
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage	
43	Racoon 25 MW PP	IPP	3'8.9	25	17	403662	Engine problem	
44	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energ	20	20	0	36045		
45	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	39	124320	Engine problem	
46	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	51	774380	Low water level & Unit-2 under maint	
47	Sikalbaha 225MW	PDB	1'150	225	203	4694665	FGMO	
48	Sikalbaha Peaking GT	IPP	1'150	150	100	2357138	Machine problem	
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	105 MW	105	105	2520799		
50	Hafzazari 100 MW peaking PP	PDB	11'8.9	98	0	0	Under SID	
51	Dohazari-Kalaish 100 MW Peaking	PDB	6'17	102	85	609077	Engine problem	
52	Juldah 100 MW Unit-1 (Accorn)	QRPP	8'13.45	100	100	2234160		
53	Juldah 100 MW PP Unit-3 (Accorn)	IPP	0	100	100	1200000		
54	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	22	511200		
55	Malancha, Ctg. EPZ (Unltd)	IPP	5'8.73+3'9.34	0	26	518880		
56	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	0	0	Fuel shortage	
57	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	16680		
58	Anwara 300 MW PP (Unltd)	IPP	300 MW	300	0	0	Transformer O/L	
59	Jodlac Power	IPP	3'18.55+1'3.6	54	54	1250354		
60	Karnaphuli Power Ltd.	IPP	110	110	110	2264026		
61	Juldah unit-2 (Accorn)	IPP	8'13.6	100	90	517440	Transformer O/L	
62	Anima Energy Ltd.	IPP	6'21.2	116	17	274745	Transformer O/L	
Chattogram area Total				2382	1219	22707571		
61	Ashuganj TPP Unit- 3	APSCL	1'150	135	80	2095832	Gas Shortage	
62	Ashuganj TPP Unit- 4	APSCL	1'150	129	0	0	Gas shortage	
63	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Under maint.	
64	Ashuganj 225 MW CCPP	APSCL	1'142+1'175	221	217	4749000	Red hot at APSCL 230 kV GIS	
65	Ashuganj 450 MW CCPP(North)	APSCL	1'360	360	260	7143300	Red hot at APSCL 230 kV GIS	
66	Ashuganj 450 MW CCPP(South)	APSCL	1'360	360	270	6839000	Red hot at APSCL 230 kV GIS	
67	Ashuganj 50 MW PP	APSCL	14'3.968	45	26	576504	Engine problem	
68	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	52	965280		
69	Ashuganj 195MW PP (APSCL-Unltd)	IPP	20'9.73+1'16	195	8	200727	Red hot at APSCL 230 kV GIS	
70	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1036499		
71	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	24	401454	Red hot at APSCL 230 kV GIS	
72	Titas 50 MW Peaking PP	PDB	6'8.92	52	50	166624		
73	Chandpur 150 MW CCPP	PDB	1'106+1'157	163	896	1232380	ST under maint	
74	Chandpur 200MW (Desh energy)	IPP	0	200	178	2707680	Engine problem	
75	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	18	375372		
76	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	11	243720		
77	Impoort (Tripura)	Imported power	0	160	120	2626560	Bad weather.	
78	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	691300		
79	Jangalia 52 MW PP (Lakdanavi)	IPP	6'8.92	52	25	502050	Engine problem	
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	21	475610		
81	Daukandi 200 MW PP (B. Trac)	IPP	154'1.4	200	0	0	Reserve.	
82	Feni Lanka Power	IPP	7'18.415+1'9.78	114	100	971280	Engine problem	
83	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	120	2174760		
84	Bhairab 54.5 MW	IPP	3'18.2	54	36	648360	33 kV feeder fault.	
Cumilla Area Total				3034	1786	37731092		
82	RPCL 210MW CCPP	IPP	4'35+1'70	202	156	3926760	Gas shortage	
83	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	21	467820		
84	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	8	193920	Engine problem	
85	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	14550		
86	Mymensingh 200 MW PP (Unltd)	IPP	200	200	177	1519200	Engine problem	
87	Jamalpur 115 MW PP (Unltd)	IPP	115 MW	115	115	2749200		
88	Sutakhal 50 MW Solar PP	IPP	50	50	0	259600		
89	Tangail Palli Power Gen 22 MW	IPP	4'6.7	22	24	360960		
Mymensingh Area Total				709	501	9492010		
90	Fenchugonj CCPP Phase-1	PDB	2'32+1'33	70	43	585000		
91	Fenchugonj CCPP Phase-2	PDB	2'35+1'35	90	42	990360	Machine problem	
92	Kushira 163 MW CCPP (KP)	IPP	1'109+1'54	163	163	3441845		
93	Shahjibazar 330 MW CCPP	PDB	3'110	330	163	3686000	GT-1 under maint	
94	Fenchugonj 51 MW PP (Barakalullah)	RPP	16'2.90	51	53	972000		
95	Fenchugonj 44MW (Energyprima)	RPP	12'3.34+2'2	0	0	0	Contract Expired	
96	Holiganj 11MW PP (Confidence-E)	SIPP, REB	1'1	11	11	261100		
97	Shahjibazar GTTP Unit- 8 & 9	PDB	2'35	66	62	1298400		
98	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	78	1278720		
99	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under Shut down	
100	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	219	5235840		
101	Sylhet 20 MW GTTP	RPP	1'20	20	18	395000		
102	Sylhet 50MW PP (EPL)	PDB	2'7.2	0	0	0	Contract Expired	
103	Shahjibazar 25 MW PP	SIPP, REB	3'9.34	25	0	389245	Engine problem	
104	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	280	7077500	FGMO	
105	Bibiana-III 400 MW CCPP	PDB	400 MW	400	367	8458000	FGMO	
106	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	229680		
107	Bibiana South 400 MW	PDB	400 MW	383	400	9108300		
Sylhet Area Total				2377	1925	43405990		
108	Bheramara GTTP Unit-3	PDB	1'20	16	0	0		
109	Bheramara (HVDC)	Imported power	2'500	1000	794	20580363		
110	Khulna 115 PP MW (KPCL-2)	QRPP	7'17	115	0	0	Contract Expired	
111	Fariapur 50 MW Peaking PP	PDB	8'6.99	54	0	0	Reserve.	
112	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	0	151746	Reserve.	
113	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Reserve.	
114	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	365	8680896	FGMO	
115	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5'8.5	40	0	0	Contract Expired	
116	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	48	121920	Reserve.	
117	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	91	644160	Engine problem	
118	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.	
Khulna Area Total				2284	1378	30179085		
118	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	0	0	Line O/L	
119	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	29	506587	Engine problem	
120	Bhola 225 MW CCPP	PDB	2'63+1'68	194	85	2063327	Machine problem	
121	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	95	12	294960	Gas shortage	
122	Payra 1320 MW	BCPCL	2'622	1244	470	9648300		
123	Bhola Nutan Biddut BD LTD	IPP	220	0	222	4138100	On Test	
124	Unltd Payra Power Ltd.	IPP	8'18.5+1'9.5	150	0	0	Line O/L	
Barisal Area Total				1826	818	16651274		
124	Baghabari 71 MW GTTP	PDB	1'71	71	0	150000	Gas shortage	
125	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage.	
126	Baghabari 50 MW Peaking PP</							