

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel.: 9564667, 9551095

Month June, 2021		Day : Wednesday				Date : 23.06.21					
Probable Maximum Demand :		13000 MW		Probable Maximum Generation :		15715 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.18 ft.		Today = 75.22 ft.		Rule Curve = 81.84 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Rated/ Present Capacity (MW)	22.06.21 (Yesterday)		23.06.21 (Today)		Gen. shortfall for : Gas/water/Coal limitation MW	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	190	200	200		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	98	90	100	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	276	247	350	360	113	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	339	338	350	380		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	11	222	220	220		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	275	265	290	300		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55		
16	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	70	100		
17	Gaganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	102	100	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	16	19		
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	55	55	55	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	51	51	51		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	90	105		
24	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	32	150	133	150		
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	2	275	290	290		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	66	104	135	135		
29	Keranganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	100	300		
30	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x10.85+9+1x 9.69	100	100	0	0	100	100		
31	Auralah 100MW PP (Aggreko)	HSD (IPP)	23x10.85+9+1x 9.69	100	100	0	0	100	100		
32	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55		
34	Bosila 108MW PP(RCLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	90	104		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	126	126	162		
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	22	0	30	0		
Dhaka Zone Total				5976	5819	2136	3117	3866	4203	473	680
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	51	49	51	51	181	Low Water Level
	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	6	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	30	40	45		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	100	100		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	203	220	220		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300		
48	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	85	100	100	100		
49	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	85	85		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
*	Malancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	28	10	20		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
54	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	54	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110		
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	10	50	100	100		
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	17	0	116	116		
Chattogram Zone Total				2442	2382	987	1170	1655	1645	181	180
58	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	80	80	80	55	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	183	183	220	220		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	295	280	310	330		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	345	280	310	330		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	40	54	55	55		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	5	50	50		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	23	150	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	90	90	90	90		
69	Chandpur 200MW (Dash energy)	HFO (IPP)	12x18.415	200	200	133	165	160	180		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	34	34	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	17	21		
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	9x11.4+8x11.95+1x11.95	200	200	0	0	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	100	34	100		
77	Chowmahani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	120	120	113	113		
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	18	36	35	35		
**	Impoort (Tijpura)	India		160	160	100	124	151	180		
Cumilla Zone Total				3094	3034	1561	1692	2099	2327	505	0
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	118	102	120	150	100	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
81	Jamalpur 55 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	85	189	175	192		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0		
85	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	56	0	50	0		
86	Tangail 22 MW PP(PPLCL)	HFO (IPP)	4x6.7	22	22	24	24	22	22		
Mymensingh Zone Total				717	709	430	459	513	508	100	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.06.21 (Yesterday)		23.06.21 (Today)		22.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	44	44			27	Under maint.
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42			48	Under maint.
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
90	Kushiana 163 MW CCPP (KPP)	Gas (IPP)	1x109+1x54	163	163	130	163	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	5	2	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	51	62	62	62				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	162	164	162	164				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	81	83				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	219	219	192	225				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	15	16				
99	Bitiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	270	341	341				
100	Bitiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	367	368	400	400				
101	Bitiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	310	360	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total				2422	2377	1796	1911	1992	2030	0	75		
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	380	385	380	380	25			Gas Shortage
105	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20				
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	5	0	60	60				
107	Khulna 225 MW CCPP	HSD (NWP/CGCL)	1 x 159+1x75	230	230	0	0	0	160				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	9	100	50	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	91	91	90	90				
110	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	0	100	100				
** Bheramara (HVDC) India				1000	1000	826	753	905	905				
Khulna Zone Total				2133	2129	1311	1329	1605	1815	25	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	31	25	25				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	86	83	85	86			111	GT-2 & STG Under
114	Bhola 95 MW PP (Aggregate)	Gas (QRPP)	1x196	95	95	12	11	12	12				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	290	480	622	622				
116	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110				
Bhola Nutan Biddut BD LTD						151	202	220	220				
Barishal Zone Total				1826	1826	558	807	1074	1185	0	111		
117	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	65	65	65	65				Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100			Gas Shortage
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	39	30	40				
121	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	35	35	35				
122	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	87	90	100				
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	40	40				
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	35				
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	0	0	0	0	150			Gas Shortage, STG S/D
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/CGCL)	1x150 + 1x75	220	220	189	166	200	200				
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	188	180	200	200				
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	392	356	400	400				
130	Bogra 22 MW PP (CBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	5	8	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	15	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	25	113	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	0	0	6	0				
Rajshahi Zone Total				2179	2179	949	1358	1670	1719	256	0		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0				Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0				Coal Shortage
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150	124			Coal Shortage
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	113	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Maipara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total				685	605	156	263	271	283	294	0		
Sub-total: Plants in operation				21474	21060	9884.0	12106	14655	15715	1834	1046		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss													
						9490	11623	14070	15088				
(B) Plants under long term maintenance/ contract expired													
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0				Contract Expired on 08/01/2021
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Fenchugonj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0				Contract Expired on 14/02/2021
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0				Contract Expired on 04/01/2020
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020
147	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 07/05/2021
148	Khulna 115 MW PP (KPCOL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0				Contract Expired on 28/05/2021
Sub-Total: Plants under long term maintenance/ contract expired				549	0	0	0	0	0				
Gross Total				22023	21060	9884	12106	14655	15715	1834	1046		
(C) Actual data of 22.06.21 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	12106.00	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11623.00	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12145.00	MW, at =	22:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	8623.00	MW, at =	8:00 hrs	Dhaka	4084	4084	0	Mymensingh	896	896	0
05.	Day-peak Generation (Generation end)	:	9884.00	MW, at =	12:00 hrs	Chattogram	1244	1244	0	Sylhet	462	462	0
06.	Evening-peak Generation (Generation end)	:	12106.00	MW, at =	21:00 hrs	Khulna	1399	1399	0	Barishal	329	329	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Rajshahi	1308	1308	0	Rangpur	788	788	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8988.00	MW, at =	5:00 hrs	Cumilla	1113	1113	0				
09.	Generation shortfall at evening peak due to :	:								Total	11623	11623	0
	a) Gas limitation	:	1359	MW		13.	Fuel cost :	(a) Gas = 168126603	Taka	(c) Coal = 62518874	Taka		
	b) Coal supply Limitation	:	294	MW			(b) Oil = 404508274	Taka	Total =	635153750	Taka		
	c) Low water level in Kaptai lake	:	181	MW									
	d) Plants under shut down/ maintenance	:	1046	MW		14.	Maximum Temperature in Dhaka was :	29.9° C					
10.	Total Energy (Generation + India Import)	:	249.67	MKWh		15.	Export through East-West interconnections :						
	By Gas =	159.346	MKWh	By Oil =	53.000	MKWh	At evening peak-hour		-224	MW, at	21:00 hrs		
	By Coal =	13.381	MKWh	By Hydro =	1.091	MKWh	Maximum		-224	MW, at	21:00 hrs		
	By Solar =	0.577	MKWh				Energy		1.0055	MKWh			
11.	Total Gas Supplied	:	1264.97	MMCFD									