

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564687, 9551095

Month June, 2021		Day : Saturday		Date : 26.06.21								
Probable Maximum Demand :		12800 MW		Probable Maximum Generation : 15598 MW								
Water Level of Kaptai Lake at 06:00 AM												
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Yesterday = 75.44 ft		Today = 75.55 ft		Rule Curve = 82.65 ft		Status of Machines under shut-down/ Maintenance		
				25.06.21 (Yesterday)		26.06.21 (Today)		25.06.21 (Yesterday)				
				Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
				Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	190	190	200	200			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	96	97	100	100			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.	
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235-1x125	360	360	277	347	300	360	13	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	341	357	350	350			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	210	219	220	220			
13	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	50	100	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	285	270	250	300			
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55			
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	70	100			
17	Gaganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	0	100	102			
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	21	22	22			
19	Summit Power, (Madhab+Ashulia)	Gas (SIPP, PDB)	6x3.07+4x3.73	80	80	42	55	55	55			
20	Maona 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	28	28	33	33			
21	Ruganaj 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33			
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	50	51	51			
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	86	105	105	105			
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	100	100	100			
25	Katpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
26	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35			
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	290	300			
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	80	114	110	114			
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300			
30	Bramanganon 100 MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
31	Aushali 100MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
32	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	55	55	55			
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	0	55	55			
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	90	104			
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	90	126	126			
37	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	31	0	30	0			
Dhaka Zone Total				5976	5819	2390	2783	3720	4060	373	680	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	26	25	25	25	205	Low Water Level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	14	25	25	25			
42	Teknat 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.89	50	50	0	40	40	45			
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	68	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	100	100			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	131	131	130	130			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	0	300	300			
48	Juldah 100 MW Unit-1 (Accorn)	HFO (QRPP)	8x13.45	100	100	82	100	100	100			
49	Juldah 100 MW PP Unit-3 (Accorn)	HFO (IPP)	8x13.45	100	100	0	10	100	100			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	102	102			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
*	Malancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			25	42	10	30			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	3	97	100	100			
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	54	54			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	107	110	110			
56	Juldah unit-2 (Accorn)	HFO (IPP)	8x13.5	100	100	0	70	100	100			
57	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	53	116	116	116			
Chattogram Zone Total				2442	2382	710	1192	1664	1664	205	180	
58	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	80	80	80	80	55	Gas Shortage	
	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	190	186	220	220			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	345	330	330			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	275	325	330	330			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	49	53	55	55			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	36	36	36	36	159	Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	50	50			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	28	133	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	91	90	90	90			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	122	160	170			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	11	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	40	34	40			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, PDB)	3x3.67+2x6.97	25	25	21	21	21	21			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.35+1x1.08	200	200	0	0	100	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	55	55	55			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	55	116	113	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	18	30	35	35			
**	Impoirt (Tripura)	India		160	160	94	112	151	180			
Cumilla Zone Total				3094	3034	1364	1884	2099	2294	477	0	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	149	185	160	160	17	Gas Shortage	
80	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	21	21			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	111	175	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0			
85	Sutikhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0			
86	Tangal 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	24	22	22			
Mymensing Zone Total				717	709	356	464	553	526	17	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.06.21 (Yesterday)		26.06.21 (Today)		25.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
87	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	44	44		26	Under maint.	
88	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
89	Fenchuganj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
90	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	130	163	163				
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP_REB)	4x2.90	11	11	5	11	11	11				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	62	62				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	160	162	162	164				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	84	84	84				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	219	219	225	225				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP_REB)	3x9.34	25	25	16	16	16	16				
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	341	341				
100	Bibiyana-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	332	403	400	400				
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	385	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total					2422	2377	1839	1938	2029	2031	0	74	
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	355	380	385	385				
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20				
106	Capalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60				
107	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150-1x75	230	230	0	0	0	160				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	100	50	100				
109	Rupsha 105 MW PP (Onon rupsha)	HFO (IPP)	6x18.445	105	105	0	91	90	91				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	883	890	898	898				
Khulna Zone Total					2133	2129	1238	1461	1603	1814	0	0	
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	28	25	28				
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	86	86	85	86		108	G1-Z & STG Under maint.	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	12	11	12	12				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	360	270	622	622				
116	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	110				
Bhola Nutan Biddut BD LTD							189	221	220	220			
Barishal Zone Total					1826	1826	666	681	1074	1188	0	108	
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	60	65	65	65				
117	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	50	60	60		50	Gas Shortage	
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	34	43	43	43				
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	40				
121	Amnura 50 MW PP(Siraha)	HFO (QRPP)	7x7.79	50	50	0	0	35	35				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	95	95				
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	40	40				
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	43	43				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	35				
126	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		150	Gas Shortage, STG S/D	
127	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	160	209	200	200				
128	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	188	188	200	200				
129	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	353	406	400	400				
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
131	Ullapara 11 MW PP (Summit)	Gas (SIPP_REB)	4x2.90	11	11	8	8	11	11				
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	42	42	42				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	0	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	89	94	94				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total					2179	2179	871	1359	1699	1738	200	0	
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	149	150	150	150		124	Coal Shortage	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Majpara, Tabula 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
Rangpur Zone Total					685	605	156	263	271	283	294	0	
Sub-total: Plants in operation					21474	21060	9590.0	12025	14712	15598	1566	1042	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							9171	11499	14068	14916			
(B) Plants under long term maintenance/ contract expired													
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
146	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEI)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0			Contract Expired on 28/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					549	0	0	0	0	0			
Grand Total					22023	21060	9590	12025	14712	15598	1566	1042	
(C) Actual data of 25.06.21 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	: 12025.00 MW, at = 21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end):										
02.	Max. Demand at eve. peak (Sub-station end)	: 11499.00 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 12105.00 MW, at = 23:00 hrs	Dhaka	3866	3866	0	Mymensingh	1001	1001	0			
04.	Minimum Generation (Generation end)	: 9062.00 MW, at = 9:00 hrs	Chattoagram	1220	1220	0	Sylhet	453	453	0			
05.	Day-peak Generation (Generation end)	: 9590.00 MW, at = 12:00 hrs	Khulna	1443	1443	0	Barishal	343	343	0			
06.	Evening-peak Generation (Generation end)	: 12025.00 MW, at = 21:00 hrs	Rajshahi	1272	1272	0	Rangpur	787	787	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs	Cumilla	1114	1114	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9213.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to:	:											
a)	Gas limitation	: 1067 MW											
d)	Coal supply Limitation	: 294 MW											
b)	Low water level in Kaptai lake	: 205 MW											
c)	Plants under shut down/ maintenance	: 1042 MW											
10.	Total Energy (Generation + India Import)	: 251.70 MCKWh											
	By Gas = 162.716 MCKWh	By Oil = 50.324 MCKWh											
	By Coal = 13.286 MCKWh	By Hydro = 0.511 MCKWh											
	By Solar = 0.765 MCKWh												
11.	Total Gas Supplied	: 1305.53 MCMCFD											
(D) Forecast of 26.06.21 (Today) Saturday :													
01.	Maximum Demand	: 12800 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 15598 MW (Generation end)	05.	Total Generation	: 266.15 MCKWh								
03.	Maximum Shortage	: -2798 MW (Generation end)	06.	Probable Max. Temperature in Dhaka	: 34.2° C								

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation