

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 3-Jul-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CAPP-Unit	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit	PDB	1'210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1'210	190	0	0	Under maint.
4	Ghorasal 365 MW CAPP Unit-7	PDB	1'243+1'122	365	300	7101055	Machine problem
5	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	Contract Expired
6	Ghorashal 108MW PP (Regen)	IPP	343.35	108	98	1453181	
7	Haripur GTTP	SBU_PDB	2'32	20	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	340	8224770	FGMO
9	Haripur 360MW CAPP(HPL)	IPP	1'235+1'125	360	341	7866000	
10	Meghnaghat 450 MW CAPP(MP)	IPP	2'150+1'150	450	310	7365750	Gas shortage
11	Meghnaghat 100 MW (EL)	QRPP	12'8.9	0	0	0	Contract Expired
12	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	305	270	6503584	FGMO
13	Madanganj 102 PP(Summit)	QRPP	6'17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	0	0	Reserve.
15	Keraniganj 100 MW PP (Powerpa)	QRPP	8'13.45	100	0	0	Reserve.
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	273672	Engine problem
17	210 MW Siddhirganj TPP	PDB	1'210	115	0	0	Under maint.
18	Siddhirganj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
19	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12'8.9	100	95	488640	
20	Siddhirganj 335 MW CAPP	EGCB	1'217+1'118	335	222	5034493	Machine problem
21	Gagnagar 102 MW PP (Digital Pa)	IPP	12'8.924	102	0	160128	Reserve.
22	Katpotti 52 MW PP (Sinha)	IPP	7'7.9	51	0	0	Fuel shortage
23	Kamatnagar 54 MW PP(Banco E)	IPP	3'19	54	35	758890	Low demand
24	Kodda 150MW PP	BFDB-RPCL	9'17.06	149	150	953760	
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	0	0	Reserve.
26	Nababganj 55 MW PP (Southern)	IPP	3'19.3	55	55	746	
27	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	108	0	0	Fuel shortage
28	Summit Power (Madhabdi+Ashul)	SIPP, REB	3'3.67+4'8.73	80	55	1233360	Engine problem
29	Machna 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	80369	
30	Ruganaj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	815300	
31	Gazipur 52 MW PP	IPP	6'8.9	52	42	601440	Engine problem
32	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Sumr)	IPP	18'17.076	300	15	57709	Low demand
34	Keraniganj 300 MW PP (AFR)	IPP	25'11.4	300	0	0	Reserve.
35	Bramhangganj 100 MW PP (Agg)	IPP	100	100	0	0	Reserve.
36	Aurahati 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Sumr)	IPP	149	80	909940	Low demand	
38	Gazipur 100 MW PP	RPCL	100 MW	105	86	1677600	Engine problem
39	Meghnaghat 104 MW PP (OPCL)	IPP	18'5.0	104	0	158400	Reserve.
40	Manikganj 162MW PP(MPCL)	IPP	9'18	162	108	635040	Engine problem
41	Spectra Solar Plant Ltd.	IPP	35	35	0	139846	
<b>Dhaka area Total</b>				<b>5819</b>	<b>2687</b>	<b>53222874</b>	
41	Chattogram TPP-1	PDB	1'210	180	100	2400000	Gas shortage
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
43	Raozan 25 MW PP	IPP	3'8.9	25	25	225122	
44	Teknaf 20MW PP (SolarTech)Khat SolarTech Energy	IPP	20	0	0	108570	
45	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	0	0	Reserve.
46	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	28	576600	Low water level & Unit-2 unc
47	Sikalbaha 225MW	PDB	1'150+1'175	225	203	4883660	FGMO
48	Sikalbaha Peaking GT	PDB	1'150	150	100	2534616	Machine problem
49	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	1206672	
50	Hathazari 100 MW peaking PP	PDB	1'18.9	98	0	0	Under S/D
51	Dohazari-Kalaish 100 MW Peak	PDB	6'17	102	68	573601	Engine problem
52	Juldah 100 MW Unit-1 (Acorn)	QRPP	8'13.45	100	100	1455240	
53	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	0	0	Reserve.
54	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	16	366960	Engine problem
55	Mataraha, Cg. EZZ	IPP	5'8.73+9.34	0	24	523290	
56	Chattogram 108 MW PP (ECPV)	IPP	6'7	108	97	2085120	Engine problem
57	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	17879	
58	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	0	0	Reserve.
59	Jodiak Power	IPP	3'18.55+1'3.6	54	17	202513	Low demand
60	Karnaphuli Power Ltd.	IPP	110	110	85	704215	Engine problem
61	Juldah unit-2 (Acorn)	IPP	8'13.6	100	10	65280	Low demand
62	Anlima Energy Ltd.	IPP	6'21.2	116	112	2128455	
<b>Chattogram area Total</b>				<b>2382</b>	<b>1090</b>	<b>20050903</b>	
61	Ashuganj TPP Unit- 3	APSCL	1'150	135	80	2056288	Gas Shortage
62	Ashuganj TPP Unit- 4	APSCL	1'150	129	0	0	Gas shortage
63	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Under maint.
64	Ashuganj 225 MW CAPP	APSCL	1'144+2'175	221	182	4753000	FGMO
65	Ashuganj 450 MW CAPP(North)	APSCL	1'360	360	315	7187000	FGMO
66	Ashuganj 450 MW CAPP(South)	APSCL	1'360	360	300	6901000	FGMO
67	Ashuganj 50 MW PP	APSCL	14'3.968	45	26	547200	Engine problem
68	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	57	1323360	
69	Ashuganj 150MW PP (APCL-U)	IPP	20'37+1'16	185	26	451536	Gas shortage
70	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	952629	
71	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	150	955127	
72	Tilas 50 MW Peaking PP	PDB	6'8.92	52	0	80936	Reserve.
73	Chandpur 150 MW CAPP	PDB	1'106+1'57	163	0	0	Under maint
74	Chandpur 200MW (Desh energy)	IPP	0	200	34	408960	Low demand
75	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	385740	Engine problem
76	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	11	252180	
77	Imopprt (Tripura)	Imported power	0	160	128	2540160	
78	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	817500	
79	Jangalia 52 MW PP (Lakdanavi)	IPP	6'8.92	52	25	389659	Low demand
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	20	432450	Engine problem
81	Cumilla 200 MW PP (B.Trac)	IPP	15'41.6	200	0	0	Reserve.
82	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	1521900	
83	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	116	2341920	
84	Bhairab 54.5 MW	IPP	3'18.2	54	36	720720	33 kV feeder fault.
<b>Cumilla Area Total</b>				<b>3034</b>	<b>1726</b>	<b>35019365</b>	
82	RPCL 210MW CAPP	IPP	4'35+1'70	202	167	4419120	Gas shortage
83	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	39412	
84	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	8	184320	Engine problem
85	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	8900	
86	Mymensingh 200 MW PP (Unite)	IPP	200	90	90	376800	Low demand
87	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	115	1724400	
88	Sutakhir 50 MW Solar PP	IPP	50	0	0	217020	
89	Tangail Palli Power Gen 22 MW	IPP	4'6.7	22	10	46560	Low demand
<b>Mymensingh Area Total</b>				<b>709</b>	<b>411</b>	<b>7456532</b>	
90	Fenchuganj CAPP Phase-1	PDB	2'32+1'33	70	43	1038000	Machine problem
91	Fenchuganj CAPP Phase-2	PDB	2'35+1'35	90	30	707400	Machine problem
92	Kushkhara 163 MW CAPP (KP)	IPP	1'109+1'54	163	0	0	
93	Shahjibazar 330 MW CAPP	PDB	3'110	330	110	244200	GT-1 under maint
94	Fenchuganj 51 MW PP (Barakat)	RPP	19'2.90	51	50	841200	
95	Fenchuganj 44MW (Energyprima)	RPP	12'3.3+5'2	0	0	0	Contract Expired
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	11	138048	
97	Shahjibazar GTTP Unit- 8 & 9	PDB	2'35	66	61	1351488	
98	Shahjibazar 80MW PP (Shahjiba)	RPP	32'2.90	86	84	1428480	
99	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under Shut down
100	Sylhet 225 MW CAPP	PDB	1'142+1'89	231	218	5046600	
101	Sylhet 20 MW GTTP	PDB	1'20	20	18	402000	
102	Sylhet 50MW PP (EPL)	RPP	2'72	0	0	0	Contract Expired
103	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	14	212496	Engine problem
104	Bibiana-II 341 MW CAPP (Summ)	IPP	1'122+1'119	341	285	7303000	FGMO
105	Bibiyana-III 400 MW CAPP	PDB	400 MW	400	401	8890000	
106	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	62100	
107	Bibiyana South 400 MW	PDB	400 MW	383	400	8865000	
<b>Sylhet Area Total</b>				<b>2377</b>	<b>1735</b>	<b>38634812</b>	
108	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Reserve.
109	Bheramara (MPCL)	Imported power	2'500	1000	804	16307836	
110	Khulna 115 PP MW (KPCL-2)	QRPP	7'17	0	0	0	Contract Expired
111	Faridpur 50 MW Peaking PP	PDB	8'6.89	54	0	0	Reserve.
112	Khulna 225 MW CAPP	NWPGCL	1'150+1'75	230	0	0	Reserve.
113	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Reserve.
114	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	400	8951904	FGMO
115	Noapara 40 MW CAPP (Khanjahan)	QRPP	1'141	0	0	0	Contract Expired
116	Noapara 100 MW PP (Bangla Tr)	IPP	70'1.4	100	100	476160	
117	Rupsha 105 MW PP (Orion rups)	IPP	6'18.445	105	90	792480	Engine problem
118	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
<b>Khulna Area Total</b>				<b>2129</b>	<b>1394</b>	<b>26528180</b>	
118	Barisal 110 MW PP (Summit )	IPP	7'17.076	110	0	0	Reserve.
119	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	29	498663	Engine problem
120	Bhola 225 MW CAPP	PDB	2'63+1'68	194	86	2109108	Machine problem
121	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	95	10	277012	Gas shortage
122	Payra 1320 MW	BCPCL	2'622	1244	500	9951200	
123	Bhola Nutan Biddut BD LTD	IPP	220	0	223	4358291	On Test
124	Uniled Payra Power Ltd.	IPP	8'18.5+1'9.5	150	0	0	Line OIL
<b>Barisal Area Total</b>				<b>1826</b>	<b>848</b>	<b>17189274</b>	
124	Baghabari 71 MW GTTP	PDB	1'71	71	70	1485000	
125	Baghabari 100 MW GTTP	PDB	1'100	100	80	1729000	Gas shortage.
126	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	50	257872	
127	Bera 70 MW Peaking PP	PDB	9'8.29	71	0	45359	Reserve.
128	Annura 50 MW PP(Sinha)	QRPP	7'7.79	50	12	53230	Low demand
129	Katakhal 50 MW PP (Northern)	QRPP	6'8.9	50	0	0	Reserve.
130	Katakhal 50 MW Peaking PP	PDB	6'8.7	50	30	148081	Engine problem
131	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'75	210	0	0	Gas shortage
132	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'75	220	181	4388264	FGMO
133	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	183	4440818	FGMO
134	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1'282+1'132	414	415	8693909	FGMO
135	Sanlahar 50 MW Peaking PP	PDB	6'8.7	50	42	257705	Engine problem
136	Bogra 22 MW PP (GGB)	RPP	6'4	22	18	338400	Engine problem
137	Bogra 20 MW PP (Energyprima)	RPP	5'3.3+5'2	0	0	0	Contract Expired
138	Uliapur 11 MW PP (Summit)	SIPP, REB	4'2.90	11	8	170226	Engine problem
139	Natore 52 MW PP (Rajshahi)	IPP	6'8.92	52	52	300160	
140	Chapainawabganj 100 MW Peak	PDB	12'8.924	104	95	862160	Engine problem
141	Baghabari 200 MW PP (Paramo)	IPP	200 MW	200	0	0	Reserve.
142	Bagura 113 MW PP (Confidenc)	IPP	113 MW	113	35	151968	Low demand
143	Confidence Power Bogura Unit-1	IPP	6'18.55	113	90	629664	Engine problem
143	Sirajgonj 6.55 MW Solar	NWPGCL	1'6	6	0	0	
<b>Rajshahi Area Total</b>				<b>2179</b>	<b>1361</b>	<b>23934816</b>	
144	Bar						