

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 4-Jul-21		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CAPP Unit-1	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-2	PDB	1210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1210	190	0	0	Under maint.
4	Ghorasal 365 MW CAPP Unit-7	PDB	1243+1122	365	300	7217127	Gas shortage
5	Ghorashah 78.5 MW PPMAX	QRPP	2*40	0	0	0	Contract Expired
6	Ghorashah 108MW PP (Regen)	IPP	343.35	108	101	1982180	Engine problem
7	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1273+1139	412	315	7915520	FGMO
9	Haripur 360MW CAPP(HPL)	IPP	1235+1125	360	271	7606000	Gas shortage
10	Meghnaghat 450 MW CAPP(MP)	IPP	2150+1150	450	0	5178750	Tripped
11	Meghnaghat 100 MW (EL)	QRPP	12*8.9	0	0	0	Contract Expired
12	Meghnaghat CAPP(Summit)	IPP	2110+1110	305	260	6517615	FGMO
13	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3*17.08+11*1.3	55	45	128605	Engine problem
15	Keraniganj 100 MW PP (Powerpa)	QRPP	8*13.45	100	70	153705	Low demand
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	369756	Engine problem
17	210 MW Siddhirganj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirganj 2120 MW GTTP	EGCB	2*105	210	0	0	Gas shortage
19	Siddhirganj 100 PP(Dutch Bangla)	QRPP	12*8.9	100	100	1664640	
20	Siddhirganj 335 MW CAPP	EGCB	1217+118	335	222	4801566	Machine problem
21	Gagnagar 102 MW PP (Digital Pa)	IPP	12*8.924	102	74	551520	Engine problem
22	Katpotti 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamatnagar 54 MW PP(Banco E)	IPP	3*18	54	54	663200	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	115	943680	Engine problem
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	140527	
26	Nabaganj 55 MW PP (Southern)	IPP	3*19.3	55	55	806791	
27	Bosila 108MW PP(ELC)	IPP	12*8.775+1*3.5	108	0	0	Fuel shortage
28	Summit Power (Madhabdi+Ashul)	SIPP, REB	3*3.67+4*8.73	80	55	1234140	Engine problem
29	Machna 33 MW PP(Summit)	SIPP, REB	4*8.3	33	33	824000	
30	Ruganaj 33 MW PP(Summit)	SIPP, REB	4*8.3	33	0	814600	Engine problem
31	Gazipur 52 MW PP	IPP	6*8.9	52	42	684960	Engine problem
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Sumr)	IPP	18*17.076	300	178	592145	Low demand
34	Keraniganj 300 MW PP (APR)	IPP	25*11.4	300	0	76703	
35	Bramhangonj 100 MW PP (Agg)	IPP	100	100	0	0	Reserve.
36	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Sumr)	IPP	149	103	1005264		Engine problem
38	Gazipur 100 MW PP	RPCL	100 MW	105	86	1836000	Engine problem
39	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.16	104	104	320640	
40	Manikganj 162MW PP(MPCL)	IPP	9*18	162	98	891360	Engine problem
41	Spectra Solar Plant Ltd.	IPP	35	35	0	69942	
Dhaka area Total				5819	2755	54990856	
41	Chattogram TPP-1	PDB	1210	180	100	2300000	Gas shortage
42	Chattogram TPP-2	PDB	1210	180	0	0	Gas shortage
43	Raazan 25 MW PP	IPP	3*8.9	25	25	278481	
44	Teknaf 20MW PP (Solar) (Khat Solartech Energy)	IPP	20	0	0	41310	
45	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	42	84320	Engine problem
46	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2*40+3*50	230	53	865800	Low water level & Unit-2 unc
47	Sikalbaha 225MW	PDB	1150+1175	225	204	4921366	FGMO
48	Sikalbaha Peaking GT	PDB	1150	150	110	2643690	Machine problem
49	Sikalbaha 105 MW PP (Baraka S)	IPP	105	85	85	1219418	Engine problem
50	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Under S/D
51	Dohazari-Kalaish 100 MW Peak	PDB	6*17	102	51	282437	Engine problem
52	Juldah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	90	1504560	
53	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	0	55680	Reserve.
54	Barakunda 22 MW PP (Regent)	SIPP, PDB	0	22	16	376500	Engine problem
55	Malanchari Cg EZZ	IPP	5*8.73+3*9.34	0	24	363000	
56	Chattogram 108 MW PP (ECPV)	IPP	6*7	108	83	2095680	Engine problem
57	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	22201	
58	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	0	0	Reserve.
59	Jodiac Power	IPP	3*18.55+1*3.6	54	0	0	Reserve.
60	Karnaphuli Power Ltd.	IPP	110	110	105	778653	Engine problem
61	Juldah unit-2 (Acorn)	IPP	8*13.6	100	100	381120	
62	Anlima Energy Ltd.	IPP	6*21.2	116	109	2502818	
Chattogram area Total				2382	1197	20714094	
61	Ashuganj TPP Unit-3	APSCL	1150	135	80	1967314	Gas Shortage
62	Ashuganj TPP Unit-4	APSCL	1150	129	0	0	Gas shortage
63	Ashuganj TPP Unit-5	APSCL	1150	134	0	0	Under maint.
64	Ashuganj 225 MW CAPP	APSCL	1144+175	221	177	4553000	FGMO
65	Ashuganj 450 MW CAPP(North)	APSCL	1360	360	315	7922400	FGMO
66	Ashuganj 450 MW CAPP(South)	APSCL	1360	360	300	7440000	FGMO
67	Ashuganj 50 MW PP	APSCL	14*3.968	45	26	585432	Engine problem
68	Ashuganj 55 MW PP (Precision)	RPP	154	55	57	1343040	
69	Ashuganj 150MW PP (APCL-U)	IPP	20*7+11*6	185	26	606090	Gas shortage
70	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1252069	
71	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	100	794545	Low demand
72	Tilas 50 MW Peaking PP	PDB	6*8.92	52	42	134320	
73	Chandpur 150 MW CAPP	PDB	11*06+1*57	163	0	0	Under maint
74	Chandpur 200MW (Desh energy)	IPP	0	200	120	634080	Low demand
75	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.80	22	21	455580	
76	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	232560	
77	Impoort (Tripura)	Imported power	0	160	124	2695680	
78	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	783300	
79	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	43	206179	Engine problem
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	20	431060	
81	Cumilla 200 MW PP (B.Trac)	IPP	15*11.4	200	0	0	Reserve.
82	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	1523040	
83	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	75	2146200	Low demand
84	Bhairab 54.5 MW	IPP	3*18.2	54	18	552600	33 kV feeder fault.
Cumilla Area Total				3034	1753	36331489	
82	RPCL 210MW CAPP	IPP	435+1170	202	160	4085600	Gas shortage
83	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	474012	
84	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	8	188160	Engine problem
85	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12800	
86	Mymensingh 200 MW PP (Unite)	IPP	200	144	1089600	Engine problem	
87	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	115	1888800	
88	Sutakhir 50 MW Solar PP	IPP	50	0	0	273780	
89	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	21	110400	
Mymensingh Area Total				709	469	8125162	
90	Fenchuganj CAPP Phase-1	PDB	2*32+1*33	70	0	820000	Machine problem
91	Fenchuganj CAPP Phase-2	PDB	2*35+1*35	90	0	265200	Machine problem
92	Kushkhara 163 MW CAPP (KP)	IPP	11*09+1*54	163	0	0	
93	Shahjibazar 338 MW CAPP	PDB	3*110	330	110	2472000	GT-1 under maint
94	Fenchuganj 51 MW PP (Barakat)	RPP	19*2.90	51	53	946200	
95	Fenchuganj 44MW (Energyprima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	180384	
97	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	62	1302720	
98	Shahjibazar 80MW PP (Shahjiba)	RPP	32*2.90	86	81	1797120	
99	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under Shut down
100	Sylhet 225 MW CAPP	PDB	1142+1189	231	218	5022350	
101	Sylhet 20 MW GTTP	PDB	1*20	20	18	394000	
102	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
103	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	0	181544	Engine problem
104	Bibiana-II 341 MW CAPP (Summ)	IPP	1122+1119	341	280	7191000	FGMO
105	Bibiyana-III 400 MW CAPP	PDB	400 MW	400	401	9360000	
106	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	172800	
107	Bibiyana South 400 MW	PDB	400 MW	383	401	9415800	
Sylhet Area Total				2377	1645	39525118	
108	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
109	Bheramara (NWDCL)	Imported power	21500	1000	792	18837090	
110	Khulna 115 PP MW (KPCL-2)	QRPP	7*17	0	0	0	Contract Expired
111	Fairdipur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve.
112	Khulna 225 MW CAPP	NWPGCL	1150+1175	230	0	0	Reserve.
113	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
114	Bheramara 410 MW CAPP	NWPGCL	1278+1132	410	360	9325440	FGMO
115	Noapara 40 MW CAPP (Khanjahan)	QRPP	5*18	40	0	0	Contract Expired
116	Noapara 100 MW PP (Bangla Tr)	IPP	70*1.4	100	100	470400	Engine problem
117	Rupsha 105 MW PP (Orion rupsa)	IPP	6*18.445	105	90	1128960	Engine problem
118	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2129	1342	29761890	
118	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Reserve.
119	Bhola 33 MW PP (Venture)	RPP	11*4.50	33	32	550328	Engine problem
120	Bhola 225 MW CAPP	PDB	2*63+1*68	194	84	2032000	Machine problem
121	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	11	283201	Gas shortage
122	Payra 1320 MW	BCPCL	2*622	1244	510	10212300	
123	Bhola Nutan Biddut BD LTD	IPP	220	0	221	4947300	On Test
124	Uniled Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line OIL
Barisal Area Total				1826	858	18025219	
124	Baghabari 71 MW GTTP	PDB	1*71	71	70	1570000	
125	Baghabari 100 MW GTTP	PDB	1*100	100	0	1064000	Gas shortage.
126	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	50	588288	
127	Bera 70 MW Peaking PP	PDB	9*8.29	71	40	95807	
128	Amura 50 MW PP(Sinha)	QRPP	7*7.79	50	35	183590	Low demand
129	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	24	82755	Low demand
130	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	23	328282	Engine problem
131	Sirajgonj Unit-1 225MW	NWPGCL	1150+1175	210	0	0	Gas shortage
132	Sirajgonj Unit-2 225MW	NWPGCL	1150+1175	220	191	4623955	FGMO
133	Sirajgonj Unit-3 225MW	NWPGCL	1141	220	185	4568991	FGMO
134	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	11282+1132	414	404	9440000	FGMO
135	Sanlahar 50 MW Peaking PP	PDB	6*8.7	50	23	158753	Low demand
136	Bogra 22 MW PP (GDB)	RPP	6*4	22	18	424080	Engine problem
137	Bogra 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	Contract Expired
138	Uliapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	10	183690	
139	Natore 52 MW PP (Rajshahi)	IPP	6*8.92	52	52	988900	
140	Chapainawabganj 100 MW Peak	PDB	12*8.924	104	95	1014368	Engine problem
141	Baghabari 200 MW PP (Paramo)	IPP	200 MW	200	0	0	Reserve.
142	Bagura 113 MW PP (Confidenc)	IPP	113 MW	113	112	544800	
143	Confidence Power Bogura Unit-1	IPP	6*18.55	113	90	627168	Engine problem
143	Sirajgonj 6.55 MW Solar	NWPGCL	1*6	6	0	31800	
Rajshahi Area Total				2179	1422	28519127	
144	Barapukuria TPP Unit-1	PDB	1125	85	0	0	Coal shortage