

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564687, 9551095

Month July, 2021		Day : Friday				Date : 09.07.21						
Probable Maximum Demand :		11900 MW		Probable Maximum Generation :		15105 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 80.00 ft		Today = 80.12 ft		Rule Curve = 85.28 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.07.21 (Yesterday)		09.07.21 (Today)		08.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening			
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	300	300	300	300			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	93	94	100	100			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.	
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	348	350	360	360			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	260	260	260	260	190	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	350	371	370	400			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	328	333	330	330			
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	100	100	100	100			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	280	285	300	300			
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55			
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	87	70	100			
17	Gaganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	94	100	102			
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	20	20			
19	Summit Power, (Madhab+Ashulia)	Gas (SIPP, PDB)	6x3.07+1x8.73	80	80	53	55	55	55			
20	Maona 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
21	Ruganaj 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	0	33	33			
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	25	25			
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	50	50			
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	98	150	150	150			
25	Katpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0			
26	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	286	250	250			
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	129	132	130	135			
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300			
30	Bramanganon 100 MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
31	Aushali 100MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
32	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	4	55	55	55			
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0			
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	104	90	104			
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	68	126	126	162			
37	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	24	0	30	0			
Dhaka Zone Total				5976	5819	2747	3511	3801	4088	400	870	
38	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	54	52	55	55	178	Low Water Level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknat 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	38	50	50			
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	110	110	110	110			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	204	210	215			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	0	200	300			
48	Juldah 100 MW Unit-1 (Accorn)	HFO (QRPP)	8x13.45	100	100	70	82	100	100			
49	Juldah 100 MW PP Unit-3 (Accorn)	HFO (IPP)	8x13.45	100	100	30	70	100	100			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	36	51	51			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	16	16	16			
*	Malancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	30	5	15			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	12	12			
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	85	110	110			
56	Juldah unit-2 (Accorn)	HFO (IPP)	8x13.5	100	100	100	100	100	100			
57	Chattogram 116 MW PP (Antima Ener)	HFO (IPP)	6x21.06	116	116	116	116	116	116			
Chattogram Zone Total				2442	2382	997	1169	1544	1634	178	180	
58	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	110	110	110	135	25	Gas Shortage	
	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	185	214	210	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	285	305	330	350			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	320	300	350	360			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	44	50	55	55			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	26	26	187	Gas shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	34	43	43	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	55	147	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	50	120	170	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	11	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	27	43	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, PDB)	3x3.67+2x6.97	25	25	18	20	21	21			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+8x1.95+1x1.08	200	200	0	0	100	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	114	114	114	114			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	115	114	113	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	36	36			
**	Impoiti (Tripura)	India		160	160	106	120	148	172			
Cumilla Zone Total				3094	3034	1596	1886	2111	2370	475	0	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	157	163	190	190	39	Gas Shortage	
80	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	21	21			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	8	8	8			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	3	184	175	200			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0			
85	Sutakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0			
86	Tangal 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22			
Mymensingh Zone Total				717	709	362	515	583	556	39	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.07.21 (Yesterday)		09.07.21 (Today)		08.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	43	43		27	Under maint.
88	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	Under maint.
89	Fenchuganj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	53	53	51	51			
90	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP_REB)	4x2.90	11	11	5	11	11	11			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	58	62	63			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	162	162	160	160			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	84	84	84			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	218	218	225	225			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	18	18	18			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP_REB)	3x9.34	25	25	16	16	16	16			
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	290	315	341			
100	Bibiyana-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0		400	Under maint.
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	389	398	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			
Sylhet Zone Total			2422	2377	1374	1391	1425	1452	0	487		
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	360	400	400	400			
105	Faridpur 50 MW Peaking PP	HFO (PDB)	6x8.98	54	54	0	21	0	20			
106	Capalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60			
107	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	100	220			
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	100	50	100			
109	Rupsha 105 MW PP (Onon rupsha)	HFO (IPP)	6x18.445	105	105	7	90	90	90			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			
**	Bheramara (HVDC)	India		1000	1000	792	792	818	818			
Khulna Zone Total			2133	2129	1159	1403	1558	1808	0	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	32	25	33			
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	86	86	85	86		108	G1-Z & STG Under maint.
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11			
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	340	500	622	622			
116	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110			
	Bhola Nutan Biddut BD LTD	Gas/HSD (IPP)				220	222	220	220			
Barishal Zone Total			1826	1826	676	851	1073	1192	0	108		
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	60	40	60	65			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	43			
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	42	0	40			
121	Amnura 50 MW PP(Siraha)	HFO (QRPP)	7x7.79	50	50	0	35	35	35			
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	55	95	50	95			
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	23	0	35			
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50			
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	42			
126	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		150	Gas Shortage, STG S/D
127	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	177	183	210	210			
128	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	180	199	200	200			
129	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	412	412	400	400			
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	18	18			
131	Ullapara 11 MW PP (Summit)	Gas (SIPP_REB)	4x2.90	11	11	8	8	11	11			
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52			
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	50	95	113	113			
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	5	113	113	113			
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Rajshahi Zone Total			2179	2179	1016	1369	1518	1722	250	0		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150		124	Coal Shortage
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10			
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	113	113	113			
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10			
141	Mapara, Tabla 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	4	0	8	0			
Rangpur Zone Total			685	605	188	263	271	283	294	0		
Sub-total: Plants in operation			21474	21060	10115.0	12358	13884	15105	1636	1645		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					9633	11769	13222	14385				
(B) Plants under long term maintenance/ contract expired												
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
144	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020
146	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
147	Meghnaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0			Contract Expired on 28/05/2021
Sub-Total: Plants under long term maintenance/ contract expired			549	0	0	0	0	0	0			
Gross Total			22023	21060	10115	12358	13884	15105	1636	1645		
(C) Actual data of 08.07.21 (Yesterday) Thursday :												
01.	Max. Demand at eve. peak (Generation end)	: 12358.00 MW, at = 21:00 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 11769.00 MW, at = 21:00 hrs										
03.	Highest Generation (Generation end)	: 12358.00 MW, at = 21:00 hrs										
04.	Minimum Generation (Generation end)	: 8693.00 MW, at = 7:00 hrs	Dhaka	4011	4011	0	Mymensingh	1056	1056	0		
05.	Day-peak Generation (Generation end)	: 10115.00 MW, at = 12:00 hrs	Chattogram	1196	1196	0	Sylhet	519	519	0		
06.	Evening-peak Generation (Generation end)	: 12358.00 MW, at = 21:00 hrs	Khulna	1437	1437	0	Barishal	342	342	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs	Rajshahi	1281	1281	0	Rangpur	804	804	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8845.00 MW, at = 5:00 hrs	Cumilla	1123	1123	0						
09.	Generation shortfall at evening peak due to :											
	a) Gas limitation	: 1164 MW										
	d) Coal supply Limitation	: 294 MW										
	b) Low water level in Kaptai lake	: 178 MW										
	c) Plants under shut down/ maintenance	: 1645 MW										
10.	Total Energy (Generation + India Import)	: 251.43 MCKWh										
	By Gas = 154.288 MCKWh	By Oil = 59.442 MCKWh										
	By Coal = 14.155 MCKWh	By Hydro = 1.197 MCKWh										
	By Solar = 0.549 MCKWh											
11.	Total Gas Supplied	: 1177.20 MCKWh										
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
			Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
						Total	11769	11769	0			
						Fuel cost :	(a) Gas = 161016339 Taka	(c) Coal = 65936586 Taka				
							(b) Oil = 416635905 Taka	Total = 643588830 Taka				
						14. Maximum Temperature in Dhaka was :	32.6° C					
						15. Export through East-West interconnections :						
						At evening peak-hour	: -200 MW, at 21:00 hrs					
						Maximum	: -200 MW, at 21:00 hrs					
						Energy	: 0.508 MCKWh					
(D) Forecast of 09.07.21 (Today) Friday :												
01.	Maximum Demand	: 11900 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 15105 MW (Generation end)	05.	Total Generation	: 242.11 MCKWh							
03.	Maximum Shortage	: -3205 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	: 34.7° C							

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation