

**EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : 14-Jul-21							Page -2
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CAPP Unit-1	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-2	PDB	1'210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1'210	190	0	126000	Gas shortage
4	Ghorasal 365 MW CAPP Unit-7	PDB	1'243+1'122	365	300	7096691	Gas shortage
5	Ghorasal 78.5 MW PPMAX	QRPP	2'40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regen)	IPP	343.35	108	105	2355545	
7	Haripur GTTP	SBU_PDB	2'32	20	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	275	6728000	Gas shortage
9	Haripur 360MW CAPP(HPL)	IPP	1'235+1'125	360	210	6270000	Gas shortage
10	Meghnaghat 450 MW CAPP(MP)	IPP	2'150+1'150	450	220	5153050	Gas shortage
11	Meghnaghat 100 MW (EL)	QRPP	12'8.9	0	0	0	Contract Expired
12	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	305	230	5829789	Gas shortage
13	Madanganj 102 PP(Summit)	QRPP	6'17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	3'17.08+1'11.3	55	55	585759	
15	Keraniganj 100 MW PP (Powerpa)	QRPP	8'13.45	100	85	853433	Engine problem
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	408276	
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
18	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	842000	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	12'8.9	100	100	2333136	
20	Siddhirgonj 335 MW CAPP	EGCB	1'217+1'118	335	324	3099147	
21	Gagnagar 102 MW PP (Digital Pa)	IPP	12'8.924	102	94	1181952	Engine problem
22	Katpotti 52 MW PP (Sinha)	IPP	77.9	51	0	0	Fuel shortage
23	Kamatnagar 54 MW PP(Banco E)	IPP	3'19	54	54	1189440	
24	Kodda 150MW PP	BFDB-RPCL	9'17.06	149	150	3180960	
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	699010	
26	Nabaganj 55 MW PP (Southern)	IPP	3'19.3	55	55	1055234	
27	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	108	0	0	Fuel shortage
28	Summit Power, Madhabdi+Ashul	SIPP, REB	3'3.67+8'7.3	80	55	1196520	Engine problem
29	Machra 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	721900	
30	Ruganaj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	667600	
31	Gazipur 52 MW PP	IPP	6'8.9	52	51	1172160	
32	Tongi 80 MW GTTP	PDB	1'105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Sumr)	IPP	18'17.076	300	275	4119925	Engine problem
34	Keraniganj 300 MW PP (AFR)	IPP	25'11.4	300	108	36068	Low demand
35	Bramhangonj 100 MW PP (Agg)	IPP	100	100	40	171636	Low demand
36	Aurahi 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	99	548239	
37	Kodda 149 MW PP Unit-1 (Sumr)	IPP	149	149	149	2309760	
38	Gazipur 100 MW PP	RPCL	100 MW	105	105	2560900	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'5	104	104	11817520	
40	Spectra 162MW PP(MPCL)	IPP	9'18	162	162	2988000	
41	Spectra Solar Plant Ltd.	IPP	35	35	0	225842	
<b>Dhaka area Total</b>			<b>5819</b>	<b>3545</b>	<b>6738912</b>		
41	Chattogram TPP-1	PDB	1'210	180	100	2400000	Gas shortage
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
43	Raazan 25 MW PP	IPP	3'8.9	25	25	554252	
44	Tokant 20MW PP (SolarTech)	SolarTech Energy	20	0	0	147825	
45	Patenga 50MW PP (Baraka)	IPP	8'6.98	50	50	526800	
46	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	2'40+3'50	230	88	1998678	Low water level & Unit-2 unc
47	Sikalbaha 225MW	PDB	1'150+1'175	225	203	4910808	FGMO
48	Sikalbaha Peaking GT	PDB	1'150	150	110	2672848	Machine problem
49	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	2509800	
50	Hathazari 100 MW peaking PP	PDB	11'8.9	98	0	0	Under S/D
51	Dohazari-Kalaish 100 MW Peak	PDB	6'17	102	51	470575	Engine problem
52	Juldah 100 MW Unit-1 (Acorn)	QRPP	8'13.45	100	82	2062920	
53	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	1548480	
54	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	22	493920	
55	Madarsha, Ctg. EZZ	IPP	5'8.73+9.34	0	25	454080	
56	Chattogram 108 MW PP (ECPV)	IPP	6'7	108	0	0	Fuel shortage
57	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	29520	
58	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0	Transformer O/L
59	Jodiac Power	IPP	3'18.55+1'3.6	54	0	0	Transformer O/L
60	Karnaphuli Power Ltd.	IPP	110	110	110	2476461	
61	Juldah unit-2 (Acorn)	IPP	8'13.6	100	100	1940160	
62	Anlima Energy Ltd.	IPP	6'21.2	116	94	2287036	Engine problem
<b>Chattogram area Total</b>			<b>2382</b>	<b>1285</b>	<b>27482723</b>		
61	Ashuganj TPP Unit- 3	APSCL	1'150	135	80	1937656	Gas Shortage
62	Ashuganj TPP Unit- 4	APSCL	1'150	129	0	0	Gas shortage
63	Ashuganj TPP Unit- 5	APSCL	1'150	134	0	0	Under maint.
64	Ashuganj 225 MW CAPP	APSCL	1'144+2'175	221	213	4784000	FGMO
65	Ashuganj 450 MW CAPP(North)	APSCL	1'360	360	330	7796300	FGMO
66	Ashuganj 450 MW CAPP(South)	APSCL	1'360	360	280	7432000	FGMO
67	Ashuganj 50 MW PP	APSCL	14'3.968	45	26	581472	Engine problem
68	Ashuganj 55 MW PP (Precision)	RPP	15'4	55	20	869280	Gas shortage
69	Ashuganj 150MW PP (APCL-U)	IPP	20'37+1'116	195	8	217454	Gas shortage
70	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	34	818380	Engine problem
71	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	150	3111272	
72	Tilas 50 MW Peaking PP	PDB	6'8.92	52	43	533352	
73	Chandpur 150 MW CAPP	PDB	1'106+1'57	163	86	1718300	Machine problem
74	Chandpur 200MW (Desh energy)	IPP	0	200	156	2425440	High voltage
75	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	22	463752	
76	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	8	216360	
77	Impoort (Tripura)	Imported power	0	160	132	3008640	
78	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	812700	
79	Jangalia 52 MW PP (Lakdanavi)	IPP	6'8.92	52	43	884534	Engine problem
80	Cumilla 25 MW PP (Summit)	SIPP, PDB	3'3.67+2'6.97	25	20	411410	Engine problem
81	Cumilla 200 MW PP (B.Trac)	IPP	154'11.6	200	200	968832	
82	Feni Lanka Power	IPP	7'18.415+1'9.78	114	114	2389440	
83	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	115	2662800	
84	Bhairab 54.5 MW	IPP	3'18.2	54	36	704520	33 kV feeder fault.
<b>Cumilla Area Total</b>			<b>3034</b>	<b>2149</b>	<b>44747894</b>		
82	RPCL 210MW CAPP	IPP	4'35+1'170	202	148	3519480	Gas shortage
83	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	21	459576	
84	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	95	8	188160	Engine problem
85	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	15000	
86	Mymensingh 200 MW PP (Unite)	IPP	200	200	184	3679200	
87	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	106	2620800	
88	Sutakhirali 50 MW PP	IPP	50	50	0	270590	
89	Tangail Palli Power Gen 22 MW	IPP	4'6.7	22	24	503520	
<b>Mymensingh Area Total</b>			<b>709</b>	<b>491</b>	<b>11243726</b>		
90	Fenchugonj CAPP Phase-1	PDB	2'32+1'33	70	43	1029000	Machine problem
91	Fenchugonj CAPP Phase-2	PDB	2'35+1'35	90	30	722280	Machine problem
92	Kushkhara 163 MW CAPP (KP)	IPP	1'109+1'54	163	0	0	Under maint.
93	Shahjibazar 338 MW CAPP	PDB	3'110	330	163	3613600	GT-1 under maint
94	Fenchugonj 51 MW PP (Barakat)	RPP	19'2.90	51	53	1169400	
95	Fenchugonj 44MW (Energyprim)	RPP	12'3.3+5'2	0	0	0	Contract Expired
96	Hobiganj 11MW PP Confidence-E	SIPP, REB	4'2.90	11	0	197136	
97	Shahjibazar GTTP Unit- 8 & 9	PDB	2'35	66	56	1335936	
98	Shahjibazar 86MW PP (Shahjiba)	RPP	32'2.90	86	84	1926720	
99	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under Shut down
100	Sylhet 225 MW CAPP	PDB	1'142+1'89	231	219	5080170	
101	Sylhet 20 MW GTTP	PDB	1'20	20	18	396000	
102	Sylhet 50MW PP (EPL)	RPP	2'72	0	0	0	Contract Expired
103	Shahjibazar 25 MW PP	SIPP, REB	3'9.34	25	16	290784	Engine problem
104	Bibiana-II 341 MW CAPP (Summ)	IPP	1'122+1'119	341	280	7116000	FGMO
105	Bibiyana-III 400 MW CAPP	PDB	400 MW	400	371	8856000	FGMO
106	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	252900	
107	Bibiyana South 400 MW	PDB	400 MW	383	397	9384600	FGMO
<b>Sylhet Area Total</b>			<b>2377</b>	<b>1740</b>	<b>41372826</b>		
108	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Reserve.
109	Bheramara (NWDCL)	Imported power	2'500	1000	814	19663636	
110	Khulna 115 PP MW (KPCL-2)	QRPP	7'17	0	0	0	Contract Expired
111	Fariapur 50 MW Peaking PP	PDB	8'6.89	54	19	120960	Engine problem
112	Khulna 225 MW CAPP	NWPGCL	1'150+1'175	230	155	755619	Low demand
113	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Reserve.
114	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	305	8891424	FGMO
115	Noapara 40 MW CAPP (Kharjahan)	QRPP	5'18.5	0	0	0	Contract Expired
116	Noapara 100 MW PP (Bangla Tr)	IPP	70'1.14	100	100	786240	
117	Rupsha 105 MW PP (Orion rupa)	IPP	6'18.445	105	105	1912320	
118	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
<b>Khulna Area Total</b>			<b>2129</b>	<b>1498</b>	<b>32150199</b>		
118	Barisal 110 MW PP (Summit )	IPP	7'17.076	110	0	0	Line O/L
119	Bhola 33 MW PP (Venture)	RPP	1'34.50	33	34	634384	
120	Bhola 225 MW CAPP	PDB	2'63+1'68	194	86	2058509	Machine problem
121	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	95	11	285768	Gas shortage
122	Payra 1320 MW	BCPCL	2'622	1244	450	11373600	Boiler problem
123	Bhola Nutan Biddut BD LTD	IPP	220	0	220	5056445	
124	United Payra Power Ltd.	IPP	8'18.5+1'9.5	150	54	372000	Line O/L
<b>Barisal Area Total</b>			<b>1826</b>	<b>655</b>	<b>19780796</b>		
124	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
125	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage
126	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	43	368608	
127	Bera 70 MW Peaking PP	PDB	9'8.29	71	4	133848	Engine problem
128	Amura 50 MW PP(Sinha)	QRPP	77'7.9	50	0	0	Fuel shortage
129	Katakhal 50 MW PP (Northern)	QRPP	6'8.9	50	43	771712	Engine problem
130	Katakhal 50 MW Peaking PP	PDB	6'8.7	50	30	257288	Engine problem
131	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'175	210	0	0	Gas shortage
132	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'175	220	170	4308591	Gas shortage
133	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	180	4677473	Gas shortage
134	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1'182+1'132	414	413	9440036	FGMO
135	Sanlahar 50 MW Peaking PP	PDB	6'8.7	50	29	285360	Engine problem
136	Bogra 22 MW PP (GDB)	RPP	6'4	22	21	491520	
137	Bogra 20 MW PP (Energyprima)	RPP	5'3+5'2	0	0	0	Contract Expired
138	Ulipara 11 MW PP (Summit)	SIPP, REB	4'2.90	11	11	246888	
139	Natore 52 MW PP (Rajshahi)	IPP	6'8.92	52	52	1094880	
140	Chapainawabganj 100 MW Peak	PDB	12'8.924	104	92	1684616	Engine problem
141	Baghabari 200 MW PP (Paramo)	IPP	200 MW	200	0	36633	Reserve.
142	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	94	1682976	Engine problem
143	Confidence Power Bogura Unit-1	IPP	6'18.55	113	95	1741248	Engine problem
143	Sirajgonj 6.55 MW Solar	NWPGCL	1'6	6	0	33900	