

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel: 9564667, 9551095

Month July, 2021		Day : Friday										Date : 23.07.21		
Probable Maximum Demand : 12700 MW		Probable Maximum Generation : 15144 MW												
Water Level of Kaptai Lake at 06:00 AM		Rule Curve = 87.52 ft.												
Sl. No.	Name of Power Station	Yesterday = Nos. of Unit X Capacity (MW)	84.25 ft Installed Capacity (MW)	Dera/ed/ Present Capacity (MW)	Today = 84.39 ft.		22.07.21 (Yesterday)		23.07.21 (Today)		22.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak		Probable Peak		Gen. shortfall for :		Machines shut down (MW)	Description/ Remarks		Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
<b>(A) Plants in operation:</b>														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	0	0	260	Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	0	180	Under Repowering		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	0	190	Under maint.		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	300	300	300	300	300	300			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	99	102	108	108	108	108			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	0	105	CB Problem		
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	0	20	Under Maint.		
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235-1x125	360	360	325	330	360	360	30	30	Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140-1x170	450	450	240	240	240	240	210	210	Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	0	115	Under Overhauling		
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	225	262	300	300	130	130	Gas Shortage		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	0	210	Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	318	330	335	335	335	335			
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	0	0	0	0	0			
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	300	290	300	300	300	300			
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08-1x11.3	55	55	0	0	55	55	55	55			
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	74	80	74	80			
17	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	100	102	100	102			
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	15	20	20	20	20			
19	Summit Power,(Madhabd+Ashulia)	Gas (SIPP, PDB)	6x3.07+4x3.73	80	80	6	31	55	55	55	55			
20	Maona 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	22	28	33	33	33	33			
21	Rupganj 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	8	33	33	33	33			
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	34	52	52	52	52			
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	35	100	100	100	100			
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	16	150	150	150	150			
25	Katpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0	0	0			
26	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	54	54	54	54			
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	270	270	270	270			
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	0	149	149	149	149			
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300	100	300			
30	Bramanganon 100 MW PP (Aggrako)	HSD (IPP)	23x0.85-91x.959	100	100	0	0	100	100	100	100			
31	Aushali 100MW PP (Aggrako)	HSD (IPP)	23x0.85-91x.959	100	100	0	0	50	100	50	100			
32	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	0	0	55	55	55	55			
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55	55	55			
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0	0	0			
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	90	104	90	104			
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	162	162	162	162			
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	14	0	30	0	30	0			
<b>Dhaka Zone Total</b>			<b>5976</b>	<b>5819</b>	<b>1873</b>	<b>2058</b>	<b>3730</b>	<b>3972</b>	<b>580</b>	<b>870</b>				
38	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	120	123	123	123	107	107	Low Water Level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0	5	5			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	10	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0	20	20			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.89	50	50	0	0	50	50	50	50			
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	34	105	105	105	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	120	120	120	120	120	120			
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150-1 x 75	225	225	0	0	0	0	225	225	Under maint.		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076-3x8.04	300	300	0	0	200	300	200	300			
48	Juldah 100 MW Unit-1 (Accorn)	HFO (QRPP)	8x13.45	100	100	40	95	100	100	100	100			
49	Juldah 100 MW PP Unit-3 (Accorn)	HFO (IPP)	8x13.45	100	100	0	0	100	100	100	100			
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	51	51	51	51			
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	0	0			
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	22	22	22	22			
*	Malancha Ctg EPZ (United)	Gas	5x8.73-3x9.34			40	42	40	40	40	40			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	96	96	97	97	97	97			
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	54	54	54	54			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	110	110	110	110	110			
56	Juldah unit-2 (Accorn)	HFO (IPP)	8x13.5	100	100	10	0	100	100	100	100			
57	Chattogram 116 MW PP (Antima Ener)	HFO (IPP)	6x21.06	116	116	97	111	112	112	112	112			
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>715</b>	<b>966</b>	<b>1534</b>	<b>1609</b>	<b>107</b>	<b>405</b>				
58	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	80	80	120	135	55	55	Gas Shortage		
	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	129	Gas Shortage		
	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	134	Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	0	26	26	26	26			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	209	214	210	210	210	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	260	360	360	360	360			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	175	175	175	175	185	185	Under maint.		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	25	20	55	55	55	55			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	45	8	45	45	187	187	Gas shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43	43	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	150	150	150	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50	50	50			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106-1x57	163	163	94	90	90	90	90	90			
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	180	170	200	200	200			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22	22	22			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	11	11	11	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	43	43	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, PDB)	3x3.67+2x6.97	25	25	20	21	21	21	21	21			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4-8x1.35+1x1.08	200	200	0	0	100	200	100	200			
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	113	113	113	113			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	102	105	113	113	113	113			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17	17	17			
**	Impoirt (Tripura)	India		160	160	104	130	138	162	162	162			
<b>Cumilla Zone Total</b>			<b>3094</b>	<b>3034</b>	<b>1056</b>	<b>1716</b>	<b>2105</b>	<b>2274</b>	<b>505</b>	<b>185</b>				
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	195	198	210	210	210	210			
80	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21	21	21			
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8	8	8			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115	115	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200										

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.07.21 (Yesterday)		23.07.21 (Today)		22.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation (MW)	Machines shut down (MW)			
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	42	40	43	43			Under maint.	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	42	42	42	42			Under maint.	
89	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	47	53	51	51				
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	0	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	51	62	63				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	155	160	163	163				
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	30	84	84				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	219	219	225	225				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	290	341	341				
100	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	392	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	377	395	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0				
<b>Sylhet Zone Total</b>					<b>2422</b>	<b>2377</b>	<b>1767</b>	<b>1698</b>	<b>1866</b>	<b>1867</b>	<b>0</b>	<b>241</b>	
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	365	395	360	400				
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	20				
106	Capalaganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60				
107	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	70	0	160				
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	105	105	105				
110	Madhumat 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)	India		1000	1000	678	733	789	789				
<b>Khulna Zone Total</b>					<b>2133</b>	<b>2129</b>	<b>1043</b>	<b>1403</b>	<b>1404</b>	<b>1734</b>	<b>0</b>	<b>0</b>	
111	Barsal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	16	29	33	33				
113	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0			Under maint.	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	52	76	66	76				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	400	540	622	622				
116	Potukhali 150MW PP (JUPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	72	110	110				
117	Bhola 220MW CCPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	212	219	220	220				
<b>Barishal Zone Total</b>					<b>2046</b>	<b>2046</b>	<b>680</b>	<b>936</b>	<b>1161</b>	<b>1171</b>	<b>0</b>	<b>194</b>	
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	71			Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	70	70	70			Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	50	50				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	20	20				
122	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0				
123	Chapanawabaganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	90	95	95				
124	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	31	31				
125	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	30				
127	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			Gas Shortage, STG S/D	
128	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	184	191	200	200				
129	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	153	156	200	200				
130	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	402	406	400	400				
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
132	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	9	11	11	11				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	24	52	52	52				
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	95	113	113				
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	90	90	90				
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
<b>Rajshahi Zone Total</b>					<b>2179</b>	<b>2179</b>	<b>831</b>	<b>1243</b>	<b>1560</b>	<b>1584</b>	<b>251</b>	<b>0</b>	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	75	70	74	74			Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage	
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	149	149	150	150			Coal Shortage	
139	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	113	113	113				
141	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
142	Majpara, Tabula 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
<b>Rangpur Zone Total</b>					<b>685</b>	<b>605</b>	<b>231</b>	<b>332</b>	<b>345</b>	<b>357</b>	<b>225</b>	<b>0</b>	
<b>Sub-total: Plants in operation</b>					<b>21694</b>	<b>21280</b>	<b>8576.0</b>	<b>10908</b>	<b>14308</b>	<b>15144</b>	<b>1668</b>	<b>1895</b>	
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>							<b>8135</b>	<b>10347</b>	<b>13572</b>	<b>14365</b>			
<b>(B) Plants under long term maintenance/ contract expired</b>													
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
144	Bogura 20 MW PP (Energysigma)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
145	Maghmaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					337	0	0	0	0				
<b>Gross Total</b>					<b>22031</b>	<b>21280</b>	<b>8576</b>	<b>10908</b>	<b>14308</b>	<b>15144</b>	<b>1668</b>	<b>1895</b>	
<b>(C) Actual data of 22.07.21 (Yesterday) Thursday :</b>													
01.	Max. Demand at eve. peak (Generation end)	:	10908.00	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	10347.00	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11208.00	MW, at =	23:00 hrs	Dhaka	2909	2909	0	Mymensingh	899	899	0
04.	Minimum Generation (Generation end)	:	8251.00	MW, at =	9:00 hrs	Chattogram	1073	1073	0	Sylhet	294	294	0
05.	Day-peak Generation (Generation end)	:	8576.00	MW, at =	12:00 hrs	Khulna	1499	1499	0	Barishal	368	368	0
06.	Evening-peak Generation (Generation end)	:	10908.00	MW, at =	21:00 hrs	Rajshahi	1320	1320	0	Rangpur	802	802	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs	Cumilla	1183	1183	0				
08.	Minimum Generation Forecast up to 8.00 hrs.	:	7820.00	MW, at =	5:00 hrs					Total	10347	10347	0
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost: (a) Gas = 153109795 Taka (c) Coal = 82933425 Taka						
	a) Gas limitation	:	1336	MW						(b) Oil = 316693268 Taka	Total =	552736487	Taka
	d) Coal supply Limitation	:	225	MW									
	e) Low water level in Kaptai lake	:	107	MW									
	c) Plants under shut down/ maintenance	:	1895	MW									
10.	Total Energy (Generation + India Import)	:	231.37	MKWWh		14.	Maximum Temperature in Dhaka was : 34.8° C						
	By Gas = 145.137 MKWWh			By Oil = 45.375 MKWWh		15.	Export through East-West interconnections :						
	By Coal = 17.375 MKWWh			By Hydro = 2.895 MKWWh			At evening peak-hour : -296 MW, at 21:00 hrs						
	By Solar = 0.784 MKWWh						Maximum : -486 MW, at 1:00 hrs						
11.	Total Gas Supplied	:	1132.02	MMCFD			Energy : 4.2795 MKWWh						
<b>(D) Forecast of 23.07.21 (Today) :</b>													
01.	Maximum Demand	:	12700	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	15144	MW	(Generation end)	05.	Total Generation : 262.17 MKWWh						
03.	Maximum Shortage	:	-2444	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 32.3° C						

#Remarks : Highest Generation 13792 MW on 27.04.2021 at 20:00

(Fazul Islam Shaker)  
Deputy Secretary, Generation