

Date : 24-Aug-21		Present Capacity		Peak Hour	Energy Generated	Remarks	
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Generation			
		Unit No. X Capacity		MW	MW		KWH
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1250	250	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1210	190	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1210	190	0	0	Gas shortage
4	Ghorasal 365 MW CAPP Unit-7	PDB	1243+1122	365	310	7196227	Machine problem
5	Ghorashah 78.5 MW PP(MAX)	QRPP	240	0	0	0	Contract Expired
6	Ghorashah 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
7	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1272+1139	412	402	9345456	
9	Haripur 360MW CAPP(HPL)	IPP	1235+1125	360	189	5156000	Gas shortage
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2150+1150	450	270	6397000	Gas shortage
11	Meghnaghat 100 MW(LEL)	QRPP	12*9	0	0	0	Contract Expired
12	Meghnaghat CAPP(Summit)	IPP	2110+1110	305	270	6592553	FGMO
13	Madangan 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
14	Madangan 355 MW PP(Summit)	(IPP)	317.08+111.3	55	40	955600	Engine problem
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	0	0	Reserve.
16	Narshingi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	21	361224	
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 2120 MW GTTP	EGCB	2105	210	0	0	Gas shortage
19	Siddhirgonj 100 PPI(Dutch Bangla)	QRPP	12*9	100	0	0	Contract Expired
20	Siddhirgonj 335 MW CAPP	EGCB	1274+1118	335	329	7646812	
21	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	102	1881072	
22	Kalpoti 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	1113840	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	2401440	
25	Mankiganj 55 MW PP (Northern)	IPP	31*9.3	55	55	1318888	
26	Nababganj 55 MW PP (Southern power)	IPP	31*9.3	55	55	1323987	
27	Bostia 108MW PPI(CLO)	IPP	12*8.775+113.5	108	0	0	Fuel shortage
28	Summit Power (Madhabadi+Ashulia)	SIPP, REB	33.67+48.73	80	45	975480	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4.8.73	33	30	817700	
30	Rugganj 33 MW PP(Summit)	SIPP, REB	4.8.73	33	33	736700	
31	Gazipur 52 MW PP	IPP	6*8.9	52	51	758400	
32	Tongi 80 MW GTTP	PDB	11105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	285	5018180	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	305	1688448	
35	Bramhangonj 100 MW PP (Aggreko)	IPP	100	100	100	875911	
36	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	101	1269697	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3457152	
38	Gazipur 100 MW PP	RPCL	100 MW	105	90	1531200	Engine problem
39	Meghnaghat 14 MW PP (OPCL)	IPP	18.516	104	94	1606160	Engine problem
40	Mankiganj 162MW PPI(MPL)	IPP	9*18	162	144	3848000	Engine problem
41	Spectra Solar Plant Ltd.	IPP	35	35	0	133059	
<b>Dhaka area Total</b>				<b>5819</b>	<b>3674</b>	<b>74851046</b>	
42	Chattoogram TPP-1	PDB	1210	180	100	2400000	Gas shortage
43	Chattoogram TPP-2	PDB	1210	180	0	0	Gas shortage
44	Rozzan 25 MW PP	IPP	3*8.9	25	25	428812	
45	Teknaf 20MW PP (Solartech)	Teknaf Solartech Energy	20	20	0	58400	
46	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	50	817920	
47	Kaptai Hydro Unit-1,2,3,4, 5	PDB	240+3*50	230	124	2292996	Low water level
48	Sikalbaha 225MW	PDB	1150+1175	225	0	0	Under maint.
49	Sikalbaha Peaking GT	PDB	1150	150	0	0	Under maint.
50	Sikalbaha 105 MW PP (Baraka Sikalbahat)	IPP	105 MW	105	105	2540036	
51	Hathazari 100 MW Peaking PP	PDB	11*9	98	0	0	Under SID
52	Dohazari-Kalesh 100 MW Peaking	PDB	8*17	102	68	1096205	Engine problem
53	Juidah 100 MW Unit-1 (Acom)	QRPP	8*13.45	100	92	2016240	
54	Juidah 100 MW PP Unit-3 (Acom)	IPP	0	100	100	2373120	
55	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	20	480240	
56	Malancha, Ctg. EPZ (United)	IPP	5*8.73+9.34	0	6	377760	
57	Chattoogram 168 MW PP (ECPV)	IPP	16*17	168	6	146880	Engine problem
58	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	28201	
59	Anwara 300 MW PP (Unite)	IPP	300 MW	300	142	3389782	Transformer OIL
60	Jodac Power	IPP	318.55+113.6	54	0	0	Transformer OIL
61	Karnaphuli Power Ltd.	IPP	110	110	110	2571816	
62	Juidah unit-2 (Acom)	IPP	8*13.6	100	100	2430720	
63	Anilma Energy Ltd.	IPP	6*21.2	116	114	2742436	
<b>Chattoogram area Total</b>				<b>2382</b>	<b>1162</b>	<b>26192564</b>	
64	Ashuganj TPP Unit-3	APSC	1150	135	0	0	Gas shortage
65	Ashuganj TPP Unit-4	APSC	1150	129	0	0	Gas shortage
66	Ashuganj TPP Unit-5	APSC	1150	134	70	1683024	Gas shortage
67	Ashuganj 225 MW CAPP	APSC	1142+175	221	180	4230000	FGMO
68	Ashuganj 450 MW CAPP(North)	APSC	1360	360	270	6828000	FGMO
69	Ashuganj 450 MW CAPP(South)	APSC	1360	360	270	6719000	FGMO
70	Ashuganj 50 MW PP	APSC	143.968	45	5	148176	Gas shortage
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	0	75360	Gas shortage
72	Ashuganj 195MW PP (APSC-United)	IPP	20*9.73+116	195	8	200727	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	35	828916	Engine problem
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	118	2937309	Engine problem
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	49	594264	
76	Chandpur 150 MW CAPP	IPP	1108+157	163	131	3275280	Engine problem
77	Chandpur 200MW (Desh energy)	IPP	0	200	160	3964320	
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	506052	
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	253080	
80	Impoport (Tripura)	Imported power	0	160	144	2817600	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	728100	
82	Jangalia 52 MW PP (Kadranav)	IPP	6*8.92	52	52	1066909	
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	31*8.726.97	25	21	519350	
84	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	200	1452864	
85	Feni Lanka Power	IPP	718.415+19.78	114	114	1923180	
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	98	1819440	Engine problem
87	Bhairab 54.5 MW	IPP	31*8.2	54	35	507960	33 kV feeder fault.
<b>Cumilla Area Total</b>				<b>3034</b>	<b>2032</b>	<b>43070941</b>	
88	RPCL 210MW CAPP	IPP	4155+170	202	102	2333640	Gas shortage
89	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	472428	
90	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	0	0	Engine problem
91	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	8600	
92	Mymensingh 200 MW PP (Unite)	IPP	200	200	176	3360000	Engine problem
93	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	107	2670000	
94	Sylhet 225 MW Solar PP	IPP	50	50	0	180570	
95	Tangail Fall Power Gen 22 MW	IPP	4*6.7	22	24	555360	
<b>Mymensingh Area Total</b>				<b>709</b>	<b>430</b>	<b>9610558</b>	
96	Fenchugonj CAPP Phase-1	PDB	2132+133	70	44	1033000	Machine problem
97	Fenchugonj CAPP Phase-2	PDB	2135+135	90	42	987120	Machine problem
98	Kushara 163 MW CAPP (KP)	IPP	1109+154	163	163	3599918	
99	Shahjibazar 330 MW CAPP	PDB	31110	330	234	5364000	Machine problem
100	Fenchugonj 51 MW PP (Barakattillah)	RPP	1972.90	51	53	1236600	
101	Fenchugonj 44MW (Energy/lima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
102	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	77952	
103	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	0	0	Under maint.
104	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	83	1916160	
105	Shahjibazar 100 MW GTTP	PDB	1100	100	0	0	Under Shut down
106	Sylhet 225 MW CAPP	PDB	1142+169	231	0	0	Under Shut down
107	Sylhet 20 MW GTTP	PDB	12*20	20	18	401000	
108	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
109	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	19	561312	Engine problem
110	Bibiana-II 341 MW CAPP (Summit)	IPP	1222+1119	341	295	7291000	FGMO
111	Bibiana-III 400 MW CAPP	PDB	400 MW	400	365	9289000	
112	Sylhet 100MW PP (Desh)	RPP	61.95	10	10	231840	
113	Bibiana South 400 MW	PDB	400 MW	383	350	7101400	Gas shortage
<b>Sylhet Area Total</b>				<b>2377</b>	<b>1687</b>	<b>3808302</b>	
114	Bheramara GTTP Unit-3	PDB	120	16	0	0	Reserve.
115	Bheramara (HVDC)	Imported power	2500	1000	690	16692363	
116	Khulna 115 PP MW (KPCCL-2)	QRPP	717	0	0	0	Contract Expired
117	Fairdour 50 MW Peaking PP	PDB	8*6.89	54	25	141830	Engine problem
118	Khulna 225 MW CAPP	NWPGL	1150+175	230	69	332160	Low demand
119	Gopalganj 100 MW Peaking PP	PDB	16*6.98	100	0	0	Reserve.
120	Bheramara 410 MW CAPP	NWPGL	1278+1132	410	245	6107328	Gas shortage
121	Noapara 40 MW PP (Khanjahan Ali)	QRPP	5*8.5	0	0	0	Contract Expired
122	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	100	583680	
123	Rupsha 105 MW PP (Orion rupsha)	IPP	618.445	105	105	2100000	
124	Madhumati 100 MW PP	NWPGL	100 MW	105	0	0	Line OIL
<b>Khulna Area Total</b>				<b>2129</b>	<b>1225</b>	<b>2897361</b>	
125	Barisal 110 MW PP (Summit)	IPP	717.076	110	0	0	Reserve.
126	Bhola 33 MW PP (Venture)	RPP	134.50	33	34	667223	
127	Bhola 225 MW CAPP	PDB	263+168	194	88	2103216	Machine problem
128	Bhola 95 MW PP (Aggreko)	QRPP	96*1.0	95	11	272203	Gas shortage
129	Payra 1320 MW	BCPCL	2622	1244	540	12324500	
130	Bhola Nutan Biddu BD LTD	IPP	220	220	219	4998109	
131	Unite Payra Power Ltd.	IPP	818.5+19.5	150	35	269200	Line OIL
<b>Barisal Area Total</b>				<b>2046</b>	<b>927</b>	<b>2624451</b>	
132	Baghabari 71 MW GTTP	PDB	171	71	0	0	Gas shortage
133	Baghabari 100 MW GTTP	PDB	1100	100	0	0	Gas shortage
134	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	43	268896	Engine problem
135	Bera 70 MW Peaking PP	PDB	9*8.29	71	40	240731	Engine problem
136	Amnara 50 MW PPI(Siha)	QRPP	71.79	50	0	0	Fuel