

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel.: 9564667, 9551095

Month August, 2021		Day : Thursday				Date : 26.08.21					
Probable Maximum Demand : 13000 MW		Probable Maximum Generation : 14669 MW				Rule Curve = 97.02 ft.					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 93.52 ft.		Today = 94.30 ft.		25.08.21 (Yesterday) 26.08.21 (Today)					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Rated/ Present Capacity (MW)	Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Water/Coal limitation MW	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Day	Evening	Day	Evening			
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	300	310	310		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	194	190	250	250	170	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270	180	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	397	383	412	412		
11	Siddhirgonj 210 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	326	290	335	335		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	0	0	0		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	255	270	300	300		
15	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40		
16	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	86	86		
17	Ganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	100	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	21	22	22		
19	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	45	44	47	47		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	51	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	90	90		
24	Kodda 150MW PP	HFO (BDOB-RPCL)	9x17.06	149	149	133	150	150	150		
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	25	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	200	280	300	300		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149		
29	Keranganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	304	100	300		
30	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	100	100	100		
31	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	15	101	50	100		
32	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
34	Bosila 108MW PP(RCLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	96	94	90	95		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
37	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	18	0	30	0		
<b>Dhaka Zone Total</b>			<b>5976</b>	<b>5819</b>	<b>3053</b>	<b>3636</b>	<b>3675</b>	<b>3902</b>	<b>688</b>	<b>850</b>	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	127	122	120	124	108	Low Water Level
	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0		
41	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	10	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50		
44	Sikalbaha 105 MW PP (Baraka Sikalab)	HFO (IPP)	6x18.415	105	105	90	17	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	126	305	200	300		
48	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	70	92	100	100		
49	Juddah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	90	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	102	102		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	21		
*	Malancha Cig EPZ (United)	Gas	5x8.73+3x9.34			2	7	5	20		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	6	6	6		
54	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	34	110	110		
56	Juddah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	114	114	116	116		
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>1042</b>	<b>1167</b>	<b>1338</b>	<b>1433</b>	<b>108</b>	<b>555</b>	
58	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	70	70	70	70	64	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5	40	Gas Shortage
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	173	171	215	215		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	270	270	330	360		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x360	360	360	270	270	330	360		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	5	5	55		Gas shortage
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+11'6	195	195	8	8	8	8	187	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	35	35	35		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	125	135	125	130		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50		
68	Chandour 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	137	140	140		
69	Chandour 200MW (Dash energy)	HFO (IPP)	12x18.415	200	200	161	160	200	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	5	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	20	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	20	21		
75	Daukidandi 200 MW PP (B.Trac)	HSD (IPP)	9x11.4+8x11.95+1x11.95	200	200	0	200	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	100	114	114	114		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	96	99	98	98		
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	18	35		
**	Impoort (Tijpura)	India		160	160	108	138	138	164		
<b>Cumilla Zone Total</b>			<b>3094</b>	<b>3034</b>	<b>1698</b>	<b>1980</b>	<b>2119</b>	<b>2328</b>	<b>610</b>	<b>0</b>	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	99	100	120	120	102	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	21	21	21		
81	Jamalpur 55 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	6	6	6		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
83	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	160	185	200	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
85	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0		
86	Tangail 22 MW PP(PPLCL)	HFO (IPP)	4x6.7	22	22	9	24	22	22		
<b>Myensingh Zone Total</b>			<b>717</b>	<b>709</b>	<b>450</b>	<b>445</b>	<b>536</b>	<b>484</b>	<b>102</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.08.21 (Yesterday)		26.08.21 (Today)		25.08.21 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
87	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	43	44		26	Under maint.
88	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	50	51	51			
90	Kushihara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage
93	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	236	234	270	270			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	81	84	84			
95	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0	231		Gas Shortage
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24			
99	Bitiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	341	341			
100	Bitiyana-II 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	374	402	400	400			
101	Bitiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	350	350	350	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			
<b>Sylhet Zone Total</b>				<b>2422</b>	<b>2377</b>	<b>1695</b>	<b>1729</b>	<b>1807</b>	<b>1858</b>	<b>297</b>	<b>74</b>	
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	280	270	300	330	140		Gas Shortage
105	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	25	0	25			
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60			
107	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 159+1x75	230	230	0	154	0	158			
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.44+7x1.515	100	100	0	100	50	100			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100			
** Bheramara (HVDC) India				1000	1000	691	697	702	702			
<b>Khulna Zone Total</b>				<b>2133</b>	<b>2129</b>	<b>1076</b>	<b>1351</b>	<b>1257</b>	<b>1580</b>	<b>140</b>	<b>0</b>	
111	Baisali 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	32	33	33			
113	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	88	88	88	88	106		Under maint.
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	12	12			
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	370	540	622	622			
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	150	150			
117	Bhola 220MW CCGP (Nutan Bidyut Bt)	Gas/HSD (IPP)	2x75+1x70	220	220	216	216	220	220			
<b>Barishal Zone Total</b>				<b>2046</b>	<b>2046</b>	<b>706</b>	<b>922</b>	<b>1235</b>	<b>1235</b>	<b>0</b>	<b>106</b>	
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	71			Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50			
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	200	200	200			
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	38	0	40			
122	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			
123	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	94	95	95			
124	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	31			
125	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0			
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	0	23			
127	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0			Gas Shortage,STG S/D
128	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	165	160	200	200			
129	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	195	182	220	220			
130	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	403	343	400	400			
131	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22			
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	43	43	43	43			
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	113	113	113	113			
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6'18.55	113	113	113	113	113	113			
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0			
<b>Rajshahi Zone Total</b>				<b>2179</b>	<b>2179</b>	<b>1064</b>	<b>1424</b>	<b>1503</b>	<b>1561</b>	<b>171</b>	<b>0</b>	
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			Coal Shortage
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	153	152	155	155	122		Coal Shortage
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10			
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	107	113	113	113			
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10			
142	Mapara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0			
<b>Rangpur Zone Total</b>				<b>685</b>	<b>605</b>	<b>264</b>	<b>265</b>	<b>276</b>	<b>288</b>	<b>292</b>	<b>0</b>	
<b>Sub-total: Plants in operation</b>				<b>21694</b>	<b>21280</b>	<b>11048.0</b>	<b>12919</b>	<b>13746</b>	<b>14669</b>	<b>2408</b>	<b>1585</b>	
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>						<b>10521</b>	<b>12303</b>	<b>13090</b>	<b>13970</b>			
<b>(B) Plants under long term maintenance/ contract expired</b>												
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
144	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
145	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>				<b>337</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>Gross Total</b>				<b>22031</b>	<b>21280</b>	<b>11048</b>	<b>12919</b>	<b>13746</b>	<b>14669</b>	<b>2408</b>	<b>1585</b>	
<b>(C) Actual data of 25.08.21 (Yesterday) Wednesday :</b>												
01.	Max. Demand at eve. peak (Generation end)	: 12919.00 MW, at = 19:30 hrs		12.		Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	: 12303.00 MW, at = 19:30 hrs		Zone		Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	: 12919.00 MW, at = 19:30 hrs		Dhaka		MW	MW	MW	Mymensingh	MW	MW	MW
04.	Minimum Generation (Generation end)	: 9650.00 MW, at = 7:00 hrs		Chattogram		4510	4510	0	Sylhet	908	908	0
05.	Day-peak Generation (Generation end)	: 11048.00 MW, at = 12:00 hrs		Khulna		1252	1252	0	Barishal	463	463	0
06.	Evening-peak Generation (Generation end)	: 12919.00 MW, at = 19:30 hrs		Rajshahi		1551	1551	0	Rangpur	381	381	0
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:30 hrs		Cumilla		1282	1282	0		829	829	0
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9513.00 MW, at = 5:00 hrs				1127	1127	0				
09.	Generation shortfall at evening peak due to :							Total		12303	12303	0
	a) Gas limitation	: 2008 MW						(a) Gas = 142330207 Taka		(c) Coal = 74020832 Taka		
	d) Coal supply Limitation	: 292 MW						(b) Oil = 673837064 Taka		Total = 890188103 Taka		
	b) Low water level in Kaptai lake	: 108 MW										
	c) Plants under shut down/ maintenance	: 1585 MW										
10.	Total Energy (Generation + India Import)	: 273.20 MKWh						14. Maximum Temperature in Dhaka was : 32.6° C				
	By Gas = 144.506 MKWh	By Oil = 89.660 MKWh						15. Export through East-West interconnections :				
	By Coal = 15.974 MKWh	By Hydro = 2.915 MKWh						At evening peak-hour : -250 MW, at 19:30 hrs				
	By Solar = 0.556 MKWh							Maximum : -400 MW, at 1:00 hrs				
11.	Total Gas Supplied	: 1103.61 MCFD						Energy : 2.6805 MKWh				
<b>(D) Forecast of 26.08.21 (Today) Thursday :</b>												
01.	Maximum Demand	: 13000 MW (Generation end)		04.		Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	: 14669 MW (Generation end)		05.		Total Generation : 274.91 MKWh						
03.	Maximum Shortage	: -1669 MW (Generation end)		06.		Probable Max. Temperature in Dhaka : 32.7° C						

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)  
Deputy Secretary, Generation