

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel.: 9564667, 9551095

Month August, 2021		Day : Sunday				Date : 29.08.21					
Probable Maximum Demand :		13500 MW		Probable Maximum Generation :		14423 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 95.34 ft.		Today = 95.92 ft.		Rule Curve = 98.01 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Rated/ Present Capacity (MW)	28.08.21 (Yesterday)		29.08.21 (Today)		Gen. shortfall for : Gas/Water/Coal limitation MW	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
<b>(A) Plants in operation:</b>											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	300	310	310	310		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Hanipur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	191	171	250	250	189	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	270	270	270	270	180	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	396	0	0	0	412	Under maint.
11	Siddhirgonj 210 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	92	100	100	118	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	315	316	335	335		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	0	0	0		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	305	305	290	300	300	300		
15	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	40	40		
16	Keranganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	14	85	86	86		
17	Ganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	100	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	21	22	22		
19	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	47	47	47	47		
20	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33		
21	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	35	51	52	52		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	19	90	105	105		
24	Kodda 150MW PP	HFO (BPOB-RPCL)	9x17.06	149	149	32	100	150	150		
25	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	115	300	300	300		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	133	149	149	149		
29	Keranganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	308	100	300		
30	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	100	100	100		
31	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.969	100	100	0	100	50	100		
32	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
33	Manikgonj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
34	Bosila 108MW PP(RCLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	94	95	90	95		
36	Manikgonj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	162	162	162	162		
37	Manikgonj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	14	0	30	0		
<b>Dhaka Zone Total</b>			<b>5976</b>	<b>5819</b>	<b>2727</b>	<b>3431</b>	<b>3378</b>	<b>3605</b>	<b>805</b>	<b>1072</b>	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	127	122	123	123	108	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	120	120	120	120		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
41	Racoon 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	12	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	17	91	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	306	160	300	300		
48	Juddah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	45	93	100	100		
49	Juddah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	90	90	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	85	85		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	20	20	21		
*	Malancha Cig EPZ (United)	Gas	5x8.73+3x9.34			2	14	10	20		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
54	Sikalbaha 54 MW Power Plant(Jodioc Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	110	110	110		
56	Juddah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	92	100	100	100		
57	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	53	115	116	116		
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>904</b>	<b>1178</b>	<b>1443</b>	<b>1429</b>	<b>288</b>	<b>375</b>	
58	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	100	100	80	80	34	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	23	23	23	22	Gas Shortage
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	181	167	215	215		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	330	330	330	360		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	0	260	260	360	Under maint.
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	51	56	55	55		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	55	63	55	55	132	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	35	35	35		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	137	127	132	138		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50		
68	Chandour 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	138	140	140		
69	Chandour 200MW (Dash energy)	HFO (IPP)	12x18.415	200	200	156	200	200	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	36	43	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	21		
75	Daukandi 200 MW PP (B.Trac)	HSD (IPP)	9x11.4+8x11.95+1x11.95	200	200	0	200	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	80	114	114	114		
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	96	105	98	98		
78	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	35		
**	Impoort (Tijpura)	India		160	160	102	146	138	163		
<b>Cumilla Zone Total</b>			<b>3094</b>	<b>3034</b>	<b>1575</b>	<b>1986</b>	<b>2171</b>	<b>2351</b>	<b>452</b>	<b>360</b>	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	106	118	120	120	84	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	21	21	21		
81	Jamalpur 55 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	65	40	65		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	63	184	185	185		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0		
85	Sulakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	26	0	50	0		
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	24	22	22		
<b>Mymensingh Zone Total</b>			<b>717</b>	<b>709</b>	<b>198</b>	<b>420</b>	<b>448</b>	<b>421</b>	<b>84</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.08.21 (Yesterday)		29.08.21 (Today)		28.08.21 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	44	44		26	Under maint.		
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51					
90	Kushihara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage		
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	233	235	235	235					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x29.20	86	86	77	83	84	84					
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	220	225	225					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24					
99	Bitiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	341	341					
100	Bitiyana-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	387	400	400	400					
101	Bitiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	350	350	350					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0					
<b>Sylhet Zone Total</b>				<b>2422</b>	<b>2377</b>	<b>1923</b>	<b>1943</b>	<b>1998</b>	<b>1998</b>	<b>66</b>	<b>74</b>			
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	280	260	300	330	150		Gas Shortage		
105	Fandpur 50 MW Peaking PP	HFO (PDB)	6x8.98	54	54	0	25	0	25					
106	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60					
107	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	158					
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.44+7x1.515	100	100	0	100	50	100					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	59	88	105	105					
110	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
** Bheramara (HVDC) India				1000	1000	706	707	720	720					
<b>Khulna Zone Total</b>				<b>2133</b>	<b>2129</b>	<b>1045</b>	<b>1180</b>	<b>1275</b>	<b>1598</b>	<b>150</b>	<b>0</b>			
111	Bairisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	1	11	33	33					
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	88	87	88	88	107		Under maint.		
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11					
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	340	570	622	622					
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150					
117	Bhola 220MW CAPP (Nutan Bidyut Bt)	Gas/HSD (IPP)	2x75+1x70	220	220	215	217	220	220					
<b>Barishal Zone Total</b>				<b>2046</b>	<b>2046</b>	<b>655</b>	<b>896</b>	<b>1234</b>	<b>1234</b>	<b>0</b>	<b>107</b>			
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	71			Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	200	200	200					
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	32	25	40					
122	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0					
123	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	85	95	95					
124	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	30	31					
125	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
126	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	32			Gas Shortage,STG S/D		
127	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	110	119	120	120					
128	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0					
129	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	196	182	220	220					
130	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	404	410	400	400					
131	Bogra 22 MW PP (CBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22					
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	34	43	52	52					
134	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113					
135	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	113	113					
136	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0					
<b>Rajshahi Zone Total</b>				<b>2179</b>	<b>2179</b>	<b>986</b>	<b>1444</b>	<b>1457</b>	<b>1499</b>	<b>171</b>	<b>0</b>			
137	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			Coal Shortage		
138	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	156	152	155	155	122		Coal Shortage		
139	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
140	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	80	113	113	113					
141	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
142	Mapara, Tutula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0					
<b>Rangpur Zone Total</b>				<b>685</b>	<b>605</b>	<b>238</b>	<b>265</b>	<b>276</b>	<b>288</b>	<b>292</b>	<b>0</b>			
<b>Sub-total: Plants in operation</b>				<b>21694</b>	<b>21280</b>	<b>10251.0</b>	<b>12743</b>	<b>13680</b>	<b>14423</b>	<b>2308</b>	<b>1988</b>			
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>						<b>9792</b>	<b>12173</b>	<b>13068</b>	<b>13778</b>					
<b>(B) Plants under long term maintenance/ contract expired</b>														
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
144	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
145	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
146	Khulna 115 MW PP (KPL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired				337	0	0	0	0	0					
<b>Gross Total</b>				<b>22031</b>	<b>21280</b>	<b>10251</b>	<b>12743</b>	<b>13680</b>	<b>14423</b>	<b>2308</b>	<b>1988</b>			
<b>(C) Actual data of 28.08.21 (Yesterday) Saturday :</b>														
01.	Max. Demand at eve. peak (Generation end)	:	12743.00	MW,	at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12173.00	MW,	at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12743.00	MW,	at =	20:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	9230.00	MW,	at =	8:00 hrs	Dhaka	4446	4446	0	Mymensingh	954	954	0
05.	Day-peak Generation (Generation end)	:	10251.00	MW,	at =	12:00 hrs	Chattogram	1302	1302	0	Sylhet	562	562	0
06.	Evening-peak Generation (Generation end)	:	12743.00	MW,	at =	20:00 hrs	Khulna	1455	1455	0	Barishal	298	298	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	20:00 hrs	Rajshahi	1205	1205	0	Rangpur	768	768	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9836.00	MW,	at =	5:00 hrs	Cumilla	1183	1183	0				
09.	Generation shortfall at evening peak due to :	:									Total	12173	12173	0
	a) Gas limitation	:	1908	MW			13.	Fuel cost :	(a) Gas = 149261136 Taka	(c) Coal = 72274482 Taka				
	d) Coal supply Limitation	:	292	MW				(b) Oil = 612000065 Taka	Total = 833535683 Taka					
	b) Low water level in Kaptai lake	:	108	MW										
	c) Plants under shut down/ maintenance	:	1988	MW			14.	Maximum Temperature in Dhaka was :	34.0° C					
10.	Total Energy (Generation + India Import)	:	278.98	MKWh			15.	Export through East-West interconnections :						
	By Gas = 145.122 MKWh			By Oil = 80.689 MKWh			At evening peak-hour	:	-150	MW,	at	20:00 hrs		
	By Coal = 15.574 MKWh			By Hydro = 2.934 MKWh			Maximum	:	-270	MW,	at	2:00 hrs		
	By Solar = 14.826 MKWh						Energy	:	1.5645	MKWh				
11.	Total Gas Supplied	:	1108.31	MMCFD										
<b>(D) Forecast of 29.08.21 (Today) Sunday :</b>														
01.	Maximum Demand	:	13500	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14423	MW	(Generation end)		05.	Total Generation	:	295.55	MKWh			
03.	Maximum Shortage	:	-923	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.8° C				

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazul Islam Shaker)  
Deputy Secretary, Generation