

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 954687, 9551095

Month September, 2021		Day : Wednesday				Date : 29.09.21							
Probable Maximum Demand :		13000 MW		Probable Maximum Generation :		14840 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 106.44 ft		Today = 106.50 ft		Rule Curve = 105.52 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.09.21 (Yesterday)		29.09.21 (Today)		28.09.21 (Yesterday) Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	310	310	310	126			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem		
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage		
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	321	303	320	320	57	Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	320	320	300	300	130	Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under overhauling		
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	372	405	412	412	7			
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	265	250	250	250				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	280	300	305	305				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	40	55	55	55				
15	Keraniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	93	50	50	50				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	98	102	102	102				
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	16	22	22				
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	54	55	55	55				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	30	52	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	100	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	64	150	149	149				
24	Kanailahat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	258	263	250	270				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	131	149	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300				
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100				
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	55	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	94	94	94	94				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	150	162	162	162				
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	21	0	30	0				
Dhaka Zone Total				5717	5560	3048	3371	3571	3891	715	793		
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	116	118	115	118		40	Unit 2 under overhauling	
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	115	115	65	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage		
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0				
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	7	25	25	25				
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	5	0	20	0				
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50				
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval		
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	75	300	300				
45	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	92	100	100	100				
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	100	100	100	100				
47	Dohazari -Kalash- 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	0	102				
48	Hafiznari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0				
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			Environment issue	
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	9	5	15				
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	48	86	85	86				
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110				
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	90	100	100	100				
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	108	90	116	116				
Chattogram Zone Total				2442	2382	1027	1260	1426	1517	245	415		
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage		
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage		
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage		
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	23	23	23				
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1175	221	221	207	212	210	210				
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	305	300	300	320				
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	12	335	300	330				
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	55	55	51	51				
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	83	83	63	63	112	Gas shortage		
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	35	35	35				
63	Ashuganj 150MW PP (Midland)	Gas (IPP)	23x7.015	150	150	132	137	135	137				
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50				
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	140	140	140	140				
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200				
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22				
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	25	25	25				
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	21	20	21				
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+1x1.059	200	200	0	0	150	200				
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	100	100	100	100				
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	48	97	90	98				
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
**	Impopt (Tripura)	India		160	160	112	130	138	164				
Cumilla Zone Total				3094	3034	1600	1976	2063	2250	510	0		
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	160	161	170	170	41	Gas Shortage		
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22				
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	0	0	0			Dependable cap. :8MW	
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115				
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	130	179	170	180				
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	36	0	50	0				
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	24	22	22				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.09.21 (Yesterday)		29.09.21 (Today)		28.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT1 Load gear problem	
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	47	50	50				
87	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	110	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	25	25	50	60	41		Gas Shortage	
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	161	158	160	160	172		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	74	78	78	78				
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	192	206	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	18	18	3		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	300	341	341				
97	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	317	316	316	316				
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
Sylhet Zone Total					2422	2377	1635	1657	1796	1806	216	117	
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	370	350	400	410				
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	32	4	32			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	120	140	225	225				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	42	105	88	105				
107	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	100	100			Line Overload	
**	Bheramara (HVDC)	India	1000	1000	1000	708	702	721	721				
Khulna Zone Total					2133	2129	1244	1329	1588	1733	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	28	30	30				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	88	87	87	87		107	Arrival of GT2 HGPI experts delayed due to covid 19	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	32	22	30	30				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	350	430	622	622		814	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	150				
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	180	227	220	220				
Barishal Zone Total					2046	2046	670	811	1099	1249	0	921	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	27	34	35				
120	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	27	27				
121	Chapsainwaganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	94	90	94				
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	0	40				
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0	43				
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0	30				
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	179	166	200	220	54		Gas Shortage	
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	193	150	200	220				
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	356	343	400	400				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	16	52	52	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total					2179	2179	1005	1276	1518	1670	435	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	78	77	77	77	8		Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	91	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
Rangpur Zone Total					655	605	176	190	198	215	8	359	
Sub-total: Plants in operation					21435	21021	10875.0	12371	13810	14840	2170	2605	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							10423	11857	13236	14223			
(B) Plants under long term maintenance/ contract expired													
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
143	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	159	0	0	0	0	0	0	
Gross Total					22031	21180	10875	12371	13810	14840	2170	2605	
(C) Actual data of 28.09.21 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	: 12371.00 MW, at = 19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 11857.00 MW, at = 19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 12371.00 MW, at = 19:30 hrs	Dhaka	4314	4314	0	Mymensingh	1013	1013	0			
04.	Minimum Generation (Generation end)	: 9181.00 MW, at = 8:00 hrs	Chattogram	1336	1336	0	Sylhet	516	516	0			
05.	Day-peak Generation (Generation end)	: 10875.00 MW, at = 12:00 hrs	Khulna	1344	1344	0	Barishal	294	294	0			
06.	Evening-peak Generation (Generation end)	: 12371.00 MW, at = 19:30 hrs	Rajshahi	1193	1193	0	Rangpur	733	733	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:30 hrs	Cumilla	1114	1114	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9031.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 2162 MW	13.	Fuel cost : (a) Gas = 161938295 Taka (c) Coal = 54666472 Taka									
b)	Low water level in Kaptai lake	: 8 MW		(b) Oil = 578503013 Taka									
c)	Plants under shut down/ maintenance	: 2605 MW		Total = 795107780 Taka									
10.	Total Energy (Generation + India Import)	: 266.59 MKWh	14.	Maximum Temperature in Dhaka was : 32.2° C									
	By Gas = 157.957 MKWh	By Oil = 73.844 MKWh	15.	Export through East-West interconnections :									
	By Coal = 11.770 MKWh	By Hydro = 2.761 MKWh		At evening peak-hour : -120 MW, at 19:30 hrs									
	By Solar = 0.556 MKWh			Maximum : -266 MW, at 20:00 hrs									
11.	Total Gas Supplied	: 1156.93 MCMCFD		Energy : 0.8425 MKWh									
(D) Forecast of 29.09.21 (Today) Wednesday :													
01.	Maximum Demand	: 13000 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 14840 MW (Generation end)	05.	Total Generation : 280.14 MKWh									
03.	Maximum Shortage	: -1840 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 33.5° C									

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation