

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month October, 2021		Day : Friday				Date : 01.10.21					
Probable Maximum Demand :		12800 MW		Probable Maximum Generation :		14891 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 106.56 ft		Today = 106.50 ft		Rule Curve = 106.00 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.09.21 (Yesterday)		01.10.21 (Today)		30.09.21 (Yesterday) Gen. shortfall for :	Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	310	300	310	310	126	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	282	331	340	340	29	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	351	0	412	412	412	
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	190	190	210	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	254	255	0	0		
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	270	280	305	305		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	55	55	55	55		
15	Karaniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	0	33	68	68		
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	64	102	102	102		
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	21	22	22		
18	Summit Power (Madhaboli+Ashulia)	Gas (SIPP, REB)	6x3.67+3x4.73	80	80	51	39	55	55		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	51	51	51		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	105	100	100		
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	0	150	149	149		
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	134	280	250	300		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149		
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	107	100	300		
28	Branhangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	100	100		
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	50	50	100		
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	94	93	94	94		
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162		
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	36	0	30	0		
Dhaka Zone Total			5717	5560	2750	3093	3574	3844	757	1198	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	159	160	159	159	40	Unit 2 under overhauling
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0		
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	50	50	50		
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	78	105	105	105		
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	286	305	300	300		
45	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	20	100	100	100		
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	100	100	100		
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	34	102		
48	Hafazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			3	19	5	15		
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	31	90	90		
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	110	110	110		
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	106	108	116	116		
Chattogram Zone Total			2442	2382	1122	1510	1514	1567	240	415	
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	80	135	55		Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	129		Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	134		Gas Shortage
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	23	23	23		
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1175	221	221	180	208	210	210		
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	305	280	360	360		
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	280	310	330		
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	52	30	55	55		
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	26	8	8	8	187	Gas shortage
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	43	43	43		
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	130	135	137		
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50		
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	138	140	140	140		
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	200	200	200	200		
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	5	11	11		
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	20	20	21		
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.015+15x1.059	200	200	0	140	150	200		
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	100	114		
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	47	87	87	87		
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
**	Impopt (Tripura)	India		160	160	118	138	138	164		
Cumilla Zone Total			3094	3034	1809	2100	2194	2412	505	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	167	192	170	190	10	Gas Shortage
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	19	22	22		
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	0	0	0		Dependable cap. : 8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	106	115	115	115		
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	150	200	170	200		
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	3	0	1.6	0		
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	31	0	50	0		
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	24	22	22		
Mymensingh Zone Total			717	709	478	550	551	549	10	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.09.21 (Yesterday)		01.10.21 (Today)		30.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	43	43		26	GT1 Load gear problem	
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	47	50	50				
87	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	62	60	60	4		Gas Shortage	
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	160	160	0	0	170		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	81	81				
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	220	220	220	220				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	280	341	341				
97	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	318	316	316	316				
98	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
Sylhet Zone Total					2422	2377	1730	1750	1657	1657	176	116	
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	355	410	400	410				
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	32	0	25			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	215	225	225				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	85	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	13	96	70	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	100	100	100			Line Overload	
**	Bheramara (HVDC)	India	1000	1000	1000	721	718	721	721				
Khulna Zone Total					2133	2129	1213	1556	1566	1726	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	20	31	30	30				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	87	87	88	88		107	Arrival of GT2 HGPI experts delayed due to covid 19	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	22	12	22	22				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	330	520	622	622		724	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	25	0	150				
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	224	224	220	220				
Barisal Zone Total					2046	2046	683	899	1092	1242	0	831	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	50	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	18	34	35				
120	Amnura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	28	28				
121	Chapsainwaganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	93	90	94				
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	0	40				
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0	50				
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0	30				
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	187	188	200	220	32		Gas Shortage	
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	189	178	200	220				
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	399	400	400	400				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	52	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	100	113	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	75	103	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Rajshahi Zone Total					2179	2179	987	1415	1519	1678	413	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	79	78	78	6		Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	70	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10				
141	Majpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
Rangpur Zone Total					655	605	154	192	199	216	6	359	
Sub-total: Plants in operation					21435	21021	10926.0	13065	13866	14891	2107	2919	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							10556	12623	13397	14387			
(B) Plants under long term maintenance/ contract expired													
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0				
143	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	159	0	0	0	0	0	0	
Gross Total					22031	21180	10926	13065	13866	14891	2107	2919	
(C) Actual data of 30.09.21 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	: 13065.00 MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 12623.00 MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	: 13065.00 MW, at = 19:00 hrs	Dhaka	4607	4607	0	Mymensingh	1050	1050	0			
04.	Minimum Generation (Generation end)	: 9254.00 MW, at = 7:00 hrs	Chattogram	1378	1378	0	Sylhet	563	563	0			
05.	Day-peak Generation (Generation end)	: 10926.00 MW, at = 12:00 hrs	Khulna	1525	1525	0	Barisal	353	353	0			
06.	Evening-peak Generation (Generation end)	: 13065.00 MW, at = 19:00 hrs	Rajshahi	1260	1260	0	Rangpur	709	709	0			
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs	Cumilla	1178	1178	0							
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9093.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 2101 MW	13.	Fuel cost :		(a) Gas = 164539388 Taka	(c) Coal = 58441435 Taka						
b)	Coal supply Limitation	: 6 MW		(b) Oil = 602657969 Taka		Total = 825638791 Taka							
c)	Low water level in Kaptai lake	: 0 MW											
d)	Plants under shut down/ maintenance	: 2919 MW	14.	Maximum Temperature in Dhaka was : 35° C									
10.	Total Energy (Generation + India Import)	: 273.13 MKWh	15.	Export through East-West interconnections :									
	By Gas = 159.726 MKWh	By Oil = 76.126 MKWh		At evening peak-hour : 58 MW, at 19:00 hrs									
	By Coal = 12.604 MKWh	By Hydro = 3.697 MKWh		Maximum : -150 MW, at 7:00 hrs									
	By Solar = 0.701 MKWh			Energy : 0.509 MKWh									
11.	Total Gas Supplied	: 1160.24 MMCFD											
(D) Forecast of 01.10.21 (Today) Friday :													
01.	Maximum Demand	: 12800 MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 14891 MW (Generation end)	05.	Total Generation : 267.59 MKWh									
03.	Maximum Shortage	: -2091 MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 34° C									

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation