

**EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : 10-Oct-21

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-1	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-2	PDB	1210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1210	190	0	0	Gas shortage
3	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	280	7069091	Machine problem
4	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Contract Expired
4	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	0	0	Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCGP	EGCB	1273+1139	412	301	7362660	Gas shortage
7	Haripur 360MW CCGP(HPL)	IPP	1235+1125	360	157	5494000	Gas shortage
8	Meghnaghat 450 MW CCGP(MPL)	IPP	2*150+1*150	450	250	6112000	Gas shortage
9	Meghnaghat 100 MW(EL)	ORPP	12*8.9	0	0	0	Contract Expired
10	Meghnaghat CCGP(Summit)	IPP	2*110+1*110	305	305	6668229	FGMO
11	Madanganj 102 PP(Summit)	ORPP	6*17	0	0	0	Contract Expired
12	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	55	1206518	
13	Karanganj 100 MW PP (Powerpac)	ORPP	8*13.45	100	50	729100	Engine problem
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.80	22	18	406692	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirgonj 100 PP(Dutch Bangla)	ORPP	12*8.9	0	0	0	Contract Expired
18	Siddhirgonj 335 MW CCGP	EGCB	1217+118	335	280	6800476	Gas shortage
19	Sagarajal 102 MW PP (Digital Po)	IPP	12*8.924	102	102	192352	
20	Katohli 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	
21	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	54	1254600	
22	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	150	2406720	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	1330196	
24	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	55	816193	
25	Bosia 108MW RPCL	IPP	12*9.75+1*13.5	0	0	0	
26	Summit Power (Madhabdi-Ashuli)	SIPP, REB	3*3.67+4*8.73	80	53	1269960	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	790600	
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	716500	
29	Gazipur 52 MW PP	RPCL	6*8.9	52	50	875520	
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Engine problem
31	Kodda 300 MW Unit-2 (Summit)	IPP	18*17.076	300	283	6474870	
32	Karanganj 300 MW PP (APR)	IPP	25*11.4	300	308	1535107	
33	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	100	721633	
34	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	98	830522	
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	131	3135456	Engine problem
36	Gazipur 100 MW PP	RPCL	100 MW	105	105	2319600	
37	Meghnaghat 104 MW PP (QPCL)	IPP	18*5.9	104	104	2654000	
38	Manikganj 162MW (MPL)	IPP	9*18	162	162	3929500	
39	Spectra Solar Plant Ltd	IPP	35	35	0	191390	
<b>Dhaka area Total</b>				<b>5560</b>	<b>3572</b>	<b>75039054</b>	
40	Chattoagram TPP-1	PDB	1*210	180	110	2700000	Gas shortage
41	Chattoagram TPP-2	PDB	1*210	180	0	0	Gas shortage
41	Razzan 25 MW PP	IPP	3*8.9	25	25	3911109	
42	Bakura 20MW PP (SolarTech/Teknaf SolarTech Energ	IPP	20	20	0	134460	
43	Palenga 50MW PP (Baraka)	IPP	8*6.98	50	50	1007040	
44	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	159	3869849	Low water level
45	Sikalbaha 225MW	PDB	1*150+1*175	225	0	0	Under maint.
46	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
47	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	2385298	
48	Hathazari 100 MW peaking PP	PDB	11*8.9	99	0	0	Under S/D
49	Dobhasari-Katohli 100 MW Peaker	PDB	6*17	102	85	1372683	Engine problem
50	Juidah 100 MW Unit-1 (Acorn)	ORPP	8*13.45	100	80	1498920	Engine problem
51	Juidah 100 MW PP Unit-3 (Acorn)	IPP	0	100	90	2071680	Engine problem
52	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	16	363360	Engine problem
*	Malancha, Cig, EPZ (Unite)		5*8.73+3*9.34	0	14	403680	
53	Chattoagram 108 MW PP (ECPV)	IPP	16*7	108	88	1299840	Engine problem
54	Kaptai 7 MW Solar PP	PDB	7*4.00	7	7	23160	
55	Anwara 300 MW PP (Unite)	IPP	300 MW	300	304	7236218	
56	Jodac Power	IPP	3*18.55+1*3.6	54	36	997681	Engine problem
57	Karnaphuli Power Ltd.	IPP	110	110	110	2450543	
58	Juidah unit-2 (Acorn)	IPP	8*13.6	100	100	2360640	
59	Anilma Energy Ltd.	IPP	6*21.2	116	97	2598164	Engine problem
<b>Chattoagram area Total</b>				<b>2382</b>	<b>1469</b>	<b>53170325</b>	
60	Ashuganj TPP Unit-3	APSCL	1*150	135	80	1858568	Gas shortage
61	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
62	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
61	Ashuganj 225 MW CCGP	APSCL	1*142+1*75	221	127	3227000	ST under maint
62	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	280	7085500	FGMO
63	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	300	7090900	FGMO
64	Ashuganj 50 MW PP	IPP	4*3.968	45	23	465972	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	51	1242660	
66	Ashuganj 195MW PP (APSCL-UR)	IPP	20*9.73+1*16	195	8	200727	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1234472	
68	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	128	3030981	Engine problem
69	Titas 50 MW Peaking PP	PDB	6*8.92	50	50	628712	
70	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	140	3331120	Machine problem
71	Chandpur 200MW (Reneg energy)	IPP	0	200	180	4311120	Engine problem
72	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	437400	
73	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	8	170280	Engine problem
**	Imoport (Tripura)	Imported power	0	160	152	3175680	
74	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	798900	
75	Jangalia 52 MW PP (Lakdhanav)	IPP	6*8.92	52	52	1078704	
76	Comilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*6.97	25	21	519040	
77	Dauidkandi 200 MW PP (B. Trac)	IPP	15*11.4	200	200	1408512	
78	Feni Lanka Power	IPP	7*18.415+1*9.78	114	80	1370280	Engine problem
79	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	86	1414560	Engine problem
80	Bhairab 54.5 MW	IPP	3*18.2	54	17	443880	33 KV feeder fault.
<b>Comilla Area Total</b>				<b>3034</b>	<b>2086</b>	<b>44438268</b>	
81	RPCL 210MW CCGP	IPP	4*36+1*70	202	117	2946160	Gas shortage
82	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	464400	
83	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	8	0	0	Under maint.
84	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	13600	
85	Mymensingh 200 MW PP (Unite)	IPP	200	200	190	4279200	
86	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	115	2446800	
87	Sulakhalai 50 MW Solar PP	IPP	50	50	0	339230	
88	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	22	397380	
<b>Mymensingh Area Total</b>				<b>622</b>	<b>465</b>	<b>10886590</b>	
89	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	70	43	1031000	Machine problem
90	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	42	997320	Machine problem
91	Kushara 163 MW CCGP (KP)	IPP	1*109+1*54	163	163	3306354	
92	Shahjibazar 330 MW CCGP	PDB	3*110	330	160	3608000	GT-2 under maint
93	Fenchugonj 51 MW PP (Barakata)	RPP	18*2.90	51	47	1142400	
94	Fenchugonj 44MW (Confidence-E)	RPP	12*3.34+2	0	0	0	Contract Expired
94	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	264000	
95	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	56	1309824	
96	Shahjibazar 86MW PP (Shahjibaz)	RPP	32*2.90	86	81	1926440	
97	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under Shut down
98	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	0	0	Under maint.
99	Sylhet 20 MW CCGP	PDB	1*20	20	18	390000	
100	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
100	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	24	557088	
101	Bibiana-II 341 MW CCGP (Summit)	IPP	1*222+1*119	341	310	7173500	FGMO
102	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	322	7780000	Gas shortage
103	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	250740	
104	Bibiyana South 400 MW	PDB	400 MW	385	320	7624100	Gas shortage
<b>Sylhet Area Total</b>				<b>2377</b>	<b>1607</b>	<b>3726266</b>	
105	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	Reserve.
**	Bheramara (HVDC)	Imported power	2*500	1000	699	16912727	
106	Khulna 115 PP MW (KPCL-2)	ORPP	7*17	0	0	0	Contract Expired
107	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	32	300480	Engine problem
108	Khulna 225 MW CCGP	NWPGCL	1*150+1*75	230	223	4486080	
109	Opapatti 100 MW Peaking PP	IPP	10*9.8	100	0	0	Reserve.
110	Bheramara 410 MW CCGP	NWPGCL	1*278+1*132	410	270	7233984	Gas shortage
111	Noapara 40 MW PP (Khanjahan A)	ORPP	5*8.5	0	0	0	Contract Expired
111	Noapara 100 MW PP (Bangla Tri)	IPP	70*1.4	100	100	567360	
112	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	88	1931040	Engine problem
113	Madhumati 100 MW PP	NWPGCL	100 MW	105	28	172944	Line O/L
<b>Khulna Area Total</b>				<b>2129</b>	<b>1440</b>	<b>31604915</b>	
114	Barsail 110 MW PP (Summit)	IPP	7*17.076	110	16	41952	Line O/L
115	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	30	660245	
116	Bhola 225 MW CCGP	PDB	2*63+1*68	194	65	1570000	Machine problem
117	Bhola 95 MW PP (Aggreko)	ORPP	96*1.10	95	17	407351	Gas shortage
118	Payra 1320 MW	BCPCL	2*622	1244	622	13336000	
119	Bhola Nutan Bidout BD LTD	IPP	220	220	220	5179390	
120	Unite Payra Power Ltd.	IPP	8*18.5+1*9.5	150	72	544680	Line O/L
<b>Barisal Area Total</b>				<b>2046</b>	<b>1042</b>	<b>21737338</b>	
121	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
121	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
122	Baghabari 50 MW Peaking PP	PDB	6*8.9	50	50	705216	
123	Bera 70 MW Peaking PP	PDB	9*8.29	71	33	253482	Engine problem
124	Amnara 50 MW PP(Sinha)	ORPP	7*7.79	50	0	0	Engine problem
125	Katakhalai 50 MW PP (Northern)	ORPP	6*8.9	50	43	230374	Engine problem
126	Katakhalai 50 MW Peaking PP	PDB	6*8.7	50	40	203897	Engine problem
127	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
128	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	156	4053509	Gas shortage
129	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	192	4627373	Gas shortage
130	Sirajgonj 400 MW CCGP Unit-4	SNWPGCL	1*282+1*132	414	408	9295345	FGMO
131	Saitaha 50 MW Peaking PP	PDB	6*8.7	50	33	448180	Engine problem
132	Bogra 22 MW PP (GBB)	RPP	6*4	22	20	470640	
133	Bogra 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	Contract Expired
134	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	242982	
135	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	797760	
136	Chapainawabganj 100 MW Peaking	PDB	12*8.924	104	93	1077216	Engine problem
137	Baghabari 200 MW PP (Paramou)	IPP	200 MW	200	158	603683	Engine problem
138	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	2591232	
139	Confidence Power Bogura Unit-1	IPP	6*18.55	113	113	2529272	
140	Sirajgonj 6.55 MW Solar	NWPGCL	1*6	6	0	33	